NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE	W A W N P 2 (2)
	LICENSE NUMBER	0 0 - 0 0 0 0 0 - 0 0 (3)
	LICENSE TYPE	4 1 0 0 0 (4)
	CAT	(5)
CON'T 0 1	REPORT SOURCE	L (6)
	DOCKET NUMBER	0 5 0 0 0 3 9 7 (7)
	EVENT DATE	1 2 2 3 8 3 (8)
	REPORT DATE	0 1 2 0 8 4 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Plant modification required removal of fire rated seals to perform
0 3 construction work. The ineffective fire rated seals constitute a loss
0 4 of fire boundary integrity per Tech. Spec. 3/4.7.7. The action statement
0 5 of Tech. Spec. 3/4.7.7.a was instituted and potential consequences were
0 6 minimal. Seals - RM C206-2005.4; C209-3001.5; C237-1003, 1003.1;
0 7 C304-4011, 4011.1, 5003, 5004; R13-1001B; R105-4004.1; R206-4222, 4222.1,
0 8 5004.

0 9		
SYSTEM CODE	Z Z	(11)
CAUSE CODE	B	(12)
CAUSE SUBCODE	Z	(13)
COMPONENT CODE	Z Z Z Z Z Z	(14)
COMP. SUBCODE	Z	(15)
VALVE SUBCODE	Z	(16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 3	—	0 0 5	/	0 3	L	—	

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Plant modification required removal of the seals. Seals will be replaced
1 1 as soon as the associated construction work is completed. In the interim,
1 2 the action statement of Tech. Spec. 3/4.7.7.a was instituted.
1 3
1 4

1 5		
FACILITY STATUS	B	(28)
% POWER	0 0 0	(29)
OTHER STATUS (30)	N/A	
METHOD OF DISCOVERY	Z	(31)
DISCOVERY DESCRIPTION (32)	N/A	

1 6		
ACTIVITY RELEASED	Z	(33)
CONTENT OF RELEASE	Z	(34)
AMOUNT OF ACTIVITY (35)	N/A	
LOCATION OF RELEASE (36)	N/A	

PERSONNEL EXPOSURES

1 7		
NUMBER	0 0 0	(37)
TYPE	Z	(38)
DESCRIPTION (39)	N/A	

PERSONNEL INJURIES

1 8		
NUMBER	0 0 0	(40)
DESCRIPTION (41)	N/A	

LOSS OF OR DAMAGE TO FACILITY (43)

1 9		
TYPE	Z	(42)
DESCRIPTION	N/A	

PUBLICITY

2 0		
ISSUED	N	(44)
DESCRIPTION (45)	N/A	

NRC USE ONLY

NAME OF PREPARER R. D. Catlow PHONE: (509)377-2501 Ext. 4755

8402030380 840120
PDR ADOCK 05000397
S PDR