

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[01] S I C V I C B 1 [2] 0 0 - 0 0 0 0 0 - 0 0 [3] 4 1 0 0 0 [4] [] [] [5]

CON'T REPORT SOURCE [6] 0 5 0 0 0 1 3 1 9 1 5 [7] 0 1 6 1 6 1 8 3 [8] 0 7 1 4 8 3 [9]

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES [10] On June 16 (1400 hours) and June 27, 1983, (2300 hours), with the Plant in Mode 1, RML-8, Turbine Building Sump Radiation Liquid Effluent Monitor, was declared inoperable due to low sample flow. There were no adverse consequences due to this event because compliance was maintained with the Technical Specification 3.3.3.8, Table 3.3-12, Action Statement 33.

SYSTEM CODE [11] M B CAUSE CODE [12] X CAUSE SUBCODE [13] Z COMPONENT CODE [14] X K X X X K X K X COMP. SUBCODE [15] K VALVE SUBCODE [16] L LER/RO REPORT NUMBER [17] 8 8 EVENT YEAR [18] 8 8 SEQUENTIAL REPORT NO. [19] 6 6 3 OCCURRENCE CODE [20] 1 REPORT TYPE [21] 1 REVISION NO. [22] 1 ACTION TAKEN [23] F FUTURE ACTION [24] 2 EFFECT ON PLANT [25] 2 SHUTDOWN METHOD [26] 2 HOURS [27] 0 0 0 0 ATTACHMENT SUBMITTED [28] N NPRD-4 FORM SUB. [29] N PRIME COMP. SUPPLIER [30] 7 COMPONENT MANUFACTURER [31] 7 0 0 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS [27] This event was due to accumulation of trash in the "Sample Monitor Inlet Isolation Valve," XVX-59714. The valve was disassembled, cleaned, and declared operable June 16 (2130 hours) and June 28, 1983, (0300 hours). Modification Request Form (MRF) 10716 is presently being reviewed by Nuclear Engineering for installation of a filter in the sample suction line to preclude recurrence.

FACILITY STATUS [32] E % POWER [33] 0 5 OTHER STATUS [34] N/A METHOD OF DISCOVERY [35] 1 DISCOVERY DESCRIPTION [36] Operator Observation

ACTIVITY CONTENT RELEASED OF RELEASE [37] 2 AMOUNT OF ACTIVITY [38] N/A LOCATION OF RELEASE [39] N/A

PERSONNEL EXPOSURES NUMBER [40] 0 0 0 TYPE [41] 3 DESCRIPTION [42] N/A

PERSONNEL INJURIES NUMBER [43] 0 0 0 DESCRIPTION [44] N/A

LOSS OF OR DAMAGE TO FACILITY TYPE [45] 2 DESCRIPTION [46] N/A

PUBLICITY ISSUED [47] N DESCRIPTION [48] N/A

NAME OF PREPARER [49] R. J. Bouknight PHONE [50] (803) 345-5209

8307250138 830714 PDR ADOCK 05000395 S PDR

IE 22 1/1

NRC USE ONLY

USNRC
SOUTH CAROLINA ELECTRIC & GAS COMPANY
POST OFFICE 764
COLUMBIA, SOUTH CAROLINA 29218

83 JUL 19 A10:30

O. W. DIXON, JR.
VICE PRESIDENT
NUCLEAR OPERATIONS

June 14, 1983

Mr. James P. O'Reilly
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II, Suite 2900
101 Marietta Street, N.W.
Atlanta, Georgia 30303


SUBJECT: Virgil C. Summer Nuclear Station
Docket No. 50/395
Operating License No. NPF-12
Thirty Day Written Report
LER 83-063

Dear Mr. O'Reilly:

Please find attached Licensee Event Report #83-063 for Virgil C. Summer Nuclear Station. This Thirty Day Report is required by Technical Specification 6.9.1.13.(b) as a result of entry into Action Statement 33 of Technical Specification 3.3.3.8, Table 3.3-12, "Radioactive Liquid Effluent Monitoring," on June 16, 1983.

Should there be any questions, please call us at your convenience.

Very truly yours,


O. W. Dixon, Jr.

RJB:OWD/dwf
Attachment

cc: V. C. Summer
E. H. Crews, Jr.
T. C. Nichols, Jr., /O. W. Dixon, Jr.
E. C. Roberts
H. N. Cyrus
Group/General Managers
O. S. Bradham
R. B. Clary
C. A. Price
A. R. Koon
D. A. Lavigne
C. L. Ligon (NSRC)
G. J. Braddick
J. C. Miller
J. L. Skolds
J. B. Knotts, Jr.
I&E (Washington)
Document Management
Branch
INPO Records Center
NPCF
File (Lic./Eng.)

OFFICIAL COPY

IE 22/11