Georgia Power Company 333 Piedmont Avenue Atlanta, Georgia 30308 Telephone 404 526-7726

Mailing Address. Post Office Box 4545 Atlanta, Georgia 30302



D. O. Foster Vice President and General Manager Vogtle Project

January 27, 1984

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Washington, D.C. 20555 Log: GN306 File: X7N00.02

NRC DOCKET NUMBERS 50-424 AND 50-425
CONSTRUCTION PERMIT NUMBERS CPPR-108 AND CPPR-109
VOGILE ELECTRIC GENERATING PLANT - UNITS 1 AND 2
APPLICATION FOR OPERATING LICENSES
AMENDMENT NUMBER 3

Dear Mr. Denton:

Georgia Power Company, acting on its own behalf and as agent for Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and the City of Dalton, Georgia, hereby submits Amendment 3 to its Application for Operating Licenses for the Vogele Electric Generating Plant - Units 1 and 2. Included in this transmittal are instructions for inserting this amendment.

This amendment consists of editorial changes to correct errors in cross references, typographical errors, incorrect units of measure, table column and row alignment etc. More substantial revisions due to data corrections, design changes, or clarification of operator actions are tabulated in Attachment 1 to this letter. It is felt that these corrections will aid in your review which is scheduled to commence on February 1, 1984.

In accordance with the requirements of 10 CFR 50.30(b) and (c), three (3) signed originals and sixty (60) copies of Amendment 3 are submitted for your use.

Yours truly,

D. O. Foster

DOF/KWK/sw Enclosures xc: List attached.

B001

8402030400 840127 PDR ADDCK 05000424 K PDR Mr. Harola R. Denton, Director January 27, 1984 Page 2

Log: GN306 File: X7N00.02

xc: M. A. Miller

R. A. Thomas

D. E. Putton

J. A. Bailey

O. Batum

L. T. Gucwa

G. Bockhold, Jr.

G. F. Trowbridge, Esquire

D. G. Eisenhut

SWORN AND SUBSCRIBED BEFORE ME, THIS

Notary Public, Georgia State at Large Notary Public, Georgia, State at Large

My Commission Expires March 21, 1985

AMENDMENT 3

Tabulation of Revisions

FSAR Section	Reason for Revision				
1.6	Add Table 1.6-3 for addition of AE Topical Reports.				
1.7	Update revision numbers of listed drawings.				
1.9	Addition of revision numbers of Regulatory Guides, editorial corrections.				
1.9	Invoking ANSI/ANS-3.3-1982 vice ANSI N18.7-1973 for RG 1.17.				
2.2	Provide results of fire analysis. Q311.3.				
2.3	Correct column headings in Table 2.3.5-11.				
3.2	Removal of requirement for qualification of safety injection system heat tracing.				
3.2	Misc. changes to project classification table.				
3.8	Clarify description of electrical penetrations.				
3.9	Implementation of computer program ME-140 for analysis of pipe supports.				
3.9	BOP active valve update of Table 3.9.B.3-9.				
4.2	Correct dimensional data of thimble plug assembly.				
4.3	Axial power distribution is controlled by manual rather than automatic actions.				
5.2	Correct description of RCS cold overpressure protection.				
6.2	Revision of hydrogen concentration calculations to reflect no recombiner operation.				
6.2 Containment cooler fans included in the maintenance program.					

FSAR Section	Reason for Revision					
6.3	Switch over time from cold to hot leg recirculation changed to provide consistency in text.					
6.4	Clarification of operator actions upon warning of smoke in the control room.					
7.3	Revised to reflect conditions which will automatically or manually initiate control room ventilation isolation.					
7.7	Revised to reflect results of control system interaction analysis.					
8.2	Updated to reflect transmission line construction.					
8.3	Additional diesel trips listed.					
8.3	Revise to clarify system design with respect to class IE dc power supply to inverters.					
8.3	Revised to correct description of equipment subject to containment flooding.					
9.1	Correct description of makeup water to spent fuel pool.					
9.1	Add description of monorail hoist in auxiliary building.					
9.1	Correct description of new and spent fuel storage facilities.					
9.2	Revised to reflect deletion of condensate storage tank heaters.					
9.2	Corrections to chilled water system FMEA due to internal design review.					
9.3	Correction of description of drain piping.					
9.3	Corrected switch numbers in Table 9.3.3-3.					
9.3	Revised to reflect addition of sump to electric boiler building.					
9.4	Corrected airflow rate of containment coolers in Table 9.4.6-1.					

FSAR Section	Reason for Revision				
9.5	Corrections and clarifications to the diesel fuel oil storage and transfer system.				
9В	Correct description of where PVC is used.				
10.1	Corrected orientation of FW bypas check valves.				
10.4	Corrected description of AFW system.				
10.4	Corrected description of steam generator blowdown processing system.				
11.5	Corrected description of radwaste building duct material and thickness.				
12.3	Corrected valve thickness and civil terminology.				
12.3	Revised to conform to system design.				
13.1	Corrected titles of supervisory and management positions.				
15.5	Clarify operator action upon receipt of a superious safety injection signal.				
18.1	Revised to reflect electric aux board nameplate color change.				
Q/R Sept. 6, 1983					
Letter	Revised response to Q 271.1				
Q/R Sept. 6, 1983					
Letter	Revised response to Q 630.1				

Southern Company Services, Inc.

Date:	January	27,	1984
-------	---------	-----	------

Re: Vogtle Electric Generating Plant

Final Safety Analysis Report

From: R. T. Oedamer

Supervisor, Technical Writing

Engineering Technical Services Department

To: DENTON H
ROOM NRC

7928 NORFOLK AVENUE BETHESDA MD 28814

Attached are changes to be inserted in your copy of the subject manual. Please revise your manual according to the Revision Insertion Instructions provided and destroy all superseded material. If the attached package of change pages does not correspond to the insertion instructions provided, notify Trinket Shaw, ext. 6837.

PLEASE SIGN BELOW AND RETURN THIS ENTIRE ACKNOWLEDGEMENT RECEIPT PAGE WITHIN 15 WORK DAYS FROM THE ABOVE DATE TO:

Supervisor, Technical Writing Room 102, Metroplex IV SCS Birmingham

Manual	Title	Vogtle Ele	ectric	Generating	Plant	Final	Safety	
		Analysis F						
Name				Manual No.		R	ev. Date	1/27/84

Georgia Power

O. O. Foster

0.1.45 - 0.1.1.45

January 27, 1984

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Afternoon der Jen

Log: GN306 File: X7N00.02

NRC DOCKET NUMBERS 50-424 AND 50-425
CONSTRUCTION PERMIT NUMBERS CPPR-108 AND CPPR-109
VOGTLE ELECTRIC GENERATING PLANT - UNITS 1 AND 2
APPLICATION FOR OPERATING LICENSES
AMENDMENT NUMBER 3

Dear Mr. Denton:

Georgia Power Company, acting on its own behalf and as agent for Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and the City of Dalton, Georgia, hereby submits Amendment 3 to its Application for Operating Licenses for the Vogtle Electric Generating Plant - Units 1 and 2. Included in this transmittal are instructions for inserting this amendment.

This amendment consists of editorial changes to correct errors in cross references, typographical errors, incorrect units of measure, table column and row alignment, etc. More substantial revisions due to data corrections, design changes, or clarification of operator actions are tabulated in Attachment 1 to this letter. It is felt that these corrections will aid in your review which is scheduled to commence on February 1, 1984.

In accordance with the requirements of 10 CFR 50.30(b) and (c), three (3) signed originals and sixty (60) copies of Amendment 3 are submitted for your use.

14.0.0

DOF/KWK/sw Enclosures xc: List attached. Mr. Harold R. Denton, Director January 27, 1984 Page 2

Log: GN306 File: X7N00.02

xc: M. A. Miller

R. A. Thomas

D. E. Dutton

J. A. Bailey

O. Batum

L. T. Gucwa

G. Bockhold, Jr.

G. F. Trowbridge, Esquire

D. G. Eisenhut

SWORN AND SUBSCRIBED BEFORE ME, THIS

27 th DAY OF

1984

Notary Public, Georgia State at Large