

APPENDIX A

NOTICE OF VIOLATION

GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station

Docket No. 50-219
License No. DPR-16

As a result of an inspection conducted on November 29, 1983 to December 2, 1983, and in accordance with the NRC Enforcement Policy, 10 CFR 2, Appendix C, the following violation was identified:

10 CFR 71.12(a) is a general license issued to any licensee of the Commission to transport licensed material in a package for which a certificate of compliance has been issued by the NRC. 10 CFR 71.12(c) requires a licensee using such a package to have a copy of the certificate of compliance for the package, and the licensee must comply with the terms and conditions of the certificate.

Condition No. 9 of Certificate of Compliance (C of C) No. 6601 for package Model No. CNS 8-120, requires the drain line and access plugs to be appropriately plugged and sealed prior to transport.

Contrary to the above, package Model No. CNS 8-120, Certificate of Compliance No. 6601, was used to transport 42 Curies of licensed material on November 2, 1983, and the drain line and access plugs were not verified to be appropriately plugged and sealed prior to transport.

This is a Severity Level V violation (Supplement V).

The GPU Nuclear Corporation is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8402060040 840117
PDR ADDCK 05000219
PDR
G