

JUL 19 1983

Docket No. 50-289

Mr. Henry D. Hukill
Vice President
GPU Nuclear Corporation
P. O. Box 480
Middletown, Pennsylvania 17057

DISTRIBUTION
Docket File
NRC PDR
L PDR
ORB#4 Rdg
DEisenhut
OELD
NSIC
EJordan
JTaylor
ACRS-10
JVanVliet
RIngram
Gray File
EBlackwood
Hornstein

DMB-d6

Subject: NUREG-0737 ACTION ITEMS II.F.1.4 "CONTAINMENT PRESSURE MONITOR",
II.F.1.5. "CONTAINMENT WATER LEVEL MONITOR", II.F.1.6 "CONTAIN-
MENT HYDROGEN MONITOR"

Dear Mr. Hukill:

With respect to the subject action items for TMI-1, we request that you provide the information described in the enclosure within 30 days of receipt of this letter. Should you have any questions, or require clarification, please contact your NRC Project Manager.

This request for information was approved by office of Management and Budget under clearance number 3150-0065 which expires September 30, 1985.

~~ORIGINAL SIGNATURE~~
JOHN F. STOLZ

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure
As stated

cc: w/enclosure
See next page

8308040166 830719
PDR ADOCK 05000289
P PDR

OFFICE ▶	ORB#4:DL	ORB#4:DL					
SURNAME ▶	JVanVliet;ps	JStolz					
DATE ▶	7/19/83	7/19/83					

Mr. R. J. Toole
Manager, TMI-1
GPU Nuclear Corporation
P. O. Box 480
Middletown, Pennsylvania 17057

Board of Directors
P. A. N. E.
P. O. Box 268
Middletown, Pennsylvania 17057

*Docking and Service Section
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Chauncey Kepford
Judith H. Johnsrud
Environmental Coalition on Nuclear Power
433 Orlando Avenue
State College, Pennsylvania 16801

*Judge Reginald L. Gotchy
Atomic Safety & Licensing Appeal Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

J. B. Lieberman, Esq.
Berlock, Israel & Lieberman
26 Broadway
New York, New York 10004

Regional Administrator
U. S. N. R. C., Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

ANGRY/TMI PIRC
1037 Maclay Street
Harrisburg, Pennsylvania 17103

John Levin, Esq.
Pennsylvania Public Utilities
Commission
Box 3265
Harrisburg, Pennsylvania 17120

Jordan D. Cunningham, Esq.
Fox, Farr and Cunningham
2320 North 2nd Street
Harrisburg, Pennsylvania 17110

Ms. Louise Bradford
TMIA
1011 Green Street
Harrisburg, Pennsylvania 17102

Ms. Marjorie M. Aamodt
R. D. #5
Coatesville, Pennsylvania 19320

Earl B. Hoffman
Dauphin County Commissioner
Dauphin County Courthouse
Front and Market Streets
Harrisburg, Pennsylvania 17101

Union of Concerned Scientists
c/o - Harmon & Weiss
1725 I Street, N. W.
Suite 506
Washington, D. C. 20006

Mr. Steven C. Sholly
Union of Concerned Scientists
1346 Connecticut Avenue, N. W.
Dupont Circle Building, Suite 1101
Washington, D. C. 20036

* Gary J. Edles, Chairman
Atomic Safety & Licensing Appeal
Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

* Dr. John H. Buck
Atomic Safety & Licensing Appeal
Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Thomas Gerusky
Bureau of Radiation Protection
Department of Environmental Resources
P. O. Box 2063
Harrisburg, Pennsylvania 17120

Federal Emergency Management Agency
ATTN: Docket Clerk
1725 I Street, NW
Washington, DC 20472

Karin W. Carter, Esq.
505 Executive House
P. O. Box 2357
Harrisburg, Pennsylvania 17120

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Dauphin County Office Emergency
Preparedness
Court House, Room 7
Front & Market Streets
Harrisburg, Pennsylvania 17101

Mr. E. G. Wallace
Licensing Manager
GPU Nuclear Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054

William S. Jordan, III, Esq.
Harmon & Weiss
1725 I Street, NW, Suite 506
Washington, DC 20006

Ms. Lennie Prough
U. S. N. R. C. - TMI Site
P. O. Box 311
Middletown, Pennsylvania 17057

Ms. Virginia Southard, Chairman
Citizens for a Safe Environment
264 Walton Street
Lemoyne, Pennsylvania 17043

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. David D. Maxwell, Chairman
Board of Supervisors
Londonderry Township
RFD#1 - Geyers Church Road
Middletown, Pennsylvania 17057

Mr. C. W. Smyth
Supervisor of Licensing TMI-1
GPU Nuclear Corporation
P. O. Box 480
Middletown, Pennsylvania 17057

Regional Radiation Representative
EPA Region III
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Mr. Richard Conte
Senior Resident Inspector (TMI-1)
U.S.N.R.C.
P. O. Box 311
Middletown, Pennsylvania 17057

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
P. O. Box 1323
Harrisburg, Pennsylvania 17120

REQUEST FOR ADDITIONAL INFORMATION ON THREE NUREG-0737 ITEMS

II.F.1.4 CONTAINMENT PRESSURE MONITOR

II.F.1.5 CONTAINMENT WATER LEVEL MONITOR

II.F.1.6 CONTAINMENT HYDROGEN MONITOR

(1) EXCEPTIONS BEING TAKEN TO NUREG-0737 REQUIREMENTS

(1a) The submittals we have received to date do not indicate that you plan to take any exceptions to the NUREG-0737 requirements. Please indicate any exceptions you plan of which we are not aware. For each exception indicate (1) why you find it difficult to comply with this item, (2) how this exception will affect the monitor system accuracy, speed, dependability, availability, and utility, (3) if this exception in any way compromises the safety margin that the monitor is supposed to provide, and (4) any extenuating factors that make this exception less deleterious than it appears at face value.

(2) II.F.1.4 - PRESSURE MONITORING SYSTEM (PMS) - ACCURACY & TIME RESPONSE

(2a) Provide a block diagram of the configuration of modules that make up your PMS. Provide an explanation of any details in the block diagram that might be necessary for an understanding of your PMS accuracy and time response.

(2b) For each module provide a list of all parameters* which describe the overall uncertainty in the transfer function of that module.

(2c) Combine** parameters in 2b to get an overall system uncertainty. If you have both strip chart recorder and indicator output, give the overall system uncertainty for both systems. If you have systems spanning different ranges, give the overall system uncertainty for each system.

(2d) For each module indicate the time response***.
For modules with a linear transfer function, state either the time constant, τ , or the Ramp Asymptotic Delay Time, *RADT*.
For modules with an output that varies linearly in time, state the full scale response time. (Most likely the only module you have in this category is the strip chart recorder.)

(2e) We will compute the overall system time response for you****.

(3) II.F.1.5 ---- WATER LEVEL MONITORING SYSTEM (WLMS) ---- ACCURACY

(3a) Provide a block diagram of the configuration of modules that make up your WLMS. Provide an explanation of any details in the block diagram that might be necessary for an understanding of your WLMS accuracy.

(3b) For each module provide a list of all parameters* which describe the overall uncertainty in the transfer function of that module.

(3c) Combine** parameters in 3b to get an overall system uncertainty. If you have both strip chart recorder and indicator output, give the overall system uncertainty for both systems. If you have systems spanning different ranges, give the overall system uncertainty for each system.

(4) II.F.1.6 ---- HYDROGEN MONITOR SYSTEM (HMS) ---- ACCURACY & PLACEMENT

(4a) Provide a block diagram of the configuration of modules that make up your HMS. Provide an explanation of any details in the block diagram that might be necessary for an understanding of your HMS accuracy. If you have different types of HMSs give this information for each type.

(4b) For each module provide a list of all parameters* which describe the overall uncertainty in the transfer function of that module.

(4c) Combine** the parameters in 4b to get an overall system uncertainty. If you have both strip chart recorder and indicator output, give the overall system uncertainty for both systems.

- (4d) Indicate the placement and number of hydrogen monitor intake ports in containment. Indicate any special sampling techniques that are used either to examine one region of containment or to assure that a good cross section of containment is being monitored.
- (4e) Are there any obstructions which would prevent hydrogen escaping from the core from reaching the hydrogen sample ports quickly?

* UNCERTAINTY PARAMETERS

The measure of overall system uncertainty we wish to obtain is the standard deviation, S . In order to compute the overall standard deviation of a system we need the standard deviations of each type of measurement error associated with each module. Therefore all module uncertainty parameters should be expressed as one standard deviation. Also, to simplify the final computation, all uncertainty parameters should be expressed as a percentage of full range of the module.

We will assume that all error components have a normal density function unless some other density function is specifically indicated.

The vendor may quote the upper limit for a random variable which is either implicitly or explicitly assumed to have a normal density function. In this case, by convention, one third the upper limit can be taken as the standard deviation. The convention of using this as the standard deviation is based on the fact that if a random sample of 1000 values of the variable are drawn from the parent population of that variable, then we would expect about 997 of the values to be less than three standard deviations. Thus three standard deviations is a good practical upper limit for the variable. (By comparison we would expect about 683 of the values to be less than one standard deviation.)

Generally, the greatest part of the uncertainty of the transfer function of a module is the random bias, and when the vendor quotes only one number as a measure of module accuracy, this number is a measure of the random bias.

In addition to the random bias, other factors which may contribute to the overall uncertainty in the transfer function of a module are:

- (1) Random error. (Sometimes called reproducibility, repeatability, or precision.)
- (2) Uncertainty due to temperature effects. (State environmental conditions.)
- (3) Uncertainty in power supply voltage.
- (4) Flow measurement uncertainty for the hydrogen monitor.
- (5) If the transducer and transmitter are separate modules, be sure to consider the uncertainty in each.
- (6) Hysteresis effect.
- (7) Deadband effect.

**** STANDARD DEVIATION OF TOTAL SYSTEM UNCERTAINTY**

To obtain the standard deviation of the total system uncertainty, the standard deviations of the module random biases can be combined Root-Sum-Square (RSS). Also the standard deviations of the first 5 of the 7 items listed under (*) can be combined in the same RSS. Call the final result

$$S(\text{total system, bias etc.}) = S(s,b)$$

For systems exhibiting hysteresis and deadband effects, the standard deviation of the total error is a function of the pattern of time variation of the monitored variable. Hence it is not possible to derive an algorithm for the standard deviation that is applicable to all cases. The following algorithm, which is developed in reference 2, provides an upper bound for the standard deviation in virtually any realistic situation, and we recommend that all licensees use this algorithm for computing hysteresis and deadband errors.

- (1) Determine the hysteresis loop half width, $H(j)$, and the deadband half width, $D(j)$, for each module (j). Note that for most modules $H(j)$ and $D(j)$ are zero.
- (2) Combine the $H(j)$ and $D(j)$ to obtain the total system half widths, $H(s)$ and $D(s)$. If the system is composed of a string of components then the system half widths are simply the sum of the module half widths. If the system configuration is other than a string of modules we leave it to the licensee to devise a method for combining module half widths.

** STANDARD DEVIATION OF TOTAL SYSTEM UNCERTAINTY (Continued)

- (3) The standard deviation of the total measurement error is bounded by the following formula:

$$S^2(\text{total system}) = S^2(s) = S^2(s,b) + H^2(s) + H(s) * D(s) + D^2(s)/2$$

*** MODULE TIME RESPONSE

Generally we deal with modules that have one or two types of time response:

(1) Modules with a response that is linear in time, such as a strip chart recorder. Here the measure of time response that is usually quoted is the time, T , required for the module output to traverse 100% of its range. The time required for the module to traverse $x\%$ of its range is then $x\%$ of T .

(2) Modules with Linear Transfer Functions (LTFs).

By definition an LTF module produces an output function such that a specific linear combination of the input function plus its time derivatives is equal to a specific linear combination of the output function plus its time derivatives. For any realistic LTF module, the highest order output time derivative is greater than the highest order input time derivative.

For LTF modules, a step function impressed on the input produces an output that is a linear combination of a step function plus a series of exponentials. Frequently for practical purposes a Higher Order Transfer Function (HOTF) can be adequately approximated by a First Order Transfer Function (FOTF). A step function impressed on the input of a FOTF module produces an output with only one exponential term, which makes the analysis of a FOTF module particularly simple.

For LTF modules the measure of time response most frequently quoted is the time constant, τ , which is defined as the time required for the output to reach 63.2% of its final response after having a step function impressed on the input. For FOTF modules the single exponential term is $\exp(-t/\tau)$.

*** MODULE TIME RESPONSE (Continued)

so that τ is a physically significant quantity for FOTF modules. For HOTF modules, τ is simply a figure used to compare the relative merit of different modules, and has no underlying physical significance as it did for FOTF modules.

By convention the time required for a LTF module to reach 100% of its response after a step function is impressed on the input is taken to be 4τ . (Some people prefer to use 5τ , but both the numbers 4 and 5, or anything else one might want to use, is an arbitrary convention.)

Sometimes the time response to a step function change in the input is measured in some other way, for example the vendor may quote the time required for the module output to go from 0% to 90% of its final response. In this case if the FOTF approximation is made, the single exponential term, $\exp(-t/\tau)$, can be fit to the two data points, and the value of τ determined.

Another useful measure of a LTF module time response is the Ramp Asymptotic Delay Time (*RADT*), which is defined as the time by which an input ramp function leads the output ramp function after the initial transient has died out. For FOTF modules τ and *RADT* are identical. For HOTF modules τ and *RADT* are different. They have different definitions, and different numerical values. However in practice it is found that τ is always equal to or slightly greater than *RADT*, the largest difference being about 2%. This difference is much less than the experimental error incurred in measuring τ or *RADT*. Thus for practical purposes the numerical values of τ and *RADT* can be considered to be identical.

The following discussion may be useful to some licensees. For LTF modules the time response is sometimes measured by inputting sinusoidal signals at two different frequencies, ω_1 and ω_2 , and observing the (output signal amplitude)/(input signal amplitude), $A(\omega_1)$ and $A(\omega_2)$. If the time response is quoted in terms of these parameters, then for a FOTF module *RADT* is given by the following formula, which is developed in reference 2.

$$A^2(\omega_1) * [1 + \omega_1^2 \tau^2] = A^2(\omega_2) * [1 + \omega_2^2 \tau^2]$$

*** MODULE TIME RESPONSE (Continued)

The above formula is exact for FOTF components and for HOTF components the formula provides a conservative estimate of *RADT* if ω_1 and ω_2 are chosen in the proper range. However, if ω_1 and ω_2 are not in the proper range the value of *RADT* computed from the formula will, at worst, be only slightly nonconservative. (The maximum achievable nonconservatism for pressure transducers is about 10%. For other types of modules the nonconservatism may be significantly higher.) We do not require the licensees to show that ω_1 and ω_2 are in the proper range because our acceptance criteria for the value of τ (or *RADT*) is sufficiently flexible to permit this small nonconservatism in the computed value of *RADT*.

The overall time constant for a string of LTF modules is a complicated function of the time constants of the individual modules. This overall time constant must be computed iteratively, and the computation is most easily done with the help of a computer. We have a computer programmed to do this computation, and are planning to do the computation with the data from all licensees. This program and its mathematical basis are described in reference 1.

REFERENCES

Some analytical methods described in the clarifications are developed in the following internal NRC memoranda. These memoranda will be provided upon request.

- (1) Memorandum from Peter S. Kapo to Walter R. Butler, dated 12 April 82, Subject: NUREG-0737, Item II.F.1.4, Containment Pressure Monitor System, Method for Estimating the Combined Time Constant of a String of Components each of which has a Known Time Constant.
- (2) Memorandum from Peter S. Kapo to Walter R. Butler, dated 23 August 82 Subject: NUREG-0737, Analytical Solution to Two Problems Pertinent to Items II.F.1.4,5,6: (1) Statistical Treatment of Hysteresis and Deadband Errors, and (2) Determination of the Time Constant of a First Order Transfer Component from Variation with Frequency of Sinusoidal Output.