



**CENTERIOR  
ENERGY**

**PERRY NUCLEAR POWER PLANT**

10 CENTER ROAD  
PERRY, OHIO 44081  
(216) 259-3737

Mail Address:  
P.O. BOX 97  
PERRY, OHIO 44081

**Robert A. Stratman**  
VICE PRESIDENT - NUCLEAR

November 15, 1994  
PY-CEI/NRR-1884L

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Perry Nuclear Power Plant  
Docket No. 50-440  
Monthly Operating Report

Gentlemen:

Attached is the October 1994 Monthly Operating Report for Perry Unit 1.  
This report is submitted in accordance with Technical Specification  
6.9.1.8.

If you have questions or require additional information, please contact  
Mr. James D. Kloosterman, Manager - Regulatory Affairs at (216) 280-5833.

Very truly yours,

LKR:sc

Attachment

cc: NRC Project Manager  
NRC Resident Inspector Office  
NRC Region III  
Director, Office of Resource Management

220084

JE24

CLEVELAND ELECTRIC ILLUMINATING COMPANY

PERRY NUCLEAR POWER PLANT

October 1, 1994 - October 31, 1994

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER : 50-440

LICENSE NUMBER: NPF-58

Table of Contents

Average Daily Unit Power Level . . . . .	1
Operating Data Report . . . . .	2
Unit Shutdowns and Power Reductions . . . . .	3

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	<u>50-440</u>
UNIT	<u>PERRY ONE</u>
DATE	<u>11/15/94</u>
CONTACT	<u>L.K.ROUTZAHN</u>
TELEPHONE	<u>(216)280-5781</u>

MONTH OCTOBER 1994

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	<u>1179</u>	17	<u>1182</u>
2	<u>1187</u>	18	<u>1177</u>
3	<u>1187</u>	19	<u>1175</u>
4	<u>1186</u>	20	<u>1176</u>
5	<u>1187</u>	21	<u>1181</u>
6	<u>1185</u>	22	<u>1180</u>
7	<u>1177</u>	23	<u>1179</u>
8	<u>1173</u>	24	<u>1184</u>
9	<u>1180</u>	25	<u>1187</u>
10	<u>1189</u>	26	<u>1186</u>
11	<u>1187</u>	27	<u>1184</u>
12	<u>1184</u>	28	<u>1182</u>
13	<u>1182</u>	29	<u>974</u>
14	<u>1182</u>	30	<u>1230</u>
15	<u>1184</u>	31	<u>1182</u>
16	<u>1184</u>		

OPERATING DATA REPORT

UNIT: PERRY ONE  
 DATE: 11/15/94

OPERATING STATUS

1. Docket: 50-440
2. Reporting Period: OCTOBER 1994
3. Utility Contact: L.K. Routzahn
4. Licensed Thermal Power (MWt): 3579
5. Nameplate Rating (Gross MWe): 1250
6. Design Electrical Rating (net MWe): 1191
7. Maximum Dependable Capacity (Gross MWe): 1225
8. Maximum Dependable Capacity (Net MWe): 1166
9. If Changes Occur in Capacity Ratings (Item Numbers 4 through 8) Since Last Report, Give Reasons:  
NONE

---

10. Power Level to Which Restricted, IF any (Net MWe): 100%
11. Reasons for Restrictions, IF Any: OPERATING LICENSE

---

	This Month	Yr-to-Date	Cumulative
12. Hours In Reporting Period	745.0	7,296.0	60,948.0
13. Hours Reactor was Critical	745.0	2,935.0	40,466.4
14. Reactor reserve Shutdown Hours	0.0	0.0	0.0
15. Hours Generator On-Line	745.0	2,688.4	38,824.0
16. Unit Reserve Shutdown Hours	0.0	0.0	0.0
17. Gross thermal Energy (MWH)	2,651,928	9,253,505	132,134,265
18. Gross Electrical Energy (MWH)	916,186	3,154,876	45,379,868
19. Net Electrical Energy (MWH)	875,822	2,996,050	43,088,979
20. Unit Service Factor	100.0%	36.8%	63.7%
21. Unit Availability Factor	100.0%	36.8%	63.7%
22. Unit Capacity Factor (using MDC Net)	100.8%	35.2%	61.2%
23. Unit Capacity Factor (Using DER Net)	98.7%	34.5%	59.4%
24. Unit Forced Outage Rate	0.0%	2.0%	11.8%
25. Forced Outage Hours	0.0	56.2	5,195.0
26. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>NONE</u>			

27. If Shutdown at end of Report Period, Estimated Date of Startup:
-

UNIT SHUTDOWNS AND POWER REDUCTIONS  
REPORT MONTH OCTOBER 1994

DOCKET NO. 50-440  
 UNIT NAME PERRY ONE  
 DATE 11/15/94  
 CONTACT L.K.ROUTZAHN  
 TELEPHONE (216)280-5781

NO.	DATE	TYPE	DURATION HOURS	REASON	METHOD	LER	SYSTEM	COMP.	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
		1		2	3	#		4	
94-05	10/29	S	0	B	5	N/A	N/A	N/A	DEEP SHALLOW ROD EXCHANGE/ N71 PUMP FLOW TRANSMITTER CALIBRATION

SUMMARY: PERRY UNIT ONE REMAINED ON LINE THROUGH THE MONTH OF OCTOBER 1994.

1. F: FORCED  
S: SCHEDULED

2. REASON:  
 A-EQUIPMENT FAILURE (EXPLAIN)  
 B-MAINTENANCE OR TEST  
 C-REFUELING  
 D-REGULATORY RESTRICTION  
 E-OPERATOR TRAINING &  
 LICENSE EXAMINATION  
 F-ADMINISTRATIVE  
 G-OPERATIONAL ERROR (EXPLAIN)  
 H-OTHER (EXPLAIN)

3. METHOD  
 1-MANUAL  
 2-MANUAL SCRAM  
 3-AUTOMATIC SCRAM  
 4-CONTINUED  
 5-REDUCED LOAD  
 9-OTHER

4. EXHIBIT G- INSTRUCTIONS  
 FOR PREPARATION OF DATA  
 ENTRY SHEETS FOR LICENSEE  
 EVENT REPORT (LER) FILE  
 (NUREG 1022)  
 5. EXHIBIT 1-SAME SOURCE