

November 28, 1994

Carolina Power and Light Company
ATTN: Mr. R. A. Anderson
Vice President
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461

SUBJECT: NRC INSPECTION REPORT NOS. 50-325/94-24 AND 50-324/94-24

Gentlemen:

Thank you for your response of October 21, 1994, to our Notice of Violation issued on September 21, 1994, concerning activities conducted at your Brunswick facility. We have evaluated your response and found that it meets the requirements of 10 CFR 2.201.

After reviewing your letter and additional inspection of work orders during this period, we acknowledge the problems which occurred with the circulating water ocean discharge pumps. Accordingly, we agree with your conclusion that the item addressed in the Notice of Violation dated September 21, 1994, did not constitute a violation. We will adjust our records to reflect that no violation of regulatory requirements occurred with respect to this item. In addition, we note you have submitted a Technical Specification (TS) change to remove this environmental limit from the Technical Specifications.

However, weaknesses were noted in documentation of activities which led to exceeding the TS limit and operator misunderstanding of the canal level as described in the Final Safety Analysis Report. In addition, performance of adjustments on the exciter power supplies of the motors on Unit 2 similar to those previously completed on Unit 1 may have prevented this problem.

We appreciate your cooperation in this matter.

Sincerely,



Bruce A. Boger, Acting Director
Division of Reactor Projects

Docket Nos.: 50-325, 50-324
License Nos.: DPR-71, DPR-62

cc: (See page 2)

9412060082 94112B
PDR ADOCK 05000324
Q PDR

1/0
IEO1

cc: H. W. Habermeyer, Jr.
Vice President
Nuclear Services Department
Carolina Power & Light Company
P. O. Box 1551 - Mail OHS7
Raleigh, NC 27602

J. P. Cowan
Director
Site Operations
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461

W. Levis
Plant Manager Unit 1
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461

C. C. Warren
Plant Manager Unit 2
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461

Mark S. Calvert
Associate General Counsel
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461

Dayne H. Brown, Director
Div. of Radiation Protection
N. C. Dept. of Environmental
Commerce & Natural Resources
P. O. Box 27687
Raleigh, NC 27611-7687

Karen E. Long
Assistant Attorney General
State of North Carolina
P. O. Box 629
Raleigh, NC 27602

Robert P. Gruber
Executive Director
Public Staff - NCUC
P. O. Box 29520
Raleigh, NC 27626-0520

(cc cont'd - See page 3)

(cc cont'd)
 Public Service Commission
 State of South Carolina
 P. O. Box 11649
 Columbia, SC 29211

Mayor
 City of Wilmington
 2518 Park Avenue
 Wilmington, NC 2840

Mayor
 City of Southport
 212 Frink Drive
 Southport, NC 28461

Mayor, City of
 Boiling Spring Lakes
 336 Cedar Road
 Boiling Spring Lakes, NC 28461

Distribution:
 H. Christensen, RII
 P. Milano, NRP
 G. A. Hallstrom, RII
 PUBLIC

NRC Resident Inspector
 U.S. Nuclear Regulatory Comm.
 HC 1, Box 208
 Southport, NC 28461

NLG

N

SEND	OFC	RII:DRP <i>[Signature]</i>	RII:DRP <i>[Signature]</i>	RII:DRP <i>[Signature]</i>	RII <i>[Signature]</i>	RII EICS	
TO	NAME	JStarefos <i>[Signature]</i>	CPatterson <i>[Signature]</i>	HChristensen	C. EVANS	B. URYC <i>[Signature]</i>	
PDR?	DATE	11/15/94	11/15/94	11/16/94	11/17/94	11/17/94	
Yes	No	COPY? Yes	No	Yes	No	Yes	No