

December 14, 1994

Mr. D. L. Farrar, Manager  
Nuclear Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III, Suite 500  
1400 OPUS Place  
Downers Grove, IL 60515

SUBJECT: INSERVICE TESTING PROGRAM UPDATE - QUAD CITIES, UNITS 1 AND 2  
(TAC NOS. M91038 AND M91039)

Dear Mr. Farrar:

By letter dated November 28, 1994, we received your request to update your IST Program for the third ten-year interval to the requirements of ASME/ANSI Standard OMa-1988, Part 10 (OM-10), for cold shutdown testing of valves. Specifically, the requirements you request to incorporate are contained in Paragraphs 4.2.1.2(g) and 4.3.2.2(g) of OM-10.

The staff approves the use of the 1989 Edition of ASME Section XI, subject to the limitations of 10 CFR 50.55a(f)(4)(iv). The staff has determined that Paragraphs 4.2.1.2(g) and 4.3.2.2(g) of OM-10 are acceptable to implement under 10 CFR 50.55a(f)(4)(iv) provided Paragraph 6.2 of OM-10 is also met.

Sincerely,

Original signed by:

Robert M. Pulsifer, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-254, 50-265

cc: see next page

DISTRIBUTION

Docket File	PUBLIC	PDIII-2 r/f
JRoe O-13 E4	RCapra	OGC O-15 B18
RPulsifer	CMoore	RWessman O-7 E23
ACRS(4) T-2 E26	PHiland, RIII	

DOCUMENT NAME: G:\CMRCJR\QUAD\QC91038.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-2	PM:PDIII-2	D:EMEB	D:PDIII-2
NAME	CMoore	RPulsifer	RWessman	RCapra
DATE	12/13/94	12/13/94	12/14/94	12/14/94

OFFICIAL RECORD COPY

190214  
9412200084 941214  
PDR ADOCK 05000254  
PDR

NRC FILE CENTER COPY

DFD110

D. L. Farrar  
Commonwealth Edison Company

Quad Cities Nuclear Power Station  
Unit Nos. 1 and 2

cc:

Mr. Stephen E. Shelton  
Vice President  
Iowa-Illinois Gas and  
Electric Company  
P. O. Box 4350  
Davenport, Iowa 52808

Michael I. Miller, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60690

Mr. L. William Pearce  
Station Manager  
Quad Cities Nuclear Power Station  
22710 206th Avenue North  
Cordova, Illinois 61242

U.S. Nuclear Regulatory Commission  
Quad Cities Resident Inspectors Office  
22712 206th Avenue North  
Cordova, Illinois 61242

Chairman  
Rock Island County Board  
of Supervisors  
1504 3rd Avenue  
Rock Island County Office Bldg.  
Rock Island, Illinois 61201

Illinois Department of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351