



**Consumers
Power
Company**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0774

J A Mooney
Executive Manager
Midland Project Office

PRINCIPAL STAFF			
✓ RA	10/2	ENE	
D/RA		PAO	+3
A/RA		PAO	
DPRP		SLO	
DRMA		RC	
DRMSP			
UE			
ML			
OL		FILE	10/0

August 17, 1983

50-329
50-330

Mr J J Harrison
Midland Project Section
U S Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND ENERGY CENTER GWO 7020
REMEDIAL SOILS WORK AUTHORIZATION
File: 0485.16 UFI: 42*05*22*04 Serial: CSC-6855
70*01

The following items were discussed in 8/15/83 and 8/16/83 telecons between Dr. Ross Landsman of NRC Region III and R. Wheeler, R. Wieland, and D. Puhalla of CPCo.

1. Four (4) additional wells will be added to the Service Water Pump Structure Dewatering System (Reference Activity Number 207050605).
2. The design for pipe hangers on lines 30" OHBC 34, 20, and 16 in the Service Water Pump Structure has been revised (Reference Activity Number 202550164).
3. An FCR will be written to allow the installation of level C wales in the Auxiliary Building Access Shafts to proceed prior to completion of Zones Z-2 and Y-2 excavations.

Dr. Landsman concurred that these three items constitute minor changes to the previously approved activities.

JAMooney

JAM/RHW/klm

8308290322 830817
PDR ADOCK 05000329
A PDR

1001
AUG 22 1983 11/0