

JAN 25 1984

Docket Nos. 50-272  
50-311

Public Service Electric and Gas Company  
Attn: Mr. Richard A. Uderitz  
VP Nuclear  
P. O. Box 236  
Hancock's Bridge, NJ 08038

Gentlemen:

Subject: Combined Inspection Report 50-272/83-35 and 50-311/83-35

This refers to the safety inspection conducted by Mr. T. Dragoun of this office on November 16-13, 1983 of activities authorized by NRC License Nos. DPR-70 and DPR-75 and to the discussions of our findings held by Mr. T. Dragoun with Mr. J. Zupko of your staff at the conclusion of the inspection.

Areas examined during this inspection are described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, measurements made by the inspector, and observations by the inspector.

Our inspector also verified the steps you have taken to correct the violations and deviations brought to your attention in letters and enclosures dated March 1, 1982, September 9, 1982, January 7, 1983 and May 6, 1983. We have no further questions regarding your action at this time.

Within the scope of this inspection, no violations were observed.

We acknowledge receipt of your letter dated December 2, 1983 relative to modification of the post accident sampling system. We understand that modifications as necessary to sample the reactor coolant system at pressures below 50 psig will be completed by March 1 and April 1, 1984, for Unit 2 and Unit 1, respectively. If our understanding is not correct, please contact this office within 10 days.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 10 CFR 2.790(b)(1). The telephone notification of your intent to request withholding, or any request for an extension of the 10-day period which you believe necessary, should be made to the Supervisor, Files, Mail and Records, USNRC Region I, at (215) 337-5223.

8402090359 840125  
PDR ADOCK 05000272  
Q PDR

OFFICIAL RECORD COPY

247DRAGOUN12/9/83 - 0001.0.0  
01/18/84

11 E06

JAN 25 1984

No reply to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely,

*Ronald R. Bellamy* / for  
Thomas T. Martin, Director  
Division of Engineering and  
Technical Programs

Enclosure: Combined NRC Region I Inspection Report Number 50-272/83-35 and 50-311/83-35

cc w/encl:

R. L. Mittl, General Manager - Nuclear Assurance and Regulation  
J. M. Zupko, Jr., General Manager - Salem Operations  
E. A. Liden, Manager - Nuclear Licensing and Regulation  
C. P. Johnson, Manager - Quality Assurance Nuclear Operations  
P. M. Krishna, Manager - Nuclear Review Board  
M. J. Wetterhahn, Esquire  
R. Fryling, Jr., Esquire  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of New Jersey

bcc w/encl:

Region I Docket Room (with concurrences)  
Senior Operations Officer (w/o encls)  
DPRP Section Chief

RI:DETP  
Dragoun/slf  
12/9/83  
*[Signature]*

*1/24/84*  
RI:DETP  
White  
*[Signature]*

*ms*  
RI:DETP  
Shanbak  
*1/23*

*mt*  
RI:DETP  
Bellamy  
*1/27*

RI:DETP  
Martin  
*[Signature]*

OFFICIAL RECORD COPY

247DRAGOUN12/9/83 - 0001.1.0  
01/18/84