



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

January 9, 1995

Mr. Guy R. Horn  
Vice-President, Nuclear  
Nebraska Public Power District  
Post Office Box 98  
Brownville, Nebraska 68321

SUBJECT: GENERIC LETTER (GL) 92-01, REVISION 1, REACTOR VESSEL STRUCTURAL  
INTEGRITY, COOPER NUCLEAR STATION (TAC NO. M83455)

Dear Mr. Horn:

By letters dated July 1, 1992, July 2, 1993, and September 16, 1993, Nebraska Public Power District (NPPD) provided its responses to GL 92-01, Revision 1. The NRC staff has completed its review of your responses. Based on its review, the staff has determined that NPPD has provided the information requested in GL 92-01.

The GL is part of the staff's program to evaluate reactor vessel integrity for Pressurized Water Reactors (PWRs) and Boiling Water Reactors (BWRs). The information provided in response to GL 92-01, including previously docketed information, is being used to confirm that licensees satisfy the requirements and commitments necessary to ensure reactor vessel integrity for their facilities.

A substantial amount of information was provided in response to GL 92-01, Revision 1. The data has been entered into a computerized data base designated Reactor Vessel Integrity Database (RVID). The RVID contains the following tables: A pressurized thermal shock (PTS) table for PWRs, a pressure-temperature limit table for BWRs, and an upper-shelf energy (USE) table for PWRs and BWRs. Enclosure 1 provides the pressure-temperature table(s), Enclosure 2 provides the USE table for your facility, and Enclosure 3 provides a key for the nomenclature used in the tables. The tables include the data necessary to perform USE and  $RT_{pts}$  evaluations. The data was taken from your response(s) to GL 92-01 and previously docketed information. References to the specific source of the data are provided in the tables.

As a result of our GL 92-01 review, the NRC staff has identified one open issue for your plant. The initial  $RT_{MDT}$  values determined by General Electric's (GE) initial methodology have not been validated and the BWR Owners Group report, GE-NE-523-109-0893, entitled, "Basis for GE  $RT_{MDT}$  Estimation Method," did not resolve the issue. GE is in the process of validating its methodology for resolving the initial  $RT_{MDT}$  determination issue and will document the results in a topical report. The BWR Owners Group is obtaining approval from its members to provide the GE topical report to the NRC staff for its review and approval. We request that you submit within 30 days a commitment to the BWR Owners Group effort or a schedule for a plant-specific

9501130073 950109  
PDR ADOCK 05000298  
P PDR

NRC FILE CENTER COPY

DF01

analysis to resolve this issue. Further, we request that you provide confirmation of the plant-specific applicability of the topical report, NEDO-32205, Revision 1, (as specified in Appendix B of that report) and submit a request for approval of the topical report as the basis for demonstrating compliance with 10 CFR Part 50, Appendix G, Paragraph IV.A.1. We further request that you verify that the information you have provided for your facility has been accurately entered in the data base. If no comments are made in your response to the last request, the staff will use the information in the tables for future NRC assessments of your reactor pressure vessel.

Once you have (1) confirmed the applicability of the topical report, NEDO-32205, Revision 1, to your plant, (2) submitted the request for approval, and (3) provided your commitment to the BWR Owners Group effort or a satisfactory schedule for providing a plant-specific analysis, the staff will consider your actions related to GL 92-01, Revision 1, to be complete. Plant-specific licensing action(s) will be initiated to resolve these issues.

The information requested by this letter is within the scope of the overall burden estimated in GL 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)." The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires July 31, 1997.

Sincerely,  
ORIGINAL SIGNED BY:  
James R. Hall, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-298

- Enclosures: 1. Pressure-Temperature Limit Table  
2. Upper-Shelf Energy Table  
3. Nomenclature Key

cc w/encls: See next page

DISTRIBUTION:

Docket File PUBLIC PD4-1 r/f D. McDonald  
W. Beckner P. Noonan ACRS (4) P. Harrell, RIV  
OGC (15B18) A. B. Beach, RIV J. Roe  
J. Hall T. J. Kim S. Sheng

Document Name: CO083455.LTR

OFC	LA/PD4-1	PE/PD4-1	PM/PD4-1
NAME	PNoonan <i>JN</i>	TKim <i>TJK</i>	JHall/vw <i>JRH</i>
DATE	1/14/95	1/14/95	1/19/94
COPY	YES/NO	YES/NO	YES/NO

Mr. Guy R. Horn


- 2 -

analysis to resolve this issue. Further, we request that you provide confirmation of the plant-specific applicability of the topical report, NEDO-32205, Revision 1, (as specified in Appendix B of that report) and submit a request for approval of the topical report as the basis for demonstrating compliance with 10 CFR Part 50, Appendix G, Paragraph IV.A.1. We further request that you verify that the information you have provided for your facility has been accurately entered in the data base. If no comments are made in your response to the last request, the staff will use the information in the tables for future NRC assessments of your reactor pressure vessel.

Once you have (1) confirmed the applicability of the topical report, NEDO-32205, Revision 1, to your plant, (2) submitted the request for approval, and (3) provided your commitment to the BWR Owners Group effort or a satisfactory schedule for providing a plant-specific analysis, the staff will consider your actions related to GL 92-01, Revision 1, to be complete. Plant-specific licensing action(s) will be initiated to resolve these issues.

The information requested by this letter is within the scope of the overall burden estimated in GL 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)." The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires July 31, 1997.

Sincerely,



James R. Hall, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosures: 1. Pressure-Temperature  
Limit Table  
2. Upper-Shelf Energy Table  
3. Nomenclature Key

cc w/encls: See next page

Mr. Guy R. Horn  
Nebraska Public Power Company

Cooper Nuclear Station

cc:

Mr. G. D. Watson, General Counsel  
Nebraska Public Power District  
P. O. Box 499  
Columbus, Nebraska 68602-0499

Lincoln Electric System  
ATTN: Mr. Ron Stoddard  
11th & O Streets  
Lincoln, Nebraska 68508

Nebraska Public Power District  
ATTN: Mr. John Mueller, Site Manager  
P. O. Box 98  
Brownville, Nebraska 68321

Midwest Power  
ATTN: James C. Parker, Sr. Engineer  
907 Walnut Street  
P. O. Box 657  
Des Moines, Iowa 50303

Randolph Wood, Director  
Nebraska Department of Environmental  
Control  
P. O. Box 98922  
Lincoln, Nebraska 68509-8922

Nebraska Public Power District  
ATTN: Mr. Robert C. Goodley, Nuclear  
Licensing & Safety Manager  
P. O. Box 98  
Brownville, Nebraska 68321

Mr. Larry Bohlken, Chairman  
Nemaha County Board of Commissioners  
Nemaha County Courthouse  
1824 N Street  
Auburn, Nebraska 68305

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 218  
Brownville, Nebraska 68321

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. Harold Borchert, Director  
Division of Radiological Health  
Nebraska Department of Health  
301 Centennial Mall, South  
P. O. Box 95007  
Lincoln, Nebraska 68509-5007

Mr. Ronald A. Kucera, Department Director  
of Intergovernmental Cooperation  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, Missouri 65102

## Summary File for Pressure-Temperature Limits

Plant Name	Boltline Ident.	Heat No. Ident.	ID Neut. Fluence at EOL/EPY	IRT <sub>nom</sub>	Method of Determin. IRT <sub>nom</sub>	Chemistry Factor	Method of Determin. CF	%Cu	%Ni
Cooper  EOL: 12/18/ 2014	Lower int. shell G-2801-7	C2407-1	1.5E18	-10°F	Plant specific	92.25	Table	0.13	0.65
	Lower int. shell G-2802-1	C2331-2	1.5E18	10°F	Plant specific	125.3	Table	0.17	0.58
	Lower int. shell G-2802-2	C2307-2	1.5E18	-20°F	Plant specific	162.8	Table	0.21	0.73
	Lower shell G-2803-1	C2274-1	1.5E18	14°F <sup>1</sup>	Plant specific	153	Table	0.20	0.68
	Lower shell G-2803-2	C2307-1	1.5E18	0°F <sup>1</sup>	Plant specific	162.8	Table	0.21	0.73
	Lower shell G-2803-3	C2274-2	1.5E18	-8°F <sup>1</sup>	Plant specific	153	Table	0.20	0.68
	Lower int. shell axial welds 1-233A/C (T)	27204 & 12008	1.5E18	-50°F	Plant specific	215.65	Table	0.19	0.97
	Lower to lower-int. shell circ. weld 1-240	21935	1.5E18	-50°F	Plant specific	175.3	Table	0.20	0.69
	Lower shell axial welds 2-233A/C	12420	1.5E18	-50°F	Plant specific	234.5	Table	0.22	1.02

References:

Chemical composition (copper [Cu] and nickel [Ni]) for weld 2-233A/C, Ni for weld 1-240 and 1-233A/C are from February 25, 1993, letter from G. R. Horn (NPPD) to USNRC Document Control Desk, subject: Submittal of Reactor Vessel Surveillance Test Results.

IRT<sub>nom</sub> data for weld 1-233A/C is from G. R. Horn letter of February 25, 1993, cited above.

Other chemical composition, and other IRT<sub>nom</sub> data are from July 1, 1992, letter from G. R. Horn (NPPD) to USNRC Document Control Desk, subject: Response to Generic Letter 92-01, Revision 1.

<sup>1</sup>Additional information required to confirm value.

## Summary File for Upper Shelf Energy

Plant Name	Beltline Ident.	Heat No.	Material Type	1/4T USE at EOL	1/4T Neutron Fluence at EOL	Unirrad. USE	Method of Determin. Unirrad. USE
Cooper  EOL: 12/18/ 2014	Lower int. shell G-2801-7	C2407-1	A 5338-1	61	1.08E18	84	65%
	Lower int. shell G-2802-1	C2331-2	A 5338-1	61	1.08E18	72	65%
	Lower int. shell G-2802-2	C2307-2	A 5338-1	67	1.08E18	84	65%
	Lower shell G-2803-1	C2274-1	A 5338-1	60	1.08E18	73	65%
	Lower shell G-2803-2	C2307-1	A 5338-1	61	1.08E18	75	65%
	Lower shell G-2803-3	C2274-2	A 5338-1	60	1.08E18	72	65%
	Lower int. shell axial welds 1-233A/C	27204 & 12008	Linde 1092, SAW	85	1.08E18	112	Surv. Weld
	Lower to lower-int. shell circ. weld 1-240	21935	Linde 1092, SAW	EMA <sup>a</sup>	1.08E18	EMA <sup>a</sup>	- -
	Lower shell axial welds 2-233A/C	12420	Linde 1092, SAW	EMA <sup>a</sup>	1.08E18	EMA <sup>a</sup>	- -

References:

Chemical composition (copper [Cu] and nickel [Ni]) for weld 2-233A/C, Ni for weld 1-240 and 1-233A/C are from February 25, 1993, letter from G. R. Horn (NPPD) to USMRC Document Control Desk, subject: Submittal of Reactor Vessel Surveillance Test Results.

Fluence, the USE of the surv. weld, and other chemical composition data are from July 1, 1992, letter from G. R. Horn (NPPD) to USMRC Document Control Desk, subject: Response to Generic Letter 92-01, Revision 1.

Plate USE data are from Table 7-1 of NDE-103-0986, which evaluated surveillance capsule 1.

<sup>2</sup>Licensee must confirm applicability of Topical Report NEDO-32205, Rev. 1

PRESSURE-TEMPERATURE LIMIT TABLES AND USE TABLES FOR ALL BWR PLANTSNOMENCLATURE

## Pressure-Temperature Limits Table

- Column 1: Plant name and date of expiration of license.  
 Column 2: Beltline material location identification.  
 Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process, (T) indicates tandem wire was used in the SAW process.  
 Column 4: End-of-life (EOL) neutron fluence at vessel inner wall; cited directly from inner diameter (ID) value or calculated by using Regulatory Guide (RG) 1.99, Revision 2 neutron fluence attenuation methodology from the quarter thickness (T/4) value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).  
 Column 5: Unirradiated reference temperature.  
 Column 6: Method of determining unirradiated reference temperature (IRT).

Plant-Specific

This indicates that the IRT was determined from tests on material removed from the same heat of the beltline material.

MTEB 5-2

This indicates that the unirradiated reference temperature was determined from following MTEB 5-2 guidelines for cases where the IRT was not determined using American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section III, NB-2331, methodology.

Generic

This indicates that the unirradiated reference temperature was determined from the mean value of tests on material of similar types.

- Column 7: Chemistry factor for irradiated reference temperature evaluation.  
 Column 8: Method of determining chemistry factor

Table

This indicates that the chemistry factor was determined from the chemistry factor tables in RG 1.99, Revision 2.

Calculated

This indicates that the chemistry factor was determined from surveillance data via procedures described in RG 1.99, Revision 2.

Column 7: Unirradiated USE.

EMA

This indicates that the USE issue may be covered by the approved equivalent margins analysis in the BWR Owners Group Topical Report: NEDO-32205, Revision 1.

Column 8: Method of determining unirradiated USE

Direct

For plates, this indicates that the unirradiated USE was from a transverse specimen. For welds, this indicates that the unirradiated USE was from test date.

65%

This indicates that the unirradiated USE was 65% of the USE from a longitudinal specimen.

Generic

This indicates that the unirradiated USE was reported by the licensee from other plants with similar materials to the beltline material.

NRC generic

This indicates that the unirradiated USE was derived by the staff from other plants with similar materials to the beltline material.

10, 30, 40, or 50 °F

This indicates that the unirradiated USE was derived from Charpy test conducted at 10, 30, 40, or 50 °F.

Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having the same weld wire heat number.

Equip. to Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having different weld wire heat number.

Sister Plant

This indicates that the unirradiated USE was derived by using the reported value from other plants with the same weld wire heat number.

Blank

indicates that there is insufficient data to determine the unirradiated USE. These licensees will utilize Topical Report NEDO-32205, Revision 1 to demonstrate USE compliance to Appendix G, 10 CFR Part 50.

Column 9: Copper content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no copper data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Column 10: Nickel content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no nickel data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

#### Upper Shelf Energy Table

Column 1: Plant name and date of expiration of license.

Column 2: Beltline material location identification.

Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process. (T) indicates tandem wire was used in the SAW process.

Column 4: Material type; plate types include A 533B-1, A 302B, A 302B Mod., and forging A 508-2; weld types include SAW welds using Linde 80, 0091, 124, 1092, ARCOS-B5 flux, Rotterdam welds using Graw Lo, SMIT 89, LW 320, and SAF 89 flux, and SMAW welds using no flux.

Column 5: EOL upper-shelf energy (USE) at T/4; calculated by using the EOL fluence and either the copper value or the surveillance data. (Both methods are described in RG 1.99, Revision 2.)

EMA

This indicates that the USE issue may be covered by the approved equivalent margins analysis in the BWR Owners Group Topical Report: NEDO-32205, Revision 1.

Column 6: EOL neutron fluence at T/4 from vessel inner wall; cited directly from T/4 value or calculated by using RG 1.99, Revision 2 neutron fluence attenuation methodology from the ID value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).