


Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

September 9, 1983

Director, Office of Nuclear Reactor Regulation
Attention: Mr. George W. Knighton, Branch Chief
Licensing Branch No. 3
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-362
San Onofre Nuclear Generating Station
Unit 3

License Condition 2.C(17)f of the San Onofre Unit 3 Operating License requires SCE to conduct a 48-hour endurance test of all auxiliary feedwater pumps and to submit test results to the NRC staff prior to exceeding five (5) percent power.

Consistent with this requirement, SCE recently completed a successful 48-hour endurance run of all three auxiliary feedwater pumps and a summary of the 48-hour endurance run is enclosed.

SCE considers that the enclosed information satisfies the requirements of License Condition 2.C(17)f of the San Onofre Unit 3 Operating License.

If you have any question or comments, please let me know.

Very truly yours,

M. O. Medford
Supervising Engineer
San Onofre Units 2 and 3 Licensing

Enclosure

cc: Mr. J. B. Martin, Regional Administration
U.S. Nuclear Regulatory Commission, Region V
Mr. H. Rood, Project Manager (To be opened by addressee only)

8309140036 830909
PDR ADOCK 05000362
P PDR

800
11

TEST SUMMARY

Auxiliary Feedwater Pump 48-Hour Endurance Run
San Onofre Unit 3

I. Test Objective

The objectives of this test were to perform 48-hour endurance runs on all three (3) Auxiliary Feedwater (AFW) System Pumps (two motor driven and one turbine driven pumps) for San Onofre Unit 3 and to demonstrate that the pumps remain within design limits with respect to bearing temperatures and vibration, and that the ambient conditions (temperature, humidity) do not exceed environmental qualification limits specified in Section 3.11 of the San Onofre Units 2 and 3 FSAR for safety related equipment in the auxiliary feedwater pump room.

The 48-hour endurance run is consistent with the recommendations of Item II.E.1.1 of NUREG-0737 and the requirements of License Condition 2.C(17)f of the San Onofre Unit 3 Operating License.

II. Test Method

1. All three AFW system pumps were run utilizing the recirculation flow path for the duration of the test.
2. Bearing temperatures were measured and recorded.

3. Vibration levels were measured and recorded.
4. AFW Pump Room ambient conditions were measured and recorded.

III. Test Results

The results of the tests demonstrated that all three AFW system pumps ran acceptably for a continuous 48 hour period. Specifically the test results for all three pumps which are provided as Attachments 1, 2 and 3 to this enclosure showed the following:

1. Bearing temperatures did not exceed the acceptance criterion of 210⁰F.
2. Vibration levels did not exceed the acceptance criteria of 1.0 mil for the pumps and 1.5 mils for the pump driver.
3. AFW pump room ambient conditions did not exceed environmental qualification limits specified in Section 3.11 of the San Onofre Units 2 and 3 FSAR for safety related equipment.

ENCLOSURE I

Attachment 1

ATTACHMENT 1
TURBINE DRIVEN
 AUXILIARY FEEDWATER PUMP P-140 ENDURANCE RUN
 DATA RECORD

Time	Bearing Temperatures				Turbine Vibration						Pump Vibration						Initial/Date
	3TE-4721 Turbine Outboard 13 (1)	3TE-4722 Turbine Inboard 14 (1)	3TE-4723 Pump Inboard 12 (1)	3TE-4726 Pump Outboard 11 (1)	Outboard			Inboard			Inboard			Outboard			
					H	V	A	H	V	A	H	V	A	H	V	A	
0	148	146	132	168	20	14	15	09	08	12	25	16	24	25	13	36	20 8/11/83
1 hr	147	146	132	176	21	12	18	09	07	13	24	20	22	24	16	3	20 8/11/83
2 hr	148	146	135	178	19	24	16	20	06	19	27	22	20	23	12	50	20 8/11/83
3 hr	148	146	132	180	19	24	16	20	08	18	26	24	44	24	18	50	20 8/11/83
4 hr	148	144	134	180	11	14	16	10	08	18	25	22	42	25	18	50	20 8/11/83
6 hr	148	146	134	179	16	14	16	10	08	18	26	24	44	25	18	50	20 8/11/83
8 hr	149	148	133	177	15	14	16	12	07	17	24	22	40	24	18	51	20 8/11/83
10 hr	148	148	133	177	15	15	11	15	08	17	22	22	30	24	20	50	20 8/11/83
12 hr	151	151	133	175	15	16	11	14	05	17	24	23	32	25	20	50	20 8/11/83
15 hr	151	151	133	175	11	14	18	13	07	20	22	24	36	25	20	46	20 8/12/83
18 hr	150	150	132	174	14	16	20	12	14	22	30	24	44	23	15	54	20 8/12/83
21 hr	148	148	132	176	22	18	22	12	09	22	26	24	40	24	22	42	20 8/12/83
24 hr	148	150	134	180	15	13	08	18	1	24	28	22	26	22	18	52	20 8/12/83
27 hr	147	149	134	180	20	15	14	12	08	20	22	24	42	18	14	38	20 8/12/83
30 hr	151	151	135	180	16	10	21	10	06	17	25	27	34	24	17	42	20 8/12/83
33 hr	149	149	134	179	15	12	20	10	06	20	25	25	36	22	16	40	20 8/12/83
36 hr	149	149	134	179	12	09	24	12	07	22	21	22	42	23	17	50	20 8/13/83
39 hr	151	151	135	179	14	07	21	10	07	18	22	20	39	20	16	42	20 8/13/83
42 hr	150	150	134	178	10	13	17	15	08	22	25	24	44	20	18	50	20 8/13/83
45 hr	151	151	135	178	14	16	12	15	09	20	22	24	44	22	20	48	20 8/13/83
48 hr	150	151	138	178	14	10	20	05	07	17	23	25	42	20	18	52	20 8/13/83
Final	150	149	134	173	14	10	17	15	08	14	27	21	46	24	20	58	20 8/14/83

(1) Bearing temperatures may be taken using temporary local indication if any of the permanent instrumentation is out of service.

Permanent Instrument	Temporary Instrument ID Number	Next Calibration Due
----------------------	--------------------------------	----------------------

ATTACHMENT 1
TURBINE DRIVEN
 AUXILIARY FEEDWATER PUMP P-140 ENDURANCE RUN
 DATA RECORD

Time	Ambient Conditions		Pump Head		Pump Speed (4)	Pump Flow	Steam Temp 7	Initial/Date
	3TIC-9506 Pump Room Temp (2)	Pump Room Humidity	3PI-4701 Suction Pressure	3PI-4703 Discharge Pressure				
							3TE-8237	
0	82°	50%	7.5	1420	3620	100 GPM	546	LC 8/11/83
1 hr	82°	49%	7.5	1420	3620	100 GPM	546	LC 8/11/83
2 hr	82°	49%	7.5	1420	3600	100	548	LC 8/11/83
3 hr	82°	52%	7.5	1410	3600	100	548	MT 8/11/83
4 hr	82°	52%	7.5	1410	3600	100	544	MT 8/11/83
6 hr	82°	52%	7.5	1410	3600	100 GPM	548	PFB 8/11/83
8 hr	82°	56%	7.5	1410	3600	100 GPM	548	PFB 8/11/83
10 hr	82°	56%	7.5	1410	3600	100 GPM	548	PFB 8/11/83
12 hr	82°	56%	7.5	1410	3600	100 GPM	548	PFB 8/12/83
15 hr	82°	56%	9.5	1410	3600	100 GPM	544	AS 8/12/83
18 hr	82°	56%	8.0	1410	3580	100	548	AS 8/12/83
21 hr	84°	58%	10.0	1410	3580	100	546	MT 8/12/83
24 hr	83°	60%	9.0	1410	3590	100	547	MT 8/12/83
27 hr	84°	58%	10.0	1400	3590	100	547	MT 8/12/83
30 hr	84°	56%	9.0	1410	3600	100	545	PFB 8/12/83
33 hr	84°	56%	9.0	1410	3600	100	548	PFB 8/12/83
36 hr	84°	55%	9.0	1410	3600	100	546	AS 8/13/83
39 hr	84°	55%	10.0 11.0	1410	3600	100	543	AS 8/13/83
42 hr	84°	54%	11.0	1410	3600	100	539	MT 8/13/83
45 hr	87°	54%	9.5	1410	3590	100	540	LC 8/13/83
48 hr	85°	54%	10.0	1410	3590	100	542	LC 8/13/83
Final	85°	56%	10.0	1420	3620	100	542	LC 8/14/83

(2) If temperature exceeds range of 3TIC-9506, take measurements with digital thermometer of 6.2.


(3) Refer to Pump Curve attached.

(4) Nominal valve for Pump Speed is 3570 rpm.

OFFICIAL TEST COPY

ATTACHMENT 1 - TURBINE DRIVEN
 AUXILIARY FEEDWATER PUMP P-140 ENDURANCE RUN
 DATA RECORD

"BEARING TEMPERATURE VS. TIME"




ORIGINAL TEST COPY
 K. Stewart 2-29-83

503-SPSU-1234
 Page 3 of 5
 SFE-240-01
 TCN-03
 Page 2 of 4
 3PE-240-01
 Rev. 0
 Page 12a of 25
 SONGS 3

ATTACHMENT 1 - TURBINE DRIVEN
 AUXILIARY FEEDWATER PUMP P-140 ENDURANCE RUN
 DATA RECORD

"PUMP ROOM TEMPERATURE & HUMIDITY VS. TIME"



HUMIDITY (%)

TEMPERATURE (F)

OFFICIAL TEST COPY
R. Johnson
 8-29-83

ENCLOSURE I

Attachment 2

ATTACHMENT 2
MOTOR DRIVEN
 AUXILIARY FEEDWATER PUMP P-141 ENDURANCE RUN
 DATA RECORD

Time	Bearing Temperatures				Motor Vibration						Pump Vibration						Initial/Date
	3TE-4730A Motor Outboard Inboard (1)	3TE-4730B Motor Inboard Outboard (1)	3TE-4717 Pump Inboard (1)	3TE-4719 Pump Outboard (1)	Outboard			Inboard			Inboard			Outboard			
					H	V	A	H	V	A	H	V	A	H	V	A	
0	*105.0	*101.0	77.0	77.0	.15	.09	.16	.19	.07	.09	.44	.22	.60	.35	.21	.72	AS 7-30-83
1 hr	*170.0	*157.1	124.5	176.9	.13	.04	.06	.18	.09	.10	.48	.23	.56	.32	.20	.68	AS 7-30-83
2 hr	*173.9	*159.6	125.0	179.0	.13	.06	.08	.18	.09	.12	.48	.24	.54	.33	.19	.68	AS 7-30-83
3 hr	*175.1	*160.4	126.0	180.0	.14	.09	.06	.18	.11	.10	.48	.24	.55	.33	.21	.65	AS 7-30-83
4 hr	*174.6	*160.0	126.0	180.0	.14	.07	.13	.18	.07	.07	.50	.22	.55	.32	.21	.72	AC 7/30/83
6 hr	*175.4	*160.7	127.0	182.0	.14	.07	.15	.19	.11	.09	.52	.22	.54	.32	.19	.68	AC 7/30/83
8 hr	*176.6	*161.6	128.0	183.0	.14	.07	.10	.20	.10	.10	.52	.20	.54	.34	.18	.74	AC 7/30/83
10 hr	*176.8	*162.5	128.0	183.0	.13	.07	.13	.20	.10	.10	.50	.24	.54	.32	.16	.68	AC 7/30/83
12 hr	*176.7	*163.0	129.0	183.0	.14	.07	.12	.20	.09	.08	.50	.22	.52	.34	.21	.68	AC 7/30/83
15 hr	*177.0	*162.8	128.0	183.0	.14	.06	.11	.19	.09	.07	.50	.22	.54	.32	.20	.66	AC 7/30/83
18 hr	*178.1	*163.8	129.0 124.0	183.0	.14	.07	.19	.14	.08	.09	.50	.24	.54	.31	.18	.65	AS 7-30-83
1 hr	170.0	154.0	121.0	179.0	.16	.06	.12	.20	.09	.09	.48	.24	.54	.30	.19	.65	AS 7-31-83
24 hr	169.0	153.0	121.0	179.0	.14	.08	.12	.19	.10	.08	.48	.25	.55	.30	.16	.65	AS 7-31-83
27 hr	169.0	153.0	121.0	178.0	.14	.06	.12	.18	.09	.09	.48	.24	.55	.30	.19	.65	AS 7-31-83
30 hr	169.0	153.0	121.0	178.0	.15	.07	.12	.20	.10	.09	.50	.22	.54	.30	.20	.68	AS 7/31/83
33 hr	170.0	154.0	122.0	178.0	.15	.07	.16	.20	.09	.13	.50	.23	.51	.32	.22	.66	AC 7/31/83
36 hr	171.0	156.0	123.0	179.0	.16	.08	.13	.24	.11	.07	.52	.22	.48	.32	.20	.70	AC 7/31/83
39 hr	170.0	155.0	122.0	180.0	.15	.07	.10	.17	.10	.10	.54	.22	.54	.30	.22	.68	AC 7/31/83
42 hr	169.0	154.0	120.0	179.0	.15	.06	.09	.18	.09	.09	.48	.24	.55	.29	.19	.65	AS 7-31-83
45 hr	170.0	154.0	120.0	179.0	.15	.06	.12	.18	.08	.09	.50	.20	.55	.28	.17	.62	AS 8-1-83
48 hr	169.0	153.0	120.0	179.0	.15	.06	.12	.18	.09	.08	.49	.19	.54	.29	.17	.65	AS 8-1-83
Final	168.0	152.0	119.0	176.0	.12	.07	.12	.18	.07	.10	.52	.23	.56	.28	.07	.64	AC 8/1/83

(1) Bearing temperatures may be taken using temporary local indication if any of the permanent instrumentation is out of service.

Permanent Instrument	Temporary Instrument ID Number	Next Calibration Due
* 3TE-4730A:B	5U-2003	8/14/83

ATTACHMENT 2
MOTOR DRIVEN
 AUXILIARY FEEDWATER PUMP P-141 ENDURANCE RUN
 DATA RECORD

Time	Ambient Conditions		Pump Head (3)		Pump Speed (4)	Pump Flow	Initial/Date
	3TIC-9506 Pump Room Temp (2)	Pump Room Humidity	3PI-4708 Suction Pressure	3PI-4710 Discharge Pressure			
0	71°	60.5%	11.0	1380	3620 rpm	100 GPM	AS 7-30-83
1 hr	73°	60.5	11.0	1390	3620	100 GPM	AS 7-30-83
2 hr	74°	59.0	11.0	1390	3620	100 GPM	AS 7-30-83
3 hr	75°	54.0	11.0	1390	3620	100 GPM	AS 7-30-83
4 hr	75°	47.0	11.0	1390	3600	100	AL 7-30-83
6 hr	76°	50.0	11.0	1395	3600	100	ZC 7/30/83
8 hr	77°	54.0	11.0	1395	3600	100	AL 7/30/83
10 hr	77°	44.0	11.0	1395	3600	100	AL 7/30/83
12 hr	78°	46.0	11.0	1395	3600	100	ZC 7/30/83
15 hr	78°	50.0	11.0	1395	3600	100	ZC 7/30/83
18 hr	80°	65.0	11.0	1390	3600	100	AS 7-30-83
21 hr	72°	85.0	11.0	1390	3600	100	AS 7-31-83
hr	71°	85.0	11.0	1390	3600	100	AS 7-31-83
27 hr	71°	90.0	11.0	1390	3600	100	AS 7-31-83
30 hr	71°	85.0	11.0	1390	3600	100	ZC 7/31/83
33 hr	71°	86.0	11.0	1390	3600	100	ZC 7/31/83
36 hr	71°	86.0	11.0	1390	3600	100	AL 7/31/83
39 hr	71°	86.0	11.0	1390	3600	100	ZC 7/31/83
42 hr	71°	61.0	11.0	1380	3600	100	AS 7-31-83
45 hr	71°	61.0	11.0	1380	3600	100	AS 8-1-83
48 hr	71°	61.0	11.0	1380	3600	100	AS 8-1-83
Final	70°	57.0	11.0	1390	3600	100	ZC 8/1/83


(2) If temperature exceeds range of 3TIC-9506, take measurements with digital thermometer of 6.2.

(3) Refer to Pump Curve attached.

(4) Nominal valve for Pump Speed is 3570 rpm.

ATTACHMENT 2 - MOTOR DRIVEN
 AUXILIARY FEEDWATER PUMP P-141 ENDURANCE RUN
 DATA RECORD

"BEARING TEMPERATURE VS. TIME"




SOS-SPSU-1234
 Page 4 of 5
 3FE-240-01 TCN 0-3
 TCN-03
 Page 3 of 4
 3PE-240-01
 Rev. 0
 Page 16a of 25
 SONGS 3

OFFICIAL TEST COPY

ATTACHMENT 2 - MOTOR DRIVEN
 AUXILIARY FEEDWATER PUMP P-141 ENDURANCE RUN
 DATA RECORD

"PUMP ROOM TEMPERATURE & HUMIDITY VS. TIME"



OFFICIAL TEST COPY

ENCLOSURE I

Attachment 3

RETEST #
ATTACHMENT 3
MOTOR DRIVEN
AUXILIARY FEEDWATER PUMP P-504 ENDURANCE RUN
DATA RECORD

PER TER 1

Time	Bearing Temperatures				Motor Vibration						Pump Vibration						Initial/Date
	3TE-4746A Motor Outboard Inboard (1)	3TE-4746B Motor Inboard Outboard (1)	3TE-4735 Pump Inboard (1)	3TE-4735 Pump Outboard (1)	Outboard			Inboard			Inboard			Outboard			
					H	V	A	H	V	A	H	V	A	H	V	A	
0	115.4	113.6	101.0	113.0	.35	.06	.25	.40	.30	.18	.28	.20	.35	.28	.13	.36	DB 8/25/83
1 hr	179.0	176.0	158.0	172.0	.35	.05	.25	.40	.32	.20	.28	.15	.36	.30	.14	.38	DB 8/25/83
2 hr	181.0	178.0	158.0	175.0	.32	.10	.23	.50	.34	.22	.25	.18	.36	.29	.15	.38	DB 8/25/83
3 hr	182.0	179.0	158.0	177.0	.33	.08	.25	.50	.30	.20	.25	.15	.36	.29	.15	.35	DB 8/26/83
4 hr	182.0	178.4	158.0	177.0	.34	.08	.27	.50	.34	.15	.28	.15	.36	.28	.17	.35	DB 8/26/83
6 hr	181.9	178.9	158.0	177.0	.34	.10	.25	.50	.32	.20	.26	.15	.36	.30	.17	.38	DB 8/26/83
8 hr	181.9	178.9	156.1	175.2	.35	.10	.26	.50	.34	.20	.26	.15	.36	.30	.15	.35	DB 8/26/83
10 hr	181.8	178.9	158	178	.38	.06	.25	.48	.32	.20	.26	.12	.48	.34	.16	.42	ZC 8/26/83
12 hr	184	181	159	178	.38	.06	.25	.48	.32	.20	.27	.15	.44	.32	.16	.60	ZC 8/26/83
15 hr	186	182	160	180	.38	.05	.22	.48	.32	.20	.26	.14	.46	.34	.18	.58	ZC 8/26/83
18 hr	187	182	161	179	.38	.05	.24	.48	.32	.16	.24	.14	.50	.32	.18	.60	ZC 8/26/83
21 hr	185	182	159	178	.38	.05	.25	.48	.32	.18	.24	.15	.50	.34	.18	.60	DB 8/26/83
24 hr	185	181	160	178	.38	.06	.24	.48	.32	.18	.24	.15	.50	.34	.18	.60	DB 8/26/83
27 hr	186	181	159	178	.38	.08	.20	.55	.32	.18	.24	.15	.45	.32	.15	.50	DB 8/27/83
30 hr	185.7	180.4	157.4	176.8	.38	.08	.22	.56	.32	.16	.24	.15	.45	.30	.18	.56	DB 8/27/83
33 hr	186	180	158	178	.38	.06	.24	.48	.30	.16	.24	.15	.40	.30	.15	.58	ZC 8/27/83
36 hr	187	182	160	179	.38	.08	.24	.48	.32	.18	.20	.14	.42	.28	.18	.60	ZC 8/27/83
39 hr	189	183	161	180	.36	.06	.22	.48	.30	.16	.24	.14	.46	.28	.18	.62	ZC 8/27/83
42 hr	189	184	162	180	.34	.05	.22	.48	.32	.16	.20	.14	.42	.30	.16	.62	ZC 8/27/83
45 hr	188.8	183.8	159.3	178.8	.34	.07	.24	.48	.32	.17	.24	.14	.42	.30	.18	.60	DB 8/27/83
48 hr	188.6	183.1	158.8	179.3	.34	.06	.25	.46	.32	.20	.24	.15	.40	.30	.18	.58	DB 8/27/83
Final	188	184	162	178	.34	.07	.24	.44	.31	.22	.24	.12	.44	.30	.16	.58	ZC 8/30/83

(1) Bearing temperatures may be taken using temporary local indication if any of the permanent instrumentation is out of service.

Permanent Instrument _____
 Temporary Instrument ID Number _____
 Next Calibration Due _____

RETEST

ATTACHMENT 3

MOTOR DRIVEN

PER TEST

AUXILIARY FEEDWATER PUMP P-504 ENDURANCE RUN DATA RECORD

Time	Ambient Conditions		Pump Head (3)		Pump Speed (4)	Pump Flow	Initial/Date
	3TIC-9506 Pump Room Temp (2)	Pump Room Humidity	3PI-4734 Suction Pressure	3PI-4736 Discharge Pressure			
0	80	62%	10.5	1350	3600 3630	100 GPM	DEB 8/25/83
1 hr	80	62%	10.5	1375	3600	100 GPM	DEB 8/25/83
2 hr	80	62%	10.5	1375	3600	100 GPM	DEB 8/25/83
3 hr	80	62%	10.5	1375	3600	100 GPM	DEB 8/26/83
4 hr	80	62%	10.5	1375	3600	100 GPM	DEB 8/26/83
6 hr	80	62%	9.5	1375	3590	100 GPM	DEB 8/26/83
8 hr	80	62%	9.5	1375	3590	100 GPM	DEB 8/26/83
10 hr	81	62%	9.5	1375	3590	100 GPM	ZC 8/26/83
12 hr	81	55%	10.5	1380	3590	100	ZC 8/26/83
15 hr	81	52%	11.0	1400	3590	100	ZC 8/26/83
18 hr	82	58%	9.0	1400	3600	100	ZC 8/26/83
21 hr	82	58%	10.5	1400	3600	100	DEB 8/26/83
24 hr	82	58%	10.0	1400	3600	100	DEB 8/26/83
27 hr	82	57%	10.0	1375	3600	100	DEB 8/27/83
30 hr	82	56%	10.5	1375	3600	100	DEB 8/27/83
33 hr	80	60%	10.5	1375	3600	100	ZC 8/27/83
36 hr	81	50%	8.5	1390	3600	100	ZC 8/27/83
39 hr	82	46%	9.0	1400	3600	100	ZC 8/27/83
42 hr	83	50%	9.5	1400	3610	100	ZC 8/27/83
45 hr	83	72%	9.5	1400	3590	100	DEB 8/27/83
48 hr	83	68%	10.5	1400	3590	100	DEB 8/27/83
Final	85	46%	10.0	1400	3590	100	ZC 8/30/83


(2) If temperature exceeds range of 3TIC-9506, take measurements with digital thermometer of 6.2.

(3) Refer to Pump Curve attached.

(4) Nominal valve for Pump Speed is 3570 rpm.

ATTACHMENT - MOTOR DRIVEN
 AUXILIARY FEEDWATER PUMP P-504 ENDURANCE RUN
 DATA RECORD

"BEARING TEMPERATURE VS. TIME"




RETEST # 1

REF TER1 503-SPSU-123a
 240-01 Page 5 of 5
 TCN-03 TCN-03
 Page 4 of 4

3PE-240-01
 Rev. 0
 Page 20 a of 25 of 5
 SOWS 3

ATTACHMENT 3 - MOTOR DRIVEN
 AUXILIARY FEEDWATER PUMP P-504 ENDURANCE RUN
 DATA RECORD

"PUMP ROOM TEMPERATURE & HUMIDITY VS. TIME"



3PE-240-01
 Rev. 0
 Page 21 of 25
 SONGS 3