

LASALLE NUCLEAR POWER STATION

UNIT 1

MONTHLY PERFORMANCE REPORT

AUGUST 1983

COMMONWEALTH EDISON COMPANY

NRC DOCKET NO. 050-373

LICENSE NO. NPF-11

8309140077 830907  
PDR ADOCK 05000373  
R PDR

IE24

## TABLE OF CONTENTS

- I. INTRODUCTION
- II. SUMMARY OF OPERATING EXPERIENCE FOR UNIT ONE
- III. PLANT OR PROCEDURE CHANGES, TESTS, EXPERIMENTS, AND SAFETY RELATED MAINTENANCE
  - A. Amendments to Facility License or Technical Specifications
  - B. Facility or Procedure Changes Requiring NRC Approval
  - C. Tests and Experiments Requiring NRC Approval
  - D. Corrective Maintenance of Safety Related Equipment
- IV. LICENSEE EVENT REPORTS
- V. DATA TABULATIONS
  - A. Operating Data Report
  - B. Average Daily Unit Power Level
  - C. Unit Shutdowns and Power Reductions
- VI. UNIQUE REPORTING REQUIREMENTS
  - A. Main Steam Relief Valve Operations
  - B. ECCS System Outages
  - C. Off-Site Dose Calculation Manual Changes
  - D. Major Changes to Radioactive Waste Treatment System
  - E. Changes to the Process Control Program

## I. INTRODUCTION

The LaSalle Nuclear Power Station Unit One is a Boiling Water Reactor with a designed electrical output of 1078 MWe net, located in Marseilles, Illinois. The Station is owned by Commonwealth Edison Company. The Architect/Engineer was Sargent & Lundy, and the primary construction contractor was Commonwealth Edison Company.

The condenser cooling method is a closed cycle cooling pond. The plant is subject to License Number NPF-11, issued on April 17, 1982. The date of initial criticality was June 21, 1982. The unit has not commenced commercial generation of power.

This report was compiled by Diane L. Lin, telephone number (815)357-6761, extension 499.

## II. SUMMARY OF UNIT OPERATING EXPERIENCE FOR UNIT ONE

August 1-12 The unit started the reporting period at approximately 54% reactor power. At 0221 hours on August 4 reactor power was reduced to restart the RR pumps. Reactor power was 36%. At 0700 hours on August 4 reactor power was increased to 63%. At 0445 hours on August 7 reactor power was 83%. At 0200 hours on August 8 the reactor was at 100% power. On August 9 at 0250 hours reactor power was reduced from 95% to 64%. At 2212 on August 9 reactor power was 92%. On August 11 at 1728 hours reactor power was decreased to approximately 70% for reactor recirc testing. At 0945 hours on August 12 reactor power was increased to 90% via reactor recirc system. On August 12 at 1250 hours the reactor scrambled while performing LIS-NR-04 the section on APRM Channel C, flow bias reference set point. Received a downscale trip which caused the RR FCV to open and the unit to scram. The reactor was critical for 276 hours and 50 minutes.

August 13-31 The reactor went critical at 0600 hours on August 13. At 1413 hours on August 13 the main generator was synchronized to the grid and loaded. At 2300 hours on August 13 reactor power was 47%. At 1500 hours on August 14 reactor power was 71%. On August 16 at 2100 hours reactor power was 95%. At 1705 hours on August 18 reactor power was reduced due to a GSEP alert initiated because of the 'A' VE Charcoal bed getting wet. At 2323 hours on August 18 reactor power was 52%. At 1700 hours on August 19 reactor power was 80%. On August 20 at 0932 the reactor scrambled due to low feedwater flow. On August 22 this outage was continued to replace the "B" recirc pump seals, heater drain system modifications and local leak rate testing. Also the main control valves were converted from partial arc to full arc steam admission. The reactor was critical for 171 hours and 32 minutes.

III. PLANT OR PROCEDURE CHANGES, TESTS, EXPERIMENTS AND SAFETY RELATED MAINTENANCE

- A. Amendments to Facility License or Technical Specifications.  
There were no amendments to the facility license or technical specifications during the reporting period.
  
- B. Facility or Procedure Changes Requiring NRC Approval.  
There were no facility or procedure changes requiring NRC approval during the reporting period.
  
- C. Tests and Experiments Requiring NRC Approval.  
There were no tests or experiments requiring NRC approval during the reporting period.
  
- D. Corrective Maintenance of Safety Related Equipment.  
The following tables present a summary of safety-related maintenance completed on Unit One during the reported period. The headings indicated in this summary include: Work Request Numbers, LER Numbers, Component Name, Cause of Malfunctions, Results and Effects on Safe Operation, and Corrective Action.

WORK REQUEST	LER	COMPONENT	CAUSE OF MALFUNCTION	RESULTS AND EFFECTS ON SAFE OPERATION	CORRECTIVE ACTION
L23265	---	D/G Air Receiver Pressure Indicator Isolation Valve	Bad Valve	Valve leaks	Replaced valve
L23828	---	Unit One 250 V <sup>Battery</sup> Charger	Bad breaker	Breaker is weak	Replaced <u>breaker</u>
L25831	83-080/03L-0	LPCS Water Leg Pump	Locked bearing	Pump frozen with the outboard bearing locked.	Replaced bearings, oil seals, mechanical seal, shaft, shaft sleeve
L25902	83-082/03L-0	Rx Bldg. Vent Exhaust Plenum Rad Monitor	Bad GM tube	Spurious upscale trip Observed.	Replaced GM tube
L26033	83-077/03L-0	Ammonia Dectecor	Bad master fault bulb	Optical unit not working	Replaced master fault bulb
L26044	83-083/03L-0	SBGT WRGM	Blown fuse	Pump didn't start in manual	Replaced fuse
L26101	83-078/03L-0	LPCS Injection Valve Low Pressure Switch	Switch out-of-adjustment	Alarm is up when pressure is not low	Recalibrated switch
L26118 L26119	---	Unit 1 Fuel Pool Vent PRM A & B	Bad detector tube	Background response increasing over time	Replaced detector tube
L26207	---	RHR Service Water Pump A-B Cubicle Temperature Hi Alarm	Bad fuse	Cubicle has high Temperature	Replaced fuse
L26576	---	HPCS Discharge Pressure Gauge	Air trapped on high side of gauge	Gauge reads lower than local gauge	Vented air
L26617	---	Division 1 Post Loca Hydrogen Monitor	Motor drive out-of alignment. Pen drive & spring loose	Recorder reads ~2% Hydrogen with the unit S/D	Realigned motor drive. Tightened pen drive and spring

WORK REQUEST	LER	COMPONENT	CAUSE OF MALFUNCTION	RESULTS AND EFFECTS ON SAFE OPERATION	CORRECTIVE ACTION
L26654	---	OPL58JA Pen #1	Problem due to heat	Pen is stuck downscale	Fixed cooling fans
L26657 L26658	---	Chlorine Detector A & B	Bad Felt wick	Electronic drip rate exceeds 4 minutes as specified in vendor manual	Replaced felt wick
L26707	---	Leak Detector $\Delta$ T Recorder	Bad amplifier	Recorder pegs high and/or low when it is pulled out and pushed in	Replaced amplifier
L26878	---	Standby Gas Treatment system Effluent and Iodine Recorder	Bad chart drive motor	Paper does not advance	Replaced chart drive motor
L27036	---	"1B" LPCI Testable Check	Appears Spring tension was set too tight	Valve binds requiring wrench assist to open and close	Cleaned and relubricated bearing. Reset timing. Adjusted spring tension.
L27037	---	"1C" LPCI Testable Check	Limit Switch dirty	Valve did not cycle properly	Cleaned limit switch
L27181	---	250 VDC Battery Charger	Blown fuse	Keeps tripping both AC feeds and DC output breakers	Replaced fuse

#### IV. LICENSEE EVENT REPORTS

The following is a tabular summary of all licensee event reports for LaSalle Nuclear Power Station, Unit One, occurring during the reporting period, August 1 through August 31, 1983. This information is provided pursuant to the reportable occurrence reporting requirements as set forth in section 6.6.B.1 and 6.6.B.2 of the Technical Specifications.

<u>Licensee Event Report Number</u>	<u>Date</u>	<u>Title of Occurrence</u>
83-076/03L-0	7-09-83	RCIC Steam Line High Flow Isolation
83-077/03L-0	7-16-83	B System Ammonia Detector
83-078/03L-0	7-19-83	Reactor Vessel Low Pressure LPCS Injection Valve Permissive
83-079/03L-0	7-08-83	Reactor Low Pressure RCIC Isolation
83-080/03L-0	7-07-83	LPCS Water Leg Pump
83-081/03L-0	7-18-83	Hole in FW Pipe
83-082/03L-0	7-11-83	Stack WRGM
83-083/03L-0	7-17-83	SBGT WRGM
83-084/03L-0	7-18-83	PCIS Valve 1CM027 Failed to Isolate
83-085/03L-0	7-22-83	Failure of a RHR SW PRM Sample Pump
83-086/03L-0	7-24-83	Unit 2 Division 1 Battery Charger
83-087/03L-0	7-18-83	Bypass Valves Failed Open/ECCS Initiation
83-088/03L-0	7-27-83	Illinois Dept. of Nuclear Safety Uncontrolled Release
83-089/03L-0	7-25-83	Failure of Unit 2 SBGT Heaters to Energize
83-090/03L-0	7-26-83	Leak in Line Designed to Contain Radioactive Liquid



LER's (Con't)

<u>Licensee Event Report Number</u>	<u>Date</u>	<u>Title of Occurrence</u>
83-091/03L-0	8-04-83	Reactor Vessel Lo Lo Water Level
83-092/03L-0	8-01-83	Control Rod 34-43 Accumulator Inop
83-093/03L-0	8-01-83	Control Rod 34-47 Full In Light Inop
83-094/03L-0	8-05-83	Radwaste Discharge Sample Pump Seal Failure

## V. DATA TABULATIONS

The following data tabulations are presented in this report:

- A. Operating Data Report
- B. Average Daily Unit Power Level
- C. Unit Shutdowns and Power Reductions

## VI. UNIQUE REPORTING REQUIREMENTS

### A. Main Steam Relief Valve Operations for Unit 1

There were no main steam relief valve operations for the reporting period.

### B. ECCS Systems Outages

The following outages were taken on ECCS Systems during the reporting period:

<u>Outage No.</u>	<u>Equipment</u>	<u>Purpose of Outage</u>
1-777-83	HPCS Water Leg Pump	Repair Oil Leak
1-796-83	HPCS Water Leg Pump	Replace Pump

### C. Off-Site Dose Calculation Manual

There were no changes to the Off-Site Dose Calculations Manual during this reporting period.

### D. Radioactive Waste Treatment System

There were no changes to the Radioactive Waste Treatment System during this reporting period.

### E. Process Control Program

There were no changes to the Process Control Program during this reporting period.

OPERATING DATA REPORT

DOCKET NO. 050-373  
UNIT LaSalle One  
DATE Sept. 7, 1983  
COMPLETED BY Diane L. Lin  
TELEPHONE (815) 357-6761

OPERATING STATUS

1. REPORTING PERIOD: August 1983 GROSS HOURS IN REPORTING PERIOD: 744  
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 100% MAX. DEPEND. CAPACITY (MWe-Net): 0  
DESIGN ELECTRICAL RATING (MWe-Net): 1078  
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): \_\_\_\_\_

4. REASONS FOR RESTRICTION (IF ANY):

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL	<u>448.4</u>	<u>1029.0</u>	<u>6457.6</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>440.1</u>	<u>2557.98</u>	<u>4415.68</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>1131742</u>	<u>4567722</u>	<u>6708301</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>361365</u>	<u>1383413</u>	<u>1743503</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>342556</u>	<u>1268919</u>	<u>1729694</u>
12. REACTOR SERVICE FACTOR	<u>NA</u>	<u>NA</u>	<u>NA</u>
13. REACTOR AVAILABILITY FACTOR	<u>NA</u>	<u>NA</u>	<u>NA</u>
14. UNIT SERVICE FACTOR	<u>NA</u>	<u>NA</u>	<u>NA</u>
15. UNIT AVAILABILITY FACTOR	<u>NA</u>	<u>NA</u>	<u>NA</u>
16. UNIT CAPACITY FACTOR (Using MDC)	<u>NA</u>	<u>NA</u>	<u>NA</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>NA</u>	<u>NA</u>	<u>NA</u>
18. UNIT FORCED OUTAGE RATE	<u>NA</u>	<u>NA</u>	<u>NA</u>

19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: 9/11/83

21. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY \_\_\_\_\_ 6/21/82  
INITIAL ELECTRICITY \_\_\_\_\_ 9/4/82  
COMMERCIAL OPERATION 9/23/83 \_\_\_\_\_

OPERATING DATA REPORT

DOCKET NO. 050-373

UNIT LaSalle One

DATE August 8, 1983

COMPLETED BY Diane L. Lin

TELEPHONE (815)357-6761

OPERATING STATUS

1. REPORTING PERIOD: July 1983 GROSS HOURS IN REPORTING PERIOD: 744

2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 100% MAX. DEPEND. CAPACITY (MWe-Net): 0  
DESIGN ELECTRICAL RATING (MWe-Net): 1078

3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): N/A

4. REASONS FOR RESTRICTION (IF ANY):

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL	<u>580.6</u>	<u>2371.8</u>	<u>6009.2</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>501.5</u>	<u>2117.88</u>	<u>3975.58</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>1028597</u>	<u>3435980</u>	<u>5576559</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>321018</u>	<u>1022948</u>	<u>1543347</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>300122</u>	<u>926363</u>	<u>1387138</u>
12. REACTOR SERVICE FACTOR	<u>NA</u>	<u>NA</u>	<u>NA</u>
13. REACTOR AVAILABILITY FACTOR	<u>NA</u>	<u>NA</u>	<u>NA</u>
14. UNIT SERVICE FACTOR	<u>NA</u>	<u>NA</u>	<u>NA</u>
15. UNIT AVAILABILITY FACTOR	<u>NA</u>	<u>NA</u>	<u>NA</u>
16. UNIT CAPACITY FACTOR (Using MDC)	<u>NA</u>	<u>NA</u>	<u>NA</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>NA</u>	<u>NA</u>	<u>NA</u>
18. UNIT FORCED OUTAGE RATE	<u>NA</u>	<u>NA</u>	<u>NA</u>

19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: \_\_\_\_\_

21. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY	<u>6/21/83</u>
INITIAL ELECTRICITY	<u>9/4/82</u>
COMMERCIAL OPERATION	<u>9/23/83</u>

ATTACHMENT A

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-373  
UNIT LaSalle One  
DATE Sept: 7, 1983  
COMPLETED BY Diane L. Lin  
TELEPHONE (815) 357-6761

MONTH August 1983

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1.	<u>632</u>
2.	<u>646</u>
3.	<u>516</u>
4.	<u>599</u>
5.	<u>683</u>
6.	<u>771</u>
7.	<u>934</u>
8.	<u>1014</u>
9.	<u>867</u>
10.	<u>990</u>
11.	<u>941</u>
12.	<u>493</u>
13.	<u>101</u>
14.	<u>513</u>
15.	<u>743</u>
16.	<u>911</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17.	<u>987</u>
18.	<u>848</u>
19.	<u>846</u>
20.	<u>377</u>
21.	<u>0</u>
22.	<u>0</u>
23.	<u>0</u>
24.	<u>0</u>
25.	<u>0</u>
26.	<u>0</u>
27.	<u>0</u>
28.	<u>0</u>
29.	<u>0</u>
30.	<u>0</u>
31.	<u>0</u>

ATTACHMENT B  
UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH August 1983

DOCKET NO. 050-373

UNIT NAME LaSalle One

DATE Sept. 7, 1983

COMPLETED BY Diane L. Lin

TELEPHONE (815) 357-6761

NO.	DATE	TYPE		DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
		F: FORCED	S: SCHEDULED				
30	8/09/83	F		0	H	5	Reduced power from 95% to 64%
31	8/11/83	S		0	H	5	Reduced power for Reactor Recirc. testing
32	8/12/83	F		17.2	B	3	Reactor scram due to APRM Hi Hi Alarm
33	8/18/83	F		0	A	5	'A' VE Charcoal Bed got wet
34	8/20/83	F		278.5	A	3	Reactor scram due to low Reactor water inlet flow



**Commonwealth Edison**  
LaSalle County Nuclear Station  
Rural Route #1, Box 220  
Marseilles, Illinois 61341  
Telephone 815/357-6761

September 7, 1983

Director, Office of Management Information  
and Program Control  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

ATTN: Document Control Desk

Gentlemen:

Enclosed for your information is the monthly performance report covering LaSalle County Nuclear Power Station, Unit One, for the period covering August 1 through August 31, 1983.

Very truly yours,

*G. J. Diederich*

G. J. Diederich  
for Station Superintendent

GJD/DLL/rmp

Enclosure

xc: J. G. Keppler NRC, Region III  
NRC Resident Inspector LaSalle  
Gary Wright III, Dept. of Nuclear Safety  
D. P. Galle CECO  
D. L. Farrar CECO  
INPO Records Center

IE24  
//