

February 7, 1984

DMB

Docket No. 50-266

Docket No. 50-301

Wisconsin Electric Power Company
ATTN: Mr. Sol Burstein
Executive Vice President
Power Plants
231 West Michigan
Milwaukee, WI 53201

Gentlemen:

We have completed our review of Revision 21 to Sections EP 4.0 and EP 8.0 and Revision 4 to Appendix D of the Point Beach Emergency Plan. Our review indicated that these changes to your emergency plan meet the planning standards of 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR 50.

Please be reminded that 10 CFR 50.54(q) requires NRC approval of any changes to your plan which may decrease the effectiveness of the plan. However, if your safety review indicates no decrease in emergency preparedness, then changes can be made without NRC approval. In all cases, you should furnish copies of each proposed change to the NRC in accordance with 10 CFR 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of 10 CFR 50, Appendix E, Section V (Implementing Procedures).

Should you have any questions regarding the letter, please contact Mr. William Snell of my staff at 312/790-5513.

Sincerely,

C. J. Paperiello, Chief
Emergency Preparedness and
Radiological Safety Branch

Enclosure: 1tr dtd 1/31/84

cc w/encl.:

J. J. Zach, Plant Manager
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
John J. Duffy, Chief
Boiler Section
Peter Anderson, Wisconsin's
Environmental Decade
Ness Flores, Chairperson

8402100229 840207
PDR ADOCK 05000266
F PDR

IE:35

11

OFFICE	Wisconsin Public Service	RIII/DRMSP	RIII	RIII	RIII
SURNAME	Commission	Snell/mf	Phillys	Jackie	Paperiello
DATE	Wally Weaver, FEMA, Region V	2/6/84	2/6/84	2/6/84	2/6/84