



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

83 SEP 15 P 1: 36

NUCLEAR PRODUCTION DEPARTMENT

September 12, 1983

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-052/1 - Update
Report - Fire Rated Penetrations
Opened to Implement Design
Change Packages
AECM-83/0508

This is an update to a previous report submitted on June 27, 1983. The conditions for which the report was submitted occurred beginning on May 23, 1983, when the following fire rated penetrations were opened to implement design change packages:

PENETRATIONS

CE-276 DA
CE-132 E
AE-74D

INCIDENT REPORT NO.

83-05-52
83-05-64
83-05-63

This required entering the action statement for Technical Specification 3.7.7 and was reported as a Special Report pursuant to Technical Specification 6.92. Hourly fire watches were established within one hour and were maintained until the penetrations were resealed. The last penetration associated with this Special Report was restored on August 29, 1983.

Yours truly,

L. F. Dale

for L. F. Dale
Manager of Nuclear Services

EBS/SHH:rg

cc: See next page

8309190150 830912
PDR ADOCK 05000416
F PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22

110

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0508

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555