WHITE MESA MILL

PROCEDURES MANUAL

January 1985

APPENDIX D

ENVIRONMENTAL SURVEILLANCE PROCEDURES MANUAL

TABLE OF CONTENTS

		Page
1.0	AIR MONITORING	
	1.1 Particulate Radionuclides	1
	1.2 Radon-222	8
	1.3 Meteorological	13
	1.4 Source Emissions	19
	1.5 Lab Instrumentation	30
2.0	WATER MONITORING	
	2.1 Surface Hydrology	32
	2.2 Groundwater Hydrology	36
	2.3 Culinary Supply	42
	2.4 Instrumentation	45
3.0	TAILING MONITORING	
	3.1 Tailing Stability	49
	3.2 Liner Integrity	59
1.0	MISCELLANEOUS	
	4.1 External Radiation, Soil and Vegetation Uptake	60
5.0	ADMINISTRATIVE CONTROL - ALARA	
	5.1 Audit Program	65

1.0 AIR MONITORING

Sect	1.1		
Page 1	of 7		
Revison:	Zero		
Date:	1/85		

WHITE MESA PROCEDURES MANUAL

Monitoring Guideline Environmental

AIR MONITORING - PARTICULATE

RADIONUCLIDES

1.0 EQUIPMENT

Equipment utilized in monitoring levels of ambient particulate radionuclides is composed of high volume (40 cfm) air samplers manufactured by General Metals Works and equipped with mass flow controllers and vacuum switch controlled timers. The mass air flow controller, once calibrated, varies the actual air flow rate, as affected by changing temperature, filter loading, and barometric pressure, to maintain a constant standard air flow rate. The timer, recording continuous run time, is controlled by a vacuum switch which automatically deactivates the timer when no vacuum exists in the system, i.e., when the motor/blower assembly is disconnected or malfunctions.

The high volume air sampler used is the General Metal Works Model 2310 Accu-Vol, with a modification on the timer. These samplers utilize an eight by ten inch glass microfiber filter such as:

- 1. Whatman EPM 1000 or
- 2. Schliecher & Schuell #! HV.

Calibration equipment consists of a Model GMW-6000 Primary Calibration System Roots Meter and Model GMW-25 calibration orifice assembly.

2.0 MONITORING METHODOLOGY

The air samplers are mounted on wooden towers two meters above ground plane and operate through use of 110-volt line power. The samplers run continuously except for calibration, mechanical or electrical failure, and maintenance downtime.

Calibration of equipment occurs monthly, or following maintenance downtime, using the orifice plate method.

The sampler flow rate is regulated to a standard air volume, using twenty-five degrees centigrade and twenty-nine point nine-two inches of mercury as standard conditions.

Sect	1.1	
Page 2	of	7
Revison:	Zero)
Date:	1/85	

2.0 MONITORING METHODOLOGY (continued)

Sample media replacement is scheduled weekly due to particulate loadings. Maximum filter use duration will be weekly.

Sample handling is as follows:

The filter media is removed from the package and is examined by naked eye by passing the media between the eye and a light source to detect any visible tears or pin pricks. Any abnormality in the filter is cause for discardment of the filter.

The filter is stamped in code signifying the filter number. The filter is pre-weighed to the nearest 0.0001 gram utilizing a Sartorious Model 2432 analytical balance. The filter tare weight is then recorded on the filter envelope along with the location, filter number, and date. On return from the field, the filter is again re-weighed and gross weight is recorded on the filter envelope. The filter number, net weight, and duration is recorded on the sample station log sheet.

At the sampler, following shutdown of the system, the "loaded" filter is removed, folded, and placed within it's original envelope. The envelope is marked by dates for the duration of the sample, time changed, and actual operating time in minutes. If any part of the filter remains on the seal gasket, it is removed and added to the envelope contents. The new, clean filter is removed from its envelope and placed over the suction head with the filter holder tightened enough for a seal, but not tight enough to rupture the filter. The sampler is then activated.

On a quarterly basis, each station filters are composited. The samples are forwarded, along with an analytical sheet to the Analytical Laboratory in a sealed transport container. The analytical results are then returned via a copy of this form. Blank filters are sent in quarterly for background radionuclide concentrations.

3.0 CALIBRATION

Samplers are checked monthly using the orifice plate assembly for calibration documentation. In addition, samplers are checked by this method following each motor replacement.

The calibration procedure is:

- Obtain air temperature and barometric pressure levels at the site.
- Place a clean filter on the sample platform and mount the calibrated orifice on it.

Sect		1.1	
Page	3	of	7
Reviso	n:	Zero)
Date:		1/85)

3.0 CALIBRATION (continued)

- Place the filter under vacuum and obtain pressure differential across orifice plate.
- Using this pressure differential, refer to orifice calibration curve graph to obtain the uncorrected flow rate (Qa).
- 5. Determine the corrected flow rate (Qs) using the following equation:

$$Qs = Qa \times \begin{bmatrix} T_1P_2 \end{bmatrix}^{1/2}$$

Note: T1 = Absolute Temperature at orifice calibration (273+ °C = degrees Kelvin)

T² = Absolute Temperature at hi-vol calibration (degrees Kelvin)

Pl = Atmospheric Pressure at orifice calibration -Standard - 760 MM Hg

p2 = Atmospheric Pressure at hi-vol calibration

- 6. Qs is the standard flow rate.
- 7. To correct equipment to the required standard flow rate, use the following equation:

$$Qa = Qs \ X \ \frac{T_2P_1}{T_1P_2}^{1/2}$$

where: Qs is the required standard flow rate.

- 8. Determine the manometer reading from the orifice calibration curve which gives a flow rate of Qa.
- 9. Set the hi-vol to this manometer reading. (Flow through the equipment setup is regulated by the flow controller through adjustment of the screw mounted on transformer pl of the flow controller).
- Disconnect the orifice and reassemble the filter head assembly for normal operation.

The orifice is recalibrated semi-annually against a positive displacement Roots meter to obtain the above-required orifice calibration curve.

Sect		1.1	
Page	4	of	7
Reviso	n:	Zero)
Date:	-	1/85)

4.0 RECORD KEEPING

Information included on the individual sample station log sheet is:

- 1. Sample period;
- 2. Sampling Location;
- 3. Suration of each sample, minutes;
- 4. Sample ID Number;
- 5. Sampler Flow Rate, Total Sample Volume, Standard Conditions;
- 6. Filter net weight, milligrams;
- 7. Analytical values in concentrations per composite sample;
- 8. Computed air concentrations (standard air conditions); and,
- 9. General Remarks.

Filters are analyzed for: U-nat., Ra-226, Th-230 and Pb-210.

Documentation of calibrations is maintained on Form UMC-A-1 attached.

The above form is maintained in that year's Environmental Operating log book under the appropriate sections or in computer files.

5.0 MONITORING LOCATIONS AND FREQUENCY

Particulate sampling is on a continuous basis with weekly or twice weekly rotation of filters and quarterly compositing of filters for analysis.

The monitoring locations are:

- BHV-1; northeast of mill;
- 2. BHV-2; nearest resident;
- BHV-3; Black Mesa background;
- 4. BHV-4; Southwest of mill; and
- 5. BHV-5; east southeast of mill.

Sect		1.1	
Page	5	of	7
Revison:		Zero	
Date:	-	1/85	

AIR SAMPLER CALIBRATION WORKSHEET

UMETCO MINERALS CORPORATION WHITE MESA

SITE	DATE	AIR TEMP.OC	BARO. PRESS	INT. "H ₂ 0	INT. RATE	FIN. "H20	FINAL FLOR
Sp.D						-	
TABE.	-				-	***************************************	
CLAR.				-	***************************************		
SEW.		****	***************************************		-	-	
SWP.	-	-	-	-	-	-	
C-B			-	-		***************************************	
F-B	***************************************	-	-			**********	-
W#2	***************************************	Marie and the state of the stat	***************************************		-	-	
FUS.	-		-	************		-	
	- Martin Martin		***************************************	***************************************	-	-	-
		°C	"H ₂ 0		scfm		scfm
CALCIU AT	TOUR AND		-				- 70 7 500

CALCULATIONS ARE:

To calculate Initial Flow Rate:

1. Determine actual flow rate (Qa) from calib. curve for manometer reading for orifice

2. Determine the standard flow rate (Qs) using:

Qs=Qa X
$$\begin{bmatrix} T_1P_2 \\ T_2P_1 \end{bmatrix}$$
 1/2

To calculate final flow rate:
1. Determine Qa for a Qs of 40 scfm using:

Qa=Qs X
$$\begin{bmatrix} T_1P_2 \\ T_2P_1 \end{bmatrix}$$
 1/2

- Determine the manometer reading from the orifice calibration curve which gives a flow rate of Qa.
- Adjust sampler using flow controller adjustment.

NOTE:

 T_1 =ABSOLUTE TEMPERATURE AT ORIFICE CALIBRATION (273+ $^{\circ}$ C). (298 $^{\circ}$ K) T_2 =ABSOLUTE TEMPERATURE AT AIR SAMPLER CALIBRATION. (273 + $^{\circ}$ C) P_1 =ATMOSPHERIC PRESSURE AT ORIFICE CALIBRATION (29.92 "Hg) P_2 =ATMOSPHERIC PRESSURE AT AIR SAMPLER CALIBRATION ("Hg).

Sect		1.1		
Page	6	of	7	
Reviso	n:	Zero		
Date:	-	1/85		

6.0 ANALYSIS PROCEDURE

The analytical procedures utilized are presented in detail in the Analytical Procedures Manual of the representative laboratory.

Analytical results are forwarded to White Mesa showing values for requested time intervals as curies or micrograms per composite sample.

In calculating radionuclide concentrations in air, analytical data is entered into a computer program which draws corresponding data from the field information file, sample dates, flow rates, sample duration, and net particulate loading, calculates concentrations and stores them in another file.

- 1. For uranium, the reported sample assay value is subtracted by the reported blank filter value. This result is then divided by the known standard air volume and conversion constants to achieve a concentration in air value. If any value is of a less than value, then fifty percent of that value is utilized and a less than value is assigned to the result.
- 2. For thorium, radium, and lead-210, the reported sample assay values and the blank assay values are reported with a counting error term. The resultant value is the difference between the sample assay value and the blank value divided by the known sampled air volume. The counting error deviation is the square root of the sum of the counting error terms squared and divided by the known sampled air volume.

7.0 QUALITY ASSURANCE

Installation/Removal of Filters

Quality assurance is maintained by:

- Inspecting all new filters for aberrations and discarding those that are;
- 2. Maintaining seals on equipment connections;
- Careful installation and removal of filters, retaining all abraded filter media;
- 4. Proper sealing of all gaskets;
- 5. Proper sequential handling of filters; and,
- Filters are inspected for fingerprint contamination by visual observation of fingerprints.

Sect	1.1
Page 7	of 7
Revison:	Zero
Date:	1/85

7.0 QUALITY ASSURANCE (continued)

Sample Duration

Record maintenance of sample duration is assured by:

- Installation of a vaccum-actuated timer which operates the timer only when motor is running and pulling the minimum allowable vacuum; and,
- Weekly monitoring of motor brush and alternator bearing wear/proper changeout at appropriate intervals.

Sample Flowrate

Quality assurance of sample flowrate is by monthly checks of flow controller operation and documentation thereof. Samplers are checked for calibration at motor rotation intervals. Sample flowrates are maintained within seven percent of required flowrate.

Calculations

Calculations are checked on a random basis for inconsistencies and are documented.

Upon retrieval of the data analytical sheet from the support laboratory, the date of receipt is noted along with the date of transcribing to the sample station log sheet and the transcriber's initials. The transcription of data is reviewed by another person of the department to minimize transposition of numerical values. Calculation and data storage is by computer program.

Sampler Performance

A record of sampler operation time versus total possible duration time is maintained as a flag against excessive equipment downtime. Sampler performance is reviewed monthly.

Sect	1.2
Page 1	of 5
Revison:	Zero
Date:	1/85

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINE

ENVIRONMENTAL

AIR MONITORING - AMBIENT

RADON GAS

1.0 EQUIPMENT

Equipment utilized in monitoring ambient levels of Rn-222 gas is the Passive Environmental Radon Monitors, (PERMS), issued by Western Radiation Consultants, which utilize an ionized TLD chip (at 670 volts) as the collector for alpha particles and an unionized TLD chip as a collector of gamma level radiation. A humidity trap of approximately three point three (3.3 lbs.) pounds of silica gel (with indicator coloration) is used to control humidity conditions within the ionized collection cone of the sampler. The silica gel is changed based solely upon the change in color of the indicator, approximately monthly, at White Mesa. The TLD's utilized are Harshaw TLD-100 (Lithium Fluoride) for gamma and Harschal TLD-200 (Calcium Fluoride) for alpha collection.

2.0 MONITORING METHODOLOGY

The "PERMs" are located at three meters above ground level.

The PERM's TLD's are rotated the first week of each month for analysis. Two sets of TLD's are utilized for each PERM. The alpha chip, covered by a aluminized mylar shield, is mounted on a cathode with a plastic "O" ring holding it in place. The gamma chip is mounted within a sealed plastic container which is fastened by an "O" ring in the vicinity of the alpha chip and cathode assembly. Handling of the chips, themselves, is done solely by the technical staff of the support laboratory.

One set of chips, in their individual holders, is rotated monthly to the Western Radiation Consultants laboratory for counting purposes while the other is placed in the monitor. The chips installed are forwarded monthly to White Mesa where the rotation occurs within two days. Each set of chips, one set containing a lithium fluoride chip assembly and a calcium fluoride assembly, per monitor station, is transported in its individual container. The chips are contained within their individual labeled holders, one set marked "A", and the other "B", and are changed thereby to prevent transposition of chips.

Sect	1.2
Page 2	of 5
Revison:	Zero
Date:	1/85

3.0 CALIBRATION

Calibration of the PERM's and TLD chips is performed by Western Radiation Consultants. This calibration occurs between receiving the units from the manufacturer and installation in the field.

The reaction activity level of the TLD chip, when heated to the proper temperature, is related to the known radon gas concentration and gamma levels and test duration in determining individual chip performance and calibration coefficients. Analytical error is the summation of counting error, TLD chip performance error, and sampling duration error.

The batteries used for the cathode energization are Eveready Photoflash No. 497 batteries wired to give 670 volts. The battery life is approximately one year and they are changed annually. Voltage potential is checked by a high voltage electrostatic voltmeter quarterly.

4.0 RECORD KEEPING

The month's TLD chips, in their respective containers, are forwarded by sealed container via the postal service to the support laboratory in Fort Sheet on which the analytical and chain of custody data is recorded. Upon where the data is transcribed from the transmittal to computer files by the ambient radon gas section of the maintained files, separated by year

Sect	1.2
Page 3	of 5
Revison:	Zero
Date:	1/85

5.0 MONITORING LOCATIONS AND FREQUENCY

Radon 222 is monitored continuously with monthly rotation of the sensors (chips) and correspondingly an average monthly result of concentration and deviation.

The monitoring locations are:

- 1. BHV-1, northeast of mill,
- 2. BHV-2; nearest resident,
- 3. BHV-3; Black Mesa background,
- 4. BHV-4; southwest of mill.
- 5. BHV-5; east southeast of mill, and
- 6. BHV-6; nearest resident (duplicate).

6.0 ANALYSIS PROCEDURE

The analytical procedures utilized are presented in detail in the Western Radiation Consultants Procedure Manual. The concentration represented on the lithium fluoride (gamma) assay is subtracted from that represented on the calcium fluoride (gamma and alpha) assay to give a representative value of the alpha concentration exposed to by the cathode chip. This value corresponds to a predetermined Radon-222 level in the ambient environment.

After analysis, the chips are heated to a higher temperature and reactivated for further field usage.

7.0 QUALITY ASSURANCE

Installation/Removal of Chips

Quality assurance during installation and removal of the sensors on a monthly basis is maintained by:

- Inspecting the sensors to ensure the chips are present and situated properly;
- Inspecting the sensors for proper labelling;
- Inspecting all electrical connections before and after chip changeout to ensure proper current flow;
- Inspecting battery casing for battery leakage;

Sect	1.2		
Page 4	of	5	
Revison:	Zero		
Date:	1/85		

7.0 QUALITY ASSURANCE (continued)

- 5. Proper rotation of set A and set B chips;
- 6. Installation of site chips, for analysis, into site transport box immediately upon removal from monitor; and
- 7. Protection of chips from direct sunlight and heat buildup during rotation.

Access to the section containing the chips within the monitor is controlled by a lock to limit unauthorized access. Abnormal variations to normal operation conditions are noted in field logs by the technician(s) assigned. This includes any vandalism noted.

Humidity Control

Air passing into the unit, via convection, passes through a layer of silica gel for humidity control purposes. The silica gel quantity is approximately one point five (1.5) kilograms. The gel has an indicator coloration which changes from saphire blue to light sky blue to pink as it retains moisture. The gel is changed when greater than fifty (50) percent is sky blue by visual observation. Changeout occurs monthly at chip changeout, and any variation from this frequency is noted in the comment section of the field logs.

Voltage Potential

The PERM increases the collection efficiency for alpha particles by supplying a positive charge of 670 volts to a cathode on which the alpha sensitive chip is placed. The power is derived from two 510 volt batteries connected in series. The combined voltage is checked on a quarterly basis with a precision electrostatic high voltage voltmeter. Variations from desired voltage are noted on field logs. Variations greater than fifty (50) volts require replacement, as reasonably achievable, of the batteries. Batteries used are Eveready Photoflash No. 497. Surveys will be done in January, April, July and October of each year.

Sample Treatment

The TLD Chips are loaded at the site into an individual site container labeled for that site. The chips are checked during preparation for transshipment to the support laboratory. An analytical sheet goes with the chips detailing locations, dates, analytical request, and technician initials. The chips are sent via the postal transport service and are enclosed in a cardboard outer container which is sealed with packaging tape. The support laboratory is verbally notified of the shipment. A copy of the analytical sheet is returned to White Mesa noting arrival at the laboratory and maintained at White Mesa until the completed copy is returned from the support laboratory.

Sect	1.2
Page 5	of 5
Revison:	Zero
Date:	1/85

7.0 QUALITY ASSURANCE (continued)

Data Logging

Upon retrieval of the data analytical sheet from the support laboratory, the data is entered into a computer file for later retrieval.

Sampler Performance

Standby samplers are used on a periodic basis to check equipment and laboratory performance. Data is logged on field logs as a calibration check.

Sect	1.3	
Page 1	of 6	
Revison:	Zero	
Date:	1/85	

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINE

ENVIRONMENTAL

AIR MONITORING - METEOROLOGICAL

1.0 EQUIPMENT

There is one meteorological station at White Mesa. The equipment utilized is summarized below:

- 1. Weathertronics Model 2030, Micro Response Anemometer.
- 2. Weathertronics Model 2020, Micro Response Wind Vane, and
- 3. Campbell Scientific Digital Recorder, Model CR5.

In addition, a substation is maintained at White Mesa and consists of a standard rain/snow gauge.

Standard Rain/Snow Gauge.

The meteorological station is equipped to operate on line or battery backup power, for power outages. The recordkeeping is handled in two methodologies, by digital cassette logging, and by paper tape printout. The logging equipment allows integration averaging over various time intervals from five minutes to twenty-four hours.

2.0 MONITORING METHODOLOGY

2.1 Substation

The substation is monitored at eight each morning by the crew who records twenty-four hour precipitation amounts. This information is utilized weekly by the environmental staff for precipitation storage calculations.

2.2 Meteorological Station

The meteorological station integrates data at a rate of one hundred times per minute and output mean values on an hourly interval basis. Data is outputted onto analog cassette tape and onto a digital paper tape providing two sources of data recovery.

Sect		1.3	
Page	2	of	6
Reviso	n:	Zero)
Date:		1/85	

2.0 MONITORING METHODOLOGY (continued)

2.2 Meteorological Station (continued)

The parameters monitored are:

- 1. Day,
- 2. Hour,
- 3. Minute.
- 4. Wind Mean Velocity, meters per second,
- 5. Total Wind Run, meters per second,
- 6. Wind direction, degrees from north, and
- 7. Stability Deviation, degrees.

3.0 CALIBRATION

3.1 Substation

The substation equipment requires no calibration as equipment meets NOAA specifications and NBS standards.

3.2 Meteorological Station

Calibaration of sensors mounted at the meteorological station is done on the following schedule:

- Semi-annually -- Wind Direction
- 2. Annually -- Wind Velocity

Equipment is recalibrated following maintenance activities and/or above schedule.

3.2.1 Wind Direction

The sixth channel of the CR5 printer record contains wind direction information in degrees clockwise from true north. By aligning the arm of the wind vane to a known compass reading and obtaining the instantaneous readout on the printer, verification of wind direction can be achieved. Adjustment to true direction requires minute rotation of the potentiometer within the wind vane housing and must be accomplished with great care. Accuracy of wind direction should be less than two degree error.

Sect		1.3	
Page	3	of	6
Reviso	n:	Zero)
Date:		1/85	

3.0 CALIBRATION (continued)

3.2.2 Wind Velocity

The fourth channel of the CR5 printer record is wind velocity in meters per second while the fifth channel is total wind run in meters per second. The anemometer operates via a LED diode light emission being interrupted on varying frequencies by a rotating chopper attached to the cups is proportional to a frequency pulse, which is the signal being fed to the CR5 unit.

Calibration is performed by rotating the cup stem, using a constant rpm generator, and comparing frequency pulses at the signal end to the known frequency rate for that rpm. Differences greater than one percent require investigation and servicing of the unit.

4.0 RECORDKEEPING

4.1 Substation

The daily substation data is filed in the Environmental Files at White Mesa on a monthly summary sheet.

4.2 Meteorological Station

Data for wind speed, wind direction and stability classification is retained in computer storage.

5.0 MONITORING LOCATION AND FREQUENCY

Monitoring of meteorological conditions is on a continuous to is. Data collection and retrieval for the substation is daily. Digital tape retrieval of the meteorological data is monthly. Paper tape retrieval is on three week intervals.

Meteorological data is obtained by the sensors at a rate of one hundred times per minute, and the equipment is set up to output averaging data on one-hour intervals.

The site of the substation is behind the main administration building. The meteorological station is located to the northeast of the mill at air sampling station one (BHV-1).

The station has sensors mounted ten meters above the ground plane.

Sect		1.3	
Page	4	of	6
Reviso	n:	Zero)
Date:		1/85	

6.0 QUALITY ASSURANCE METHODOLOGY

6.1 Substation

Quality assurance of the substation consists of:

- 1. Weekly checks by environmental staff of crew function, and
- 2. Monthly checks of data transmittal.

6.2 Meteorological Stations

Quality assurance of the meteorological station is composed of:

- 1. Proper calibration of equipment,
- 2. Documentation of calibration.
- 3. Monthly documented inspections of equipment operation, and,
- 4. Maintenance of replacement standby equipment.

The formats covering calibration documentation and inspections are attached.

Wind direction sensors are checked semi-annually and wind anemometers are calibrated annually, or as needed.

Proper recording of data requires monthly cleaning of tape head mechanism and usage of correct tape for frequency response. The cassette tape to be used is:

TDK D-C90 minute tape

Normal Bias 120 EQS

Sect		1.3	
Page	5	of	6
Revisor	1:	Zero)
Date:	-	1/85)

METEU OGICAL STATION

CALIBRATION LOG

		Sit	e:	ear:
WIND DIRECTIO	DN			
Tech. Int.	Date of Calibration	Sensor Readout	Known RPM Direction	% Error
2.				
3.				
WIND VELOCITY				
Tech. Int.	Date of Calibration	Sensor Readout	Known RPM Velocity	% Error
2.				

3.

Sect		1.3	
Page	6	of	6
Reviso	n:	Zero	
Date:	amaron	1/85	

METEOROLOGICAL STATION

INSPECTION

YEAR	MONTH		TECH.	
Checkoff List				
Power to Unit	Power to	Cassette	Recorder	
Backup Voltage Level				
Date on Tape				
Time on Tape				
Printer Tape Condition				
Tape Head Cleaned				
Time Tape Installed				
Time Tape Reversed				
Time Tape Disconnected				
Anemometer Operation				
Wind Vane Operation				
COMMENTS				

Sect	1.4	
Page 1	of	11
Revison:	Zero)
Date:	1/85	

WHITE MESA PROCEDUPES MANUAL

MONITORING GUIDELINES

ENVIRONMENTAL

AIR QUALITY EMISSIONS

1.0 EQUIPMENT

Monitoring of air quality emissions, or stack sampling, is achieved by White Mesa Environmental personnel using Research Appliance Company equipment as discussed below:

- 1. RAC Model 201009 Model 2414 Stack Sampler Serial Number 2310;
- 2. Two each, RAC Model 201044 Modular Sample Case;
- 3. One each, RAC Model 201019 Umbilical Cord;
- 4. Three each, RAC Model 201013 100mm dia. Filter Holders;
- One each, RAC Model 201005 Standard Pitobe 3 ft length, stainless steel./S-type probe;
- 6. Barometer;
- Pyschronometer;
- 8. Satorius Model 2432 Balance; and
- 9. Triple Beam Balance.

2.0 MONITORING METHODOLOGY

The methods used for radionuclide monitoring of stack emissions are modified versions to EPA methods; STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES - Revision to Reference Method 1-8: Thursday, August 18, 1977, Part II, as attached. Modifications to standard procedures are 11mited to:

- Sample Location: Due to existing stack designs;
- Filter Size: Use of 100mm dia glassfiber filter rather than 64mm dia. glassfiber filter;
- Usage of O.IN nitric acid as impinger solution instead of distilled water, as uranium is more soluble in nitric acid; and,
- 4. Usage of O.1N nitric acid as glassware wash medium.

Sect		1.4	
Page	2	of	11
Reviso	n:	Zero)
Date:		1/8)

2.0 MONITORING METHODOLOGY (continued)

Stack data formats and basic equations utilized in stack sampling are as attached. All calculations are made using either the operating nomograph or by programs written for a Texas Instruments 59 calculator.

Operations of equipment guideline also is attached.

REFERENCE METHODS 1-8



THURSDAY, AUGUST 18, 1977



ENVIRONMENTAL PROTECTION AGENCY



STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

Revision to Reference Method 1-8

Title 40—Protection of Environment CHAPTER I—ENVIRONMENTAL PROTECTION AGENCY

[FRL 754-5]

PART 60-STANDARDS OF PERFORM-ANCE FOR NEW STATIONARY SOURCES

Revision to Reference Methods 1-8

AGENCY: Environmental Protection Agency.

ACTION Final Rule.

SUMMARY: This rule revises Reference Methods I through 8, the detailed requirements used to measure emissions from affected facilities to determine whether they are in compliance with a standard of performance. The methods were originally promulgated December 23, 1971, and since that time several revisions became apparent which would clarify, correct and improve the methods. These revisions make the methods easier to use, and improve their accuracy and reliability.

EFFECTIVE DATE: September 19, 1977.

ADDRESSES: Copies of the comment letters are available for public inspection and copying at the U.S Environmental Protection Agency, Public Information Staf ee Unit (EPA Library), Room 1 M Street, S.W., Washington, 291 20460. A summary of the comments and EPA's responses may be obtained upon written request from the EPA Public Information Center (PM-215), 401 M Street, S.W., Washington, D.C. 20460 (specify "Public Comment Summary: Revisions to Reference Methods 1-8 in Appendix A of Standards of Performance for New Stationary Sources")

FOR FURTHER INFORMATION CON-TACT:

Don R. Goodwin, Emission Standards and Engineering Division, Environmental Protection Agency, Research Triangle Park, North Carolina 27711, telephone No. 919-541-5271.

SUPPLEMENTARY INFORMATION: The amendments were proposed on June 8, 1976 (40 FR 23060). A total of 55 comment letters were received during the comment period—34 from industry, 15 from governmental agencies, and 6 from other interested parties. They contained numerous suggestions which were incor-

porated in the final revisions.

Changes common to all eight of the reference methods are: (1) the clarification of procedures and equipment specifications resulting from the comments, (2) the addition of guidelines for alternative procedures and equipment to make prior approval of the Administrator unnecessary and (3) the addition of an introduction to each reference method discussing the general use of the method and delineating the procedure for using alternative methods and equipment.

Specific changes to the methods are:

METHOD 1

1. The provision for the use of more than two traverse diameters, when spec-

ified by the Administrator, has been deleted. If one traverse diameter is in a plane containing the greatest expected concentration variation, the intended purpose of the deleted paragraph will be fulfilled.

2. Based on recent data from Fluidyne (Particulate Sampling Strategies for Large Power Plants Including Nonuniform Flow, EPA-600/2-76-170, June 1976) and Entropy Environmentalists (Determination of the Optimum Number of Traverse Points: An Analysis of Method 1 Criteria (draft). Contract No. 68-01-3172), the number of traverse points for velocity measurements has been reduced and the 2:1 length to width ratio requirement for cross-sectional layout of rectangular ducts has been replaced by a "balanced matrix" scheme.

3. Guidelines for sampling in stacks containing cyclonic flow and stacks smaller than about 0.31 meter in diameter or 0.071 m* in cross-sectional area will be published at a later date.

 Clarification has been made as to when a check for cyclonic flow is necessary; also, the suggested procedure for determination of unacceptable flow conditions has been revised.

METHOD 2

 The calibration of certain pitot tubes has been made optional. Appropriate construction and application guidelines have been included.

 A detailed calibration procedure for temperature gauges has been included.
 A leak check procedure for pitot lines has been included.

METHOD 3

1. The applicability of the method has been confined to fossil-fuel combustion processes and to other processes where it has been determined that components other than O₁, CO₂, CO, and N₃ are not present in concentrations sufficient to affect the final results.

2. Based on recent research information (Particulate Sampling Strategies for Large Power Plants Including Nominiform Flow, EPA-600/2-76-170, June 1976), the requirement for proportional sampling has been dropped and replaced with the requirement for constant rate sampling Proportional and constant rate sampling have been found to give essentially the same result.

3 The "three consecutive" requirement has been replaced by "any three" for the determination of molecular

weight, CO, and O.

 The equation for excess air has been revised to account for the presence of CO.

 A clearer distinction has been made between molecular weight determination and emission rate correction factor determination.

6 Single point integrated sampling has been included.

METHOD 4

1 The sampling time of 1 hour has been changed to a total sampling time which will span the length of time the pollutant emission rate is being determined or such time as specified in an applicable subpart of the standards.

The requirement for proportional sampling has been dropped and replaced with the requirement for constant rate sampling.

The leak check before the test run has been made optional; the leak check after the run remains mandatory.

METHOD 5

 The following alternatives have been included in the method:

a. The use of metal probe liners.

 b. The use of other materials of construction for filter holders and probe liner parts.

c. The use of polyethylene wash bottles and sample storage containers.

d. The use of desiccants other than silica gel or calcium sulfate, when appropriate.

e. The use of stopcock grease other than silicone grease, when appropriate.

 The drying of filters and probe-filter catches at elevated temperatures, when appropriate.

g. The combining of the filter and probe washes into one container.

2. The leak check prior to a test run has been made optional. The post-test leak check remains mandatory. A method for correcting sample volume for excessive leakage rates has been included.

 Detailed leak check and calibration procedures for the metering system have

been included

Метнор 6

1. Possible interfering agents of the method have been delineated.

2. The options of: (a) v sing a Method 8 impinger system, or (!) determining SO, simultaneously w'th particulate matter, have been 'acluded in the method.

3. Based on recent research data, the requirement for proportional sampling has been dropped and replaced with the requirement for constant rate sampling.

4. Tests have shown that isopropanol obtained from commercial sources occasionally has peroxide impurities that will cause erroneously low SO, measurements. Therefore, a test for detecting peroxides in isopropanol has been included in the method.

5. The leak check before the test run has been made optional; the leak check after the run remains mandatory.

A detailed calibration procedure for the metering system has been included in the method.

METHOD 7

 For variable wave length spectrophotometer, a scanning procedure for determining the point of maximum absorbance has been incorporated as an option.

METHOD 8

 Known interfering compounds have been listed to avoid misapplication of the method.

The determination of filterable particulate matter (including acid mist) simultaneously with SO, and SO, has been allowed where applicable.

Since occassionally some commercially available quantities of isopropanol have peroxide impurities that will cause erroneously high sulfuric acid mist measurements, a test for peroxides in isopropanol has been included in the method.

4. The gravimetric technique for moisture content (rather than volumetric) has been specified because a mixture of isopropyl alcohol and water will have a volume less than the sum of the volumes of its content.

5. A closer correspondence has been nude between similar parts of Methods 8 and 5.

MISCELLANEOUS

Several commenters questioned the meaning of the term "subject to the approval of the Administrator" in relation to using alternate test methods and procedures. As defined in § 60.2 of subpart A, the "Administrator" includes any authorized representative of the Administrator of the Environmental Protection Agency. Authorized representatives are EPA officials in EPA Regional Offices or State, local, and regional governmental officials who have been delegated the responsibility of enforcing regu. ations under 40 CFR 60. These officials in consultation with other staff members familiar with technical aspects I source testing will render decisions regarding acceptable alternate test procedures.

In accordance with section 117 of the Act, publication of these methods was preceded by consultation with appropriate advisory committees, independent experts, and Federal departments and agencies.

(Secs. 111, 114 and 301(a) of the Clean Air Act, sec. 4(a) of Pub. L. No. 91-604, 84 Stat. 1683; sec. 6(a) of Pub. L. No. 91-604, 84 Stat 1687; sec. 2 of Pub. L. No. 90-148, 81 Stat. 504 [42 U.S.C. 18574-6, 1857c-9, 1857g(a)].)

NOTE -The Environmental Protection Agency has determined that this document does not contain a major proposal requiring preparation of an Economic Impact Analysis under Executive Orders 11821 and 11949 and OMB Circular A-107

Dated: August 10, 1977.

DOUGLAS M. COSTLE. Administrator

Part 60 of Chapter I of Title 40 of the Code of Federal Regulations is amended by revising Methods 1 through 8 of Appendix A-Reference Methods follows:

APPENDIX A. REFERENCE METHODS

APPENDIX A. REPERENCE METHODS

The reference methods in this appendix are referred to in § 60.8 (Performance Tests) and § 60.11 (Compliance With Standards and Maintenance Requirements) of 40 CFR Part 60, Subpart A (General Provisions). Specific uses of these reference methods are described in the standards of performance contained in the subparts, beginning with Subpart 1).

Within each standard of performance, a section titled "Test Methods and Procedures" is provided to (1) identify the test methods applicable to the facility subject to the respective standard and (2) identify any special instructions or conditions to be followed when applying a method to the respective facility. Such instructions (for example, establish sampling rates, volumes, or lemperatures) are to be used either in addition to, or as a substitute for procedures in a reference method. Similarly, for sources subject to emission monitoring requirements, specific instructions pertaining to any use of a reference method are provided in the subpart or in Appendix 1. Appendis II

Inclusion of methods in this appendix is not intended as an endorsement or denial of their applicability to sources that are not subject to standards of performance. The methods are potentially applicable to other sources: however, applicability should be continued by careful and appropriate evaluation of the conditions prevalent

The approach followed in the formulation of the ref-The approach followed in the formulation of the re-rence michods involves specifications for equipment, procedures, and performance. In concept, a performance specification approach would be preferable in all methods because this atlows the greatest flexibility to the user. In practice, however, this approach is improactivation most cases because performance specifications cannot be established. Most of the methods described herein, therefore, involve specific equipment specifications and procedures, and only a few methods in this appendix rely in performance criteria.

on performance criteria.

Minor changes in the reference methods should not necessarily affect the validity of the results and it is recognized that alternative and equivalent methods exist. Section 69.8 provides authority for the Administrator to specify or approve (1) equivalent methods, (2) alternative methods, and (3) minor changes in the methodology of the reference methods. It should be clearly understood that unless otherwise identified all such methods and changes must have prior approval of the Administrator. An owner employing such methods or deviations from the reference methods without obtaining prior approval dies so at the risk of subsequent disapproval and reference methods, certain specific souling.

prior approval does so at the risk of subsequent disapproval and retesting with approved methods.

Within the reference methods, certain specific equipment or procedures are recognized as being acceptable or potentially acceptable and are specifically identified in the methods. The items identified as acceptable options may be used without approval but must be identified in the test report. The potentially approvable options are cited as "subject to the approval of the Administrator" or as "or equivalent." Such potentially approvable techniques or alternatives may be used at the discretion of the owner without prior approval. However, detailed descriptions for applying those potentially approvable techniques or alternatives are not provided in the reference methods. Also, the potentially approvable options are not necessarily acceptable in all applications. Therefore, an owner electing to use such potentially approvable techniques or alternatives are in fact applicable and are properly executed; (2) including a written description of the alternative method in the test report (the written method must be clear and must be eapable of heing performed without additional instruction, and the degree of detail should be similar to the detail contained in the reference methods); and (3) providing any rationale or supporting data necessary to show the validity of the alternative in the particular application. Failure to meet these requirements can result in the Administrator's disapproval of the alternative.

METHOD 1-SAMPLE AND VELOCITY TRAVERSES FOR STATIONARY SOURCES

1. Principle and Amplicability

1.1 Principle. To aid in the representative measurement of pollutant emissions and/or total volumetric flow

1.1 Principle, To aid in the representative measurement of pollutant emissions and/or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas.


1.2 Applicability. This method is applicable to flowing gas streams in ducts, stacks, and flues. The method cannot be used when (1) flow is cyclonic or swirting (see Section 2.4), (2) a stack is smaller than about 0.30 meter (12 in.) in diameter, or 0.071 m² (11) in.); in cross-sectional area, or (5) the measurement site is less than two stack or duct diameters downstream or less than a half diameter upstream from a flow disturbance.

The requirements of this method mist be considered before construction of a new facility from which emissions will be measured; failure to do so may require subsequent alterations to the stack or devisition from the standard procedure. Cases involving variants are subject to approval by the Administrator, U.S. Environmental Protection Agency.

2. Therefore

2.1 Selection of Measurement Sits. Sampling or velocity measurement is performed at a site located at least eight stack or duct diameters downstream and two diameters upstream from any flow disturbance such as a bend, expansion, or contraction in the stack, or from a visible flame. If necessary, an alternative location may nestected, at a position at least two stack or duct diameters downstream and a half diameter instream from any flow disturbance. For a feetingular cross section, an equivalent diameter (D_c) shall be calculated from the following equation, to determine the upstream and degree and disturces:

$$D_{\star} = \frac{2 LW}{L+W}$$






Figure 1-1. Minimum number of traverse points for particulate traverses.

where I wiength and it width

2.2 Determining the Number of Traverse Points.

2.2.1 Particulate Traverses. When the right and two-diameter criterion can be met, the missing number of traverse points shall be: 1) twelve, for circular of recta Zuiar stacks with diameters or equivalent diameters greater than 6.6 better 20 m., (2) eight, for circular stacks with diameters between 0.30 and 0.64 meter 42.24 m.). 3 may 6 or fertiampliar stacks with equivalent diameters between 0.30 and 0.64 meter 42.24 m.).

When the eight and two-diameter criterion cannot be used the minimum number of traverse point is determined from Figure 1-1, there referring to the figure, low-ever, determined the meanest questeam and downstream diameter of equivalent of matter by the stack diameter of equivalent of matter the determine from Figure 1-1 the minimum number of traverse points the first position of the number of determine from Figure 1-1 the minimum number of distances from Figure 1-1 the minimum number of duct dealestest spectrum, and (2) to the number of duct dealestest spectrum, and (2) to the number of duct dealestest spectrum, and (2) to the number of duct dealestest spectrum, select the higher of the two minimum minibers of traverse from a greater value, and for feeting third stacks the number is a milliple of 4, shown in Table 1-1.

Tank 1 1 Consectional from the redunisher suchs

	15
Northern Light and Lands	in
	3
	4
Managaran makan makan da 1986 Managaran ber	. ñ
Property many of the party of the All Contracts and	- 5
Contract to the second section of	






Figure 1-2. Minimum number of traverse points for volocity (nonparticulate) traverses.

22.2 Velocity (Non Particulate) Traverses. When relocity or estumetric flow rate is to be determined thus and particulate matter), the same proceedure as that for particulate traverses (Section 2.2.1) is followed, except that Figure 1-2 may be used distend of Figure 1.2.3 Cross-occitonal Layout and Location of Traverse Points.

2.3.1 Circular Stacks. Locate the traverse points on two perpendicular diameters advorting to Tathe 1.2 and the example shown in Figure 1-3. Any equation for examples, see Clustons 2 and 3 in the Bithlography) that gives the same values as those in Table 1.2 may be used in her of Table 1.2.

For particulate traverses, one of the diameters trust be in a plane containing the greatest expected conjectation variation, e.g., after bends, one diameter shall be in the plane of the bend. This requirement becomes less criticals the distance from the distributione increases. Herefore, other diameter locations may be used, solid, cit trapproval of the Administrator.

In addition, for stacks having diameters greater than 0.61 in (24 in.) in traverse points shall be located within 2.5 centimeters (1.00 in.) of the stack walls. An 1 for sine & diameters equal to or less than 0.61 in C1 in., not traverse points fall the located within 1.2 and 0.5 in. of the stack walls. To meet these critical, observe the proceduris given below.

2.3.1.1 Blucks With Diameters Greater Than 0.61 in (24 in.). When any of the traverse points as located in (24 in.). When any of the traverse points are robusted fraverse points in (1.00 in 7, or (2.3 a distance critical to the northernoon of the stack walls, relocate them away from the stack walls to (1.3 distance points as found of the stack walls adjusted traverse points for energy to member of a diameter thall be the "adjusted fraverse points are continued to form a single adjusted traverse points for the adjusted point as two separal fraverse points, from the adjusted point as two separal fraverse points, freat the adjusted fraverse points for morting the data.




Figure 1.3. Example showing circular stack cross section divided into 12 equal areas, with location of traverse points indicated.

Table 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS (Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1,4	1.3	1.1	1.
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.
3		75.0	29.6	19.4	14.5	11.8	9.9	8.5	7.5	6.7	6.0	5.
4		93.3	70.4	32.3	22.5	17.7	14.6	12.5	10.9	9.7	8.7	7.
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.
10			- 1		97.4	88.2	79.9	21.7	61.8	38.8	31.5	27.
11						93.3	85.4	78.0	70.4	61.2	39.3	32.
12						97.9	90.1	83.1	76.4	69.4	60.7	39.
13	- 3						94.3	87.5	81.2	75.0	68.5	60.
14							98.2	91.5	85.4	79.6	73.8	67.
15								95:1	89.1	83.5	78.2	72.
16								98.4	92.5	87.1	82.0	77.
17									95.6	90.3	85.4	80.
18									98.6	93.3	88.4	83.
19					- 1					96.1	91.3	86.
20:										98.7	94.0	89.
21											96.5	92.
22											98.9	94.
23												96.
24		1.50										98.

2.3.1.2 Blacks With Diameters Equal to or Less Than 0.61 m (24 in). Follow the procedure in Section 2.3.1.1, noting only that any "adjusted" points should be relocated away from the stark walls to (1) a distance of 1.3 cm (0.30 in.1, or (2) a distance equal to the nozzle inside diameter, whichever is larger 2.3.2 Rectangular Starks Determine the number of traverse points as explained in Sections 2.1 and 2.7 of this method. From Table 1.1, determine the grid configuration. Divide the stark cross-section into as many equal rectangular elemental areas as traverse points,

and then locate a traverse point at the centroid of each equal area according to the example in Figure 1.4. The situation of traverse points being too close to the stack wally is not expected to arise with rectangular stacks. If this problem should ever arise, the Administrator must be contacted for resolution of the matter 2.4. Verification of Absence of Cyclonic Flow in most stationary sources, the direction of stack gas flow is assentially parallel to the stack walls. However, cyclonic flow may exist (1 after such devices as cyclones and inertial demisters following venturi scrubbers, or

(2) in stacks having tangential inlets or other duct configurations which tend to induce swirling, in these instances, the presence or absence of cyclonic flow at the sampling location must be determined. The following techniques are acceptable for this determination.




Figure 1.4. Example showing rectangular stack cross section divided into 12 equal areas, with a traverse point at centroid of each area.

Level and zero the manometer. Connect a Type 8 pitot tube to the manometer. Position the Type 8 pitot tube at each traverse point, in succession, so that the planes of the face openings of the pitot tube are perpendicular to the since cross-sectional plane; when the Type 8 pitot tube is in this position, it is at "0" reference." Note the differential prosture (2p) reading at each traverse point. If a null (zero) pitot reading is obtained at 0" reference at a given traverse point, an acceptable flow condition crists at that point. If the pitot reading is not zero at 0" reference, rotate the pitot tube (up to ±30" yaw sayle), until an ull reading isobtained Carefully determine and record the value of the rotation angle (a) to the nearest degree. After the unit technique has been applied at each traverse point, educible the average of the absolute values of c assign a values of 0" to those points for which no rotation was required, and include these in the overall severall flow condition in the stack is unacceptable and alternative methodology, subject to the approval of the Administrator, thus be used to perform accurred sample and websity traverses.

3. Itudiography

3. Itoliography

1 Determining Dust Concentration in a Gos Stream. ASME. Performance Test Code No. 27, New York.

ASME. Performance Test Code No. 27. New York. 1957.

2. Devorkin, Howard, et al. Air Pollution Source Testing Manual Air Pollution Control District. Los Angeles, CA. November 1963.

3. Methods for Determination of Velocity, Volume, Dust and Mist Control of Close, Western Precipitation Division of Joy Manufacturing Co. Los Angeles, CA. Builden Mr. 50, 1968.

4. Standard Method for Sampling Stacks for Particulate Matter. In: 1971 Book of AcTM Standards, Part 23.

ASTM Designation D-2928-71. Philadelphia, Pa. 1971.

5. Hanson, H. A., et al. Particulate Sampling Strategies of Large Power Plants Including Nonminiform Flow. USEPA. ORD, ESRL, Research Triangle Park, N.C. EPA-6892-76-170. June 1978.

5. Entropy Environmentalists, Inc. Determination of the Optimum Number of Sampling Points: An Analysis of Method I Criteria. Environmental Protection Agency. Research Triangle Park, N.C. EPA Contract No. 68-01-3172, Task 7.

METHOD 2- DETERMINATION OF STACE CLAS VELOCITY AND VOLUMETRIC FLOW RATE (TYPE S PITOT TURE)

1. Principle and Applicability

1. Principle and Applicability

1.1 Principle. The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity bread with a Type S (Statisscheibe or reverse type) pitot title.

1.2 Applicability. This method is applicable for measurement of the average velocity of a gas stream and for quantifying as flow.

This procedure is not applicable at measurement sites which fail to meet the criteria of Method 1, Section 2.1. Also, the method cannot be used for direct measurement in evolution or swirling gas streams; Section 2.4 of Method 1 shows how to determine evolution or swirling flow conditions. When unacceptable conditions exist, alternative procedures, subject to the approval of the Administrator, U.S. Environmental Troteenian Agency, must be employed to make accurate flow rate determinations; examples of such alternative procedures are: (1) to install straightening vanues, (2) to calculate the total submetro flow nite simehometrically, or (3) to move to another measurement site at which the flow is acceptable.

2 Apparatus

Specifications for the apparatus are given below. Any other apparatus that has been demonstrated (subject to approval of the Administrator) to be capable of meeting the specifications will be considered acceptable.






Figure 2-1. Type S pitot tube manometer assembly.

21 Type 8 Pitot Tube. The Type 8 pitot tube (Figure 2-1) shall be made of metal tubing (e.g., stampless steel). It is recommended that the external tubing diameter (dimension D., Figure 2-2b) be between 648 and 0.95 centimeters (948 and 4, inch.). There shall be an equal distance from the base of each leg of the pitot tute to its face opening plane (dimensions F₃ and F₃. Figure 2-2b), it is recommended that this distance be between 1.65 and 1.30 times the external tubing diameter. The face openings of the pitot tube shall, preferably, be aligned as shown in Figure 2-2; however, sight mesalignements of the openings are permissible (see Figure 2-3). The Type 8 pitot tube shall have a known coefficient, determined as outlined in Section 4. An identification number shall be assigned to the pitot tube this number shall be assigned to the pitot tube this number shall be permanently marked or engraved on the loody of the tube.








Figure 2-2. Properly constructed Type S pitot tube, shown in: (a) end view; face opening planes perpendicular to transverse axis; (b) top view; face opening planes parallel to longitudinal axis; (c) side view; both legs of equal length and centerlines coincident, when viewed from both sides. Baseline coefficient values of 0.84 may be assigned to pitot tubes constructed this way.




Figure 2-3. Types of face-opening misalignment that can result from field use or improper construction of Type S pitot tubes. These will not affect the baseline value of $\overline{Cp}(s)$ so long as a1 and a2 < 10°, β_1 and β_2 < 5°, z < 0.32 cm (1/8 in.) and w < 0.08 cm (1/32 in.) (citation 11 in Section 6).

A standard plint tube may be used justeed of a Type R footided that it meets the specifications of Sections 2.7 and 4.2 note, however, that the static and impact resource holes of standard print tubes are susceptible to

ind 4.2, note, however, that the static and injunct account bales of standard jutof times are susceptible to plusting in particulated adon was stronger. Therefore, whenever a standard pitof time is used in perform a traverse, adequate proof must be furnished that the appendix of the pitof time have not plusting a volocity that the pitof time have not plusting a volocity bead λΔμ reading at the four livarees period, thus can be those by taking a volocity the allowed and static below of the standard pitof time have not plusting out the inquict and static below of the standard pitof time have the inquict and static below of the standard pitof time have and after the air purpose at the single 1 discount of the inquict and static below of the standard pitof that years all the final traverse point is meantably have another point in the final traverse point is meantably have another point in the final traverse point is meantably have another point into the latter that the proceeding, then comparative appearing shall be inknown as have, for the heat we have have a present another and pitof the proceeding the comparative appearing shall be inknown as have, for the heat we have a purpose at which small proceeding the comparative appearing shall be inknown as have, for the heat we have a purpose at which small proceeding the comparative appearing shall be inknown as insolved edition in sometical exception in another device is used. All of sampling translate entitled another have the purpose of the sampling translate entitled another have been proceeded as the sampling translate entitled another have been proceeded as the sampling translate and the proceeding the sampling translate and the sampling translate and the proceeding and the sampling translate and the proceeding the sampling translate and the process of the sampling translate to the supervey of the sampling translation of the individual Ap readings at lower than 12 points, more than one Ar conding is below 1.3 min in the intermediation for the measurement of low

velocities

As an afternative in criteria (i) through (i) above, the following externation may be perfected before the the peressity of using a more sensitive differential pressure. # Miles

$$T = \frac{\sum_{i=1}^{n} \sqrt{\Delta p_i + K}}{\sum_{i=1}^{n} \sqrt{\Delta p_i}}$$

ere:

pp. Individual velocity head reading at a fracerse
point, min figure. II.00:

A = Total number of traverse points.

A = 0.13 unit 110 when metric units are used and

0.002 in (12) when English units are used.

A =0.13 sum 140 when metric units are used and 0.00 in 140 when English units are used.

If I is greater than 1.05, the velocity head data are unacceptal is and a more sensitive differential pressure gains must be used.

Note, self-differential pressure gains exister than he had named manuscriets are used to g., manuscrib the gains of the manuscript of the gains with those of a gainst annual relations of a differential pressure gainst compare Ap readours of the gains with those of a gainst conjugate annual relations of a differential pressure gainst compare Ap readours of the gainst with those of a gainst conjugate annually represent the story of Ap a read to the differential pressure gainst had been added to the conjugate for some gainst some the story.

I at read permittive varies of Ap as read to the differential pressure gainst availed and pressure gainst some few some short some present to the approach of the conjugate of the conjugate of the procedure of the present of the subject to the approach of the filed built the measure of the Administrator.

2.1 Temperature to some A therefore a table builting the gain that the manuscript is the production of the plant that the sense of the filed built the measure of the production of the plant that the sense to do the internal positions that the sense to the plant that the sense to the plant that the present to the plant that the sense to the plant that the operation of the little that the present to the plant that the expectation of the plant that the present of the plant that the expectation of the plant that the present of the plant that the present to the plant that the expectation of the plant that the present that the present to the plant that the expectation of the plant that the present to the plant that the expectation of the plant that the present to the plant that the expectation of the plant that the present to the plant that the expectation of the plant that the present to the plant that the expectation of the plant that the present that the plant th

RULES AND REGULATIONS

perature range need not be attached to the pitot tube, this alternative is subject to the approval of the

Pressure Profes and Plance, A therometer tube and

Admiredition.

2.4 Pressure Proband Flaure. A pictometer tube and merinity of water filled U tille mannamer capable of meritary of water filled U tille mannamer capable of meritary of water filled U tille mannamer capable of meritary of water filled U tille. Mannamer capable of meritary of a Type X timul tille with the fore opening planes positioned marifed in the gas flow may also be filled at the re-source period.

2.5 Harmoster, A merenty, amerold, or other barometer apable of measuring atmospheric pressure to within 2.5 mm fly flo.1 in. High may be used. In many cases, the barometer reading dray be obtained from a megrey authorized and her probable barometric freedom of the state of the respected and an adjustment for electric state distributed and an adjustment for electric state of the respected and an adjustment fareface shall be requested and an adjustment fareface and her planes between the weather shallon and the say plane point shall be approved at a rate of minus 2.5 mm (0.1 in.) Higher respected and an electronic fareface and in a fill in.) Higher forms the weather shallon and the say plane point shall be approved at a rate of minus 2.5 mm (0.1 in.) Higher forms do not rease.

2.5 thus finestly Determination fragments. Method Argunderent, if needed fore Section 3.6, to determine the very gas try molecular weight, and Reference Method & equipment for missing content determination, ether methods may be used subject to hipproval of the Administrator.

2.7 Californion Fitter Tube. When californion of the Type 5 pited time is med as a reference. The standard point tube small, professible, have a known coefficient, obtained either 1, directly from the National Road, Gaithersburg.

Maryland, or (2) by calibration against another standard pitot time with an Nile-traceable coefficient. Alternatively, a standard pitot time designed according to trated in Figure 2.4 decreases to clustoms 2.5, below and time feeting to may be used to these spectreations will have baseline surface to the superior about 0.9 and 0.0 a

inisphetical (shown in Figure 2.4), all possibil,

2.7.1 Hemispherical shown in Facility or oncell tip.
2.7.2 A minimum of six diameters of taken to the case of the min of the external diameters of the taken between the tip and the states pressure bules.
2.7.3 A r on m of width diameters straight from between the state; ressure bules and the recutorier of the external title, for whigh the 90 decree band 2.7.4 Value pressure who dequalities improvementally 0.1 fb. equally spaces to a decomplete ring contractation.
2.7.5 Value pressure is decomplete ring contractation.
2.7.5 Value pressure is decomplete ring contractation.

0.1 De emails spacent la parameter ring configuration, 27.5 Simils degree bend, with curved or mittered function.

2.8 Differential Pressure Gauge for Type S. Pitot Tube Configuration. An inclined manage for or equivalent is used. If the single-velocity cultivation technique is embloyed one Section A.1.2 to the cultivation distribution inflorences in pressure gauge shall be readable to the marries 0.13 mm H₂O 0.000 m. H₂O₁. For most isolocity cultivations, the gauge shall be readable to the nearest 0.13 mm H₂O 0.00 m H₂O₂ for Δp values between 1.3 mm H₂O 0.00 m H₂O₂ for Δp values between 1.3 mm H₂O 0.00 m H₂O₃ for Δp values above 25 mm H₂O 0.00 h. H₂O₃ for Δp values the search will be regulated to read Δp values below 1.3 mm H₂O 0.00 in H₂O₃ for the regulated to read Δp values below 1.3 mm H₂O 0.00 in H₂O₃ for the regulated to read Δp values below 1.3 mm H₂O 0.00 in H₂O₃ for the regulated to read Δp values below 1.3 mm H₂O 0.00 in H₂O₃ for the regulated to read Δp values below 1.3 mm H₂O 0.00 in H₂O₃ for the regulated to read Δp values below 1.3 mm H₂O 0.00 in H₂O₃ for the regulated to read Δp values below 1.3 mm H₂O 0.00 in H₂O₃ for the regulated to the results of the regulated to the regulated to the results of the regulated to the re




Figure 2.4. Standard pitot tube design specifications.

3. Thursday

2. Trace or found the higher than we would be France T. A. Capillage, solven of secret backs usually I because the members and pure take near to use that capen the foreign to a large members of the reported that a prevent cake force be surfaced as a finish take force be surfaced as with at least 7.6 cm (100 mm), the point impact operate with at least 7.6 cm (100 mm) to prevent specific products outline measurement (100 mm). The presence shall remain the star before the surface of the manner of the star prevent such except using suction to obtain the mix man of 7.6 cm (2 mm). Her force that check prevents on the star of the star of the star of the mix man of the star of

tometer level and rore man drift due to entrations and functione almost a subsection of the country of the coun

PLANT					
DATE	100 200				
STACK DIAMETER OF					
BAROMETRIC PRESSI					
CROSS SECTIONAL A					
OPERATORS					
PITOT TUBE I.D. NO.					
AVG. COEFFICIEN					
LAST DATE CALIBI	SCHEMATIC OF STACK CROSS SECTION				
Traverse Vo	el. Hd., Δp	Stack Ten	nperature	Pg mm Hg (in.Hg)	√∆p
The second secon	n (in.) H ₂ 0	ts, oc (of)	Ts, OK (OR)		
					And Street White Advantage of Concession
					-
	-				
	THE PARTY OF THE P			-	
		1			
				-	
	***************************************			-	
			-		
		Average			

Figure 2-5. Velocity traverse data.

5.5 Determine the ctark cas dry molecular weight. The Determine the stack ras dry molecular weight. For combustion processes or processes that emit assertially (0. 0. C. C. and No law Method 3. For processes emitting essentially air, an analysis need not be conducted use a dry momental weight of 200. For other termesses other methods, subsect to the approval of the light of the misture consent from Reference it are equivalent or from Method 5.

Determine the prospectional area of the stack does at the emitting bration. Whenever possible, I youthly meaning the stack dimensions rather than lasting brusprints.

4 Objection

All Type 8 Plus Tube Before its initial use, warefully examine the Type 8 pilot tube in kon, side, and at a views to serrly test the face openings of the title Area of ed within the steel in titles illustrated in Figure 1-2 w 1-3. The crust title shall not be used if it fails to meet these at attract specifications. After excitain the face opening alignment, measure sted fecors the face step day one on it the pilot tube.

(a) the external tubing diameter (dimension D_A , Figure 2-2b); and (b) the base-to-oponing plane distances (dimensions P_A and P_A . Figure 2-2b). If D_t is between 6-48 and 0-36 cm (44 and 4_2 in.) and if P_A and P_A are equal and between 10 and 1-30 R_t , there are two possible options. (1) the putof tube may be calibrated according to the procedure outlined in Sections 4.12 through 4.15 below, or (2) a baseline (seeinted tube) roofficient value of 0.84 may be assigned to the pitof tube. Note, however, that if the putof tube is part of an assamily, calibration may still be required, despite knowledge of the baseline coefficient value (see fection 4.1). If P_B , P_A , and P_B are outside the specified limits, the pitof tube must be calibrated as outlined in 4.12 through 4.13 telow.


nito tube must be calibrated as outlined in 4.1.2 through 4.1.3 below.

4.1.4 Type 8 Pitot Tube Assemblies. During sample and velocity traverses, the isolated Type 8 pitot tube is not siways used; in many instances, the pitot tube is used in combination with other source-sampling components thermocouple, sampling probe, nozzle) as part of an "assembly." The pressure of other sampling components can a similar affect the baseline value of the Type 8 pitot tube coefficient (Citatina in Section 6), therefore an assigned (or otherwise known) baseline coefficient

value may or may not be valid for a given assembly. The baseline and assembly coefficient values will be identical only when the relative piacement of the companents in the assembly is such that aerodynamic interference effects are eliminated. Figures 2-6 through 2-8 diffusions interference-free component arrangements for Type spiriot tubes having external tubing dramaters between 0-48 and 0-35 cm 3-18 and 18 an.) Type 8 pitot tube assemblies that full to meet any or all of the specifications of Figures 2-6 through 2-8 shall be calibrated according to the procedure outlined in Sections 4.1.2 through 4.1.5 below, and prior to calibration, be values of the intercomponent spacings (pitot-nozzle, pitot-thermocomple, pitot-pobe sheath) shall be measured and recorded. Norg.—Do not use any Type 8 pitot tube assembly

Norz.—Do not use any Type 8 pitot tube assembly which is constructed such that the impact pressure opening plane of the pitot tube is below the entry plane of the norzie (see Figure 2-6b).

4.1.2 Calibration Setup. If the Type 8 pitot tube is to e calibrated, one lag of the tube shall be permanently marked A, and the other, & Calibration shall be done in a flow system having the following essential design features



A. BOTTOM VIEW; SHOWING MINIMUM PITOT-NOZZLE SEPARATION.




Figure 2-6. Proper pitot tube - sampling nozzle configuration to prevent aerodynamic interference; buttonhook - type nozzle; centers of nozzle and pitot opening aligned; Dt between 0.48 and 0.95 cm (3/16 and 3/8 in.).




Figure 2-7. Proper thermocouple placement to prevent interference; Dt between 0.48 and 0.95 cm (3/16 and 3/8 in.).




Figure 2-8. Minimum pitot-sample probe separation needed to prevent interference; Dt between 0.48 and 0.95 cm (3/16 and 3/8 in.).

4.1.2.1 The flowing gas stream must be confined to a duct of definite cross-sectional area, either circular or rectangular. For circular cross-sections, the minimum duct diameter shall be 30.5 cm (12 in 1) for rectangular cross-sections, the width inhorter side; shall be at least \$4.5 cm (10 in).

25.4 cm (10 ln):
4.1.2.2 The cross-sectional area of the calibration duct 4.1.2. The cross-sectional area of the calibration duct must be constant over a distance of 10 or more duct diameter. For a rectanguise cross-section, use an equivalent diameter, calculated from the following equation, to determine the minister of duct diameters:

$$D_i = \frac{2|L|W|}{(|L+|W|)}$$

Equation 2-1

 $\begin{aligned} &\textbf{w}_{loc}(e) \\ & D_{s} = \textbf{F}_{loc}(u, u) \\ & L = \textbf{F}_{s}(u, u) \\ & \textbf{H} = \textbf{W}(d), \textbf{h} \end{aligned}$

To ensure the presence of static finity descined flow patterns at the calibration site, or "test section," the site must be located at least eight diameters downstream and two diameters upstream from the negreet distorti-

Note.—The eight and two-diameter criteria are not absolute; other test section locations may be used outject to approval of the Administrator), provided that the flow at the test site is stable and demonstrably parallel to the duct axis.

41.2.3 The flow system shall have the capacity to presente a test section velocity around 915 m min (3.000)

friming. This velocity must be constant with time to guarantee steady flow during calibration. Note that Type 8 pitot tube coefficients obtained by single-relocity calibration at 915 m/min (3,000 fr/min) and to will generally be valid to within ±3 percent for the necessariement of velocities between 180 and 350 m/min is 3,000 fr/min). If a more precise correlation between 180 and 350 m/min; seed and 1,000 fr/min). If a more precise correlation between 180 for first in the expansity is generate at least four distinct, time-intra-nut rest-cention velocities covering the wide fir mine fixed to 5,000 fr/min), and calibration data shall le taken at regular velocity intervals over this range (see Cristianos 9 and 14 in Section 6 for details).

4.1.2.4 Two entry ports, one each for the clandard and Type 8 pitot tubes, shall be cut in the test section the standard putot entry pert shall be located sharing downstream of the Type 8 port, so that the similar downstream of the Type 8 port, so that the similar and Type 8 mineral openings will be in the same cross-sectional plane during cabination. To faciliate alignment of the print three during cabination, it is advantle that the test section be considered. Note that this proceeding the agencia one and must not be used without first referring to the viscoul considerations presented in Section 3.1.5. Note also that the procedure applies only to single-velocity withtenton. To obtain calibration data for the A and B adder of the Type 8 pitot tube, proceed

for the A kin is note of the replace proceeding, proceedings follows:

4.13.1 Make rure that the manufactor is properly filled and that the all is free from contamination and is of the proper density. Inspect and look often k all providing tepart or replace of necessary.

\$1.52 Level and soro the manumeter. Turn on the fan and allow the flow to stabilize. Scalibe Type Sentry

A 1.3.2 Level and toro the manometer. Turn on the fan and allow the flow to stabilize. Scatthe Type S entry port.

4.1.3.3 Frome that the manometer is level and toroed. Position the simulard pilot time at the calibration point determined as contined in School 4.1.5.1, and align the tube so that us top is pointed directly into the flow. Purchase the stable of the flow that the entry port automate are should be taken in aligning the tube the avoid yaw and pilot angles. Make sure that the entry port automated in the one shown in Figure 2-9. Remove the simular to the one shown in Figure 2-9. Remove the simular of the one shown in Figure 2-9. Remove the simular of one shown in Figure 2-9. Remove the simular of into tube from the duct and deconnect it from the manometer. Seat the standard entry port.

4.1.3.4 Connect the Type 8 pinot tube to the manometer level and stor. Insert and align the Type 8 pinot tube so that its A side impact opening is at the same point as was the standard into tube and spointed directly into tube its walled to the time that the calify port surrounding the tube is projectly scaled.

4.1.3.6 Read 5/p and enter its value in the defa table. Remove the Type 8 pilot tube from the duct and disconnect it from the reasonment.

4.1.3.7 Repeat steps 4.1.3.3 through 4.1.3.7 above for the B side of the Type 8 pilot tube.

4.1.3.8 Repeat steps 4.1.3.3 through 4.1.3.7 above for the B side of the Type 8 pilot tube.

4.1.3.9 Perform calculations, as described in Section 4.1.4 helow.

4.1.4.1 For each of the six pairs of 5p readings (i.e., three from side A and three from side B) obtained.

TOT TUBE IDENTIFICATION NUMBER:	37AC
LIBRATED BY:	The state of the s

	"A" SI	"A" SIDE CALIBRATION				
RUN NO.	△ Pstd em H20 (in. H20)	Δp(s) em H20 (in. H20)	C _{p(s)}	DEVIATION Cp(s) - Cp(A)		
1						
2						
3						
		Cp (SIDE A)				

	"B" SID	E CALIBRATIO	N	
RUNNO.	Δ p ₅₁ d cm H ₂ O (in. H ₂ O)	Δ p(s) cm H ₂ O (in. H ₂ O)	Cp(s)	DEVIATION $C_{p(s)} \cdot \overline{C}_{p}(B)$
1				
2	A STATE OF THE STA			
3				
		Cp (SIDE B)		

AVERAGE DEVIATION =
$$\sigma$$
 (A OR B) = $\frac{\frac{3}{\Sigma} \left[C_p(s) \cdot \overline{C}_p(A \text{ OR B}) \right]}{3}$ \longrightarrow MUST $\varepsilon \varepsilon < 0.01$

| To (SIDE A) - To (SIDE B) | - MUST BE < 0.01

Figure 2.9. Pitot tube calibration data.

$$C_{x^{(s)}} = C_{x^{(s)}\text{d}} \ \sqrt{\frac{\Delta p_{s^{(s)}}}{\Delta p_{s}}}$$

Equation 2-2

 $C_{\Psi(s)}$ = Type S pilot tube coefficient

Colord) = Standard pitot tube coefficient; use 0.90 if the coefficient is unknown and the tube is designed

according to the criteria of Sections 2.7.1 to 2.7.5 of this method. $\Delta p_{r,s} = \text{Velocity head measured by the stendard pitot tribe, cm <math>H_2O$ (in H_2O). $\Delta p_{r,s} = \text{Velocity head measured by the Type S pitot tribe, cm <math>H_2O$ (in H_2O). $4.142 \quad \text{Calculate C}, \text{ (side A), the mean A-side coefficient, and C_r (side B), the mean B-side coefficient calculate the difference between these two average values.$

4.1.4.3 Calculate the deviation of each of the three Aside values of $C_{\pi(s)}$ from \widetilde{C}_{π} (side A), and the deviation of each B side value of C, in from C, (side B). Use the following equation:

Deviation =
$$C_{\mathbf{r},\mathbf{r}} - \overline{C}_{\mathbf{r}}(\Lambda \text{ or } \mathbf{B})$$

Equation 2 3

4.1.4.4 Calculate σ, the average deviation from the mean, for both the A and B sides of the pitot time. Use the following equation:

$$\sigma \text{ (side A or B)} = \frac{\sum_{1}^{3} |C_{r(s)} - \overline{C}_{r}(A \text{ or } B)|}{3}$$

Equation 2-4

4.1.4.5 Use the Type S pitot tube only if the values of * (side A) and * (side B) are less than or equal to 0.01 and if the absolute value of the difference between \overline{C}_{σ} (A) and \widetilde{C}_{\bullet} (B) is 0.01 or less.

4.1.5 Special considerations.

4.1.5.1 Selection of calibration point.

4.1.5.1.1 Selection of calibration point.
4.1.5.1.1 When an isolated Type 8 pitot tube is calibrated, select a calibration point at it near the center of the duct, and follow the procedures outlined in sections 4.1.3 and 4.1.4 above. The Type 8 pitot coefficients so obtained, i.e., C_i, (side A) and C_i (side II), will be valid, so long as either, (I) the isolated pitot tube is used, of (2) the pitot tube is used with other components morrie, thermocouride, sample propel in an artangement that is free from acrostynamic interference effects (see Figure 2.4 through 2.8).

2.6 through 2.8.

4.1.5.1.2 For Type S pirot tribe thermocourie same brantons twithout sample project select a sone ration near tot or near the center of the chief, and follow the procedures outlined in Sections 4.1.3 am. 1.1.4 above The co-tholents in administration of the collection of the arrangement (Figures 2-e and 2-s).

or with allow componentism as interleption for a strange-ment (Figures 2-a and 2-a).

4.5.1.3. For assemblies with sample probes, the cultration point should be beauted at or near the center of the due; however, insortion of a probe sheath into a small due; near cames significant cross-sectionia area be-kage and volul morrow coefficient values in that no a because it is not because the look age effect, the calibration point may be a few inches off-center if necessary. The actual there are effect will be negligible when the theoretical blockage, as determined by a projected area model of the probe should, be 2 percent or less of the duet cross-sectional area for assumblies without external sheaths (Figure 2-15a), and 3 percent or less for assemblies with external sheates (Figure 2-10b).

4.5.2. For those probe assemblies in which pitol tube-nozife interference is a factor i.e., there in which the pitol nozid separation distance falls to meet the specification illustrated in Figure 2-6a), the value of Carry depends upon the amount of free-space between the tithe and morels, and therefore is a function of nozide size. In these instances, separate calibrations shall be performed with each of the commonly used nozife sizes in place. Note that the single-velocity guildration tech-nique is acceptable for this purpose, even though the larger nozife sizes (>0.635 cm or 1, in 1 are not ordinarily used for isokopete sampling at velocities around 915 norms (100 Gramm), which is the calibration to charm the problem of the pitol title needs as the ordinarily time of the pitol title need by calibration, only one side of the pitol title need by calibration for the side which will face the flow). The pitol title must still meet the gligmment specifications of Figure 2-or 2-3, however, and must have an average deviation (e) value of 0.01 or

the alignment specifications of Facure 2 2 or 2 3, however, and must have an average deviation (a) value of 0.01 or less (see Section 4.1.4.4).




Figure 2-10. Projected area models for typical pitot tube assemblies.

4.1.6.1 Field Use and Recalibration.
4.1.6.1 Field Use.
4.1.6.1.1 When a Type 8 pitot tube disolated tube or assembly) is used in the field, the appropriate coefficient value (whether assigned or obtained by calibration is shall be used to perform velocity calculations. For calibrated Type 8 pitot tubes, the A side coefficient shall be used when the A side of the tube faces the flow, and the B side coefficient shall be used when the B side faces the flow; alternatively, the arithmetic average of the A and B side coefficient values may be used, irrespective of which side faces the flow.
4.1.6.1.2 When a probe assembly is used to sample a small dust (12 to 36 in. in diameter), the probe sheath sometimes blocks a significant part of the dust cross-section, calibring a reduction in the effective value of \$\overline{C}_F(a)\$. Consult Citation 9 in Section 6 for details. Con-

Consult Citation 9 in Section 6 for details. Conventional pitot-sampling probe assemblies are not secommended for use in ducts having inside diameters smaller than 12 inches (Citation 16 in Section 6).

4.1.6.2 Recalibration.

emailer than 12 inches (Citation 16 in Section 6).

4.16.2.1 Isolated Pitot Tubes After each field use, the pitot tube shall be carefully recambled in top, side, and end views. If the pitot face openings are still aligned within the specifications illustrated in Figure 2-2 or 2.3, it can be assumed that the baseline coefficient of the pitot tube has not changed. If, however, the tube has been damaged to the extent that it no longer meets the specifications of Figure 2 or 2.3, the damage shall either the repaired to restore proper slignment of the face openings or the tube shall be discarded.

4.16.2.2 Fitot Tube A seemblies. After each field use, eheck the face opening alignment of the pitot tube, as in Section 4.1.6.2.1 also, remeasure the intercomponent spacings of the assembly. If the intercomponent spacings have not changed and the face opening alignment is acceptable, it can be assumed that the coefficient of the assembly has not changed. If the face opening alignment is no longer within the specifications of Figures 2-2 or 2-3, either repair tile damage or replace the pitot tube leadington or recalibrate the assembly. If necessary). If the intercomponent spacings have changed, restore the original spacings or recalibrate the assembly.

4.2 Standard pitot tube (if applicable). If a standard pitot tube is used for the velocity traverse, the tube shall be constructed according to the criteria of Section 2.7 and shall be assumed a baseline coefficient value of 0.90 if the standard pitot tube is used as part of an assembly,

the tube shall be in an interference-free arrangement (subject to the approval of the Administrator).

4.3 Temperature Gauges. After each field use, calibrate dial thermometers, liquid-filled built thermometers, liquid-filled built thermometers, and other the filling of the f (subject to the approval of the Administrator).

4.3 Temperature Gauges. After each field use, calibrate dail thermometers, liquid-filled built thermometers, thermocoupie-potentionieter systems, and other gauges at a temperature a thin the percent of the average absolute stack temperature. For temperatures up to 405° C (751° F), use an ASTM mercury-in-glass reference thermometer, or equivalent, as reference, alternatively, either a reference thermocouple and potentiometer (calibrated by NHS) or thermometric fixed points, e.g., ioo bath and boiling water corrected for harometric pressure) may be used. For temperatures above 405° C (761° F), use an NHS-calibrated reference thermocouple-potentiometer system or an alternate reference, subject to the approval of the Administrator.

If, during calibration, the absolute temperatures measures.

If, during calibration, the absolute temperatures measured with the gauge being calibrated and the reference gauge agree within 1.5 percent, the temperature data taken in the field shall be considered valid. Otherwise, the pollutant emission test shall either be considered invalid or adjustments of appropriate) of the test results shall be made, subject to the approval of the Administrator.

4.4 Barometer. Calibrate the barometer used against a mercury barometer

Carry out raiculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

5.1 Nomenclature

A = Cross-sectional area of stack, mt (fst).

Bee Water vapor in the gas stream (from Method 5 or Reference Method 4), proportion by volume C. Pitat take coefficient, dimensionless.

K. = Pitot tube constant

$$34.97 \; \frac{\mathrm{m}}{\mathrm{sec}} \left[\frac{(g/g\mathrm{-mole}) \left(\; \mathrm{mm} \; \mathrm{Hg} \right)}{\left(\; {}^{\circ}\mathrm{K} \right) \left(\; \mathrm{mm} \; \mathrm{H}_{2}\mathrm{O} \right)} \right]^{1.4}$$

for the metric system and

$$85.49 \; \frac{\mathrm{ft}}{\mathrm{sec}} \left[\frac{(\mathrm{Ib}\Pi\mathrm{b\text{-}mole})(\mathrm{in}, \mathrm{Hg})}{({}^{\circ}\mathrm{R})(\mathrm{in}, \mathrm{Hg}\mathrm{O})} \right]^{\mathrm{tot}}$$

= Md (1-Bas)+18.0 Bas Equation 2-5

 P_{bs} . Barometric pressure at measurement site, mm Hg (in. Hg). P_s =Stack static pressure, mm Hg (in. Hg). P_s =Absolute stack gas pressure, mm Hg (in. Hg).

 $=P_{bar}+P_{t}$ Equation 2-6 Part = Standard absolute pressure, 760 mm Hg (29.92

in. Hg).

Q.e = Dry volumetric stack gas flow rate corrected to standard conditions, deemfar (dsaffar).

I. Stack temperature, "C (*F).

T. = Absolute stack temperature, *K (*R).

=273+1, for metric

Equation 2-7

Equation 2-10

=460+t, for English

Equation 2-8

Total = Standard absolute temperature, 293 °K (528° R)

 ε_* = A verage stack gas relocity, m/sec (R/sec). $\Delta \mu$ = Velocity head of stack gas, mm H₂O (m. H₂O). 600 = Conversion factor, sec ht. 8.0 = Molecular weight of water, g/g-mole (lb-lb-

5.2 Average stack gas velocity.

$$\begin{split} \mathbf{r}_{\star} &= K_{\nu} C_{\nu} (\sqrt{\Delta p})_{\star \star \star} \sqrt{\frac{T_{\star (\mathtt{avg})}}{P_{\star} M_{\star}}} \\ &\qquad \qquad \text{Equation 2-9} \end{split}$$

5.3 Average stack gas dry volumetric flow rate.

$$Q_{st} = 3,600(1 - B_{ws})v_s A\left(\frac{T_{sad}}{T_{s(avg)}}\right)\left(\frac{P_s}{P_{sad}}\right)$$

6. Hillingraphy
1. Mark, L. S. Mechanical Engineers' Handbook, New York, McGraw-Hill Book Co., Inc. 1951.
2. Perry, J. H. Chemical Engineers' Handbook, New York, McGraw-Hill Book Co., Inc. 1960.

3 Shigebara, R. T., W. F. Todd, and W. S. Smith, Significance of Errors in Stack Sampling Measurements, U.S. Environmental Protection Agency, Research Triangle Park, N.C. (Presented at the Aurusal Meating of the Air Pollution Centrol Association, St. Louis, Mc, June 14-19, 1970.)

4. Standard Method for Sampling St. & Sor Particulate Matter, In. 1971. Book of ASTM Searchards, Part 23, Philadelphia, Pa. 1971. ASTM Designation D. 2128-71, 5. Venuard, J. K. Flementary Flurd Mechanics, New York, John Wiley and Sons, Inc. 1937.

6. Fluid Meters—Their Theory and Application, American Society of Mechanical Engineers, New York, N.Y. 1952.

7. ASHUAE Handbook of Fundame et als. 1972, p. 208.

Y. 1992.
 A. SHURAE, Handbook of Fundame dals, 1972. p. 208.
 Anouni Book of ASTM Standards. Part 28, 1974. p.

American Society of Mechanical Rogenests, New York, N. Y. 1999.

7. ASHERAE Handbook of Fundamentals, 1972, p. 208.

8. Anomal Book of ASIM Standards, Part 25, 1974, p. 618.

9. Vollato, R. F. Guidelines for T. pe R. Pitot Tube Calibration, U.S. Environmental F. Jection Agency, Research Trangle Park, N.C., Present, Earl 14 Anomal Meeting, Source Evaluation Society Duyton, Comp. Separabet 18, 1975.

10. Vollato, R. F. A Type S. Pitot Tube Calibration Study U.S. Environmental Protect, a Agency, Emission Measurement Branch, Research Triangle Park, N.C. July 1974.

11. Vollato, R. F. The Effects of Impact Opening Misalignment on the Value of the Type S. Pitot Tube Calibration of Measurement Branch, Research Triangle Park, N.C. Jeriolect 1976.

12. Vollato, R. F. Establishment of a Bandom Coefficient Value for Properly Constituted Type S. Calibration J. Properly Constituted Type S. Calibration J. Properly Constituted Type S. Calibration December 1976.

13. Vollato, R. F. An Evaluation of Shiele Volocity Calibration Techniques as a Means of Shiele Volocity Calibration Techniques as a Means of Determining Type S. Pino Tubes of Englishments 1975.

14. Vollato, R. F. The Calibration of Shiele Volocity Calibration Techniques as a Means of Determining Type S. Pino Tubes of However, Emission Measurement of Low Velocities Calibration Techniques as Means of Determining Type S. Pino Tubes of However, Emission Measurement of Low Velocities Calibration Techniques and Measurement of Low Velocities Calibration of Province Calibration Techniques and Measurement of Low Velocities Calibration of Province Calibration Techniques and Measurement of Low Velocities Calibration of The Science Sampling Park No. No. No. 1998.

16. Vollato K. F. Recommended Provedure for Sample Triversors in December 1976.

17. Ower F. Land R. C. Pankhuren The Measurement of Air Flow 4th Ed. London, Persamon Press, 1985.

18. Vollato K. F. A Survey of Colonatrially Available Institute of Low Velocities Calibration Provision Agency Emission Measurement Branch

Probes. Prepared by the University of Windsor for the Ministry of the Environment, Toronto, Canada, Februnty 1975.

METHOD S. GAS ANALYSIS FOR CARBON DIOXIDE, OXYGEN, EXCESS AIR, AND DRY MOLECULAR WEIGHT

1. Principle and Applicability

1. Principle and Applicability

1.1 Principle A gas sample is extracted from a stack, for one of the following methods: (1) single-point, grab sampling; (2) single-point, integrated sampling; or (3) multi-point, integrated sampling. The gas sample is maisted for percent carbon discide (CD2), percent oxygen (O), and, if necessary percent carbon monostide (CO), if a dry molecular weight determination is to be made, either an Orsal or a Fyrite bundyzer may be used for the analysis; for excess air or emission rate correction factor determination, as Orsal analyser must be used.

1.2 Applicability. This method is applicable for the minimary CO, and O concentrations, excess are and the molecular weight of a sample from a gas stream of a facility of conduction process. The method may also be applicable to other concentrations. The intended may also be applicable to other concentrations sufficient to (N), are not present in concentrations sufficient to

that compounds other than CO_1 , O_2 , CO, and effregen (N_2) are not breast. In concentrations sufficient to substitute the results.

Other methods, as well as modifications to the procedure described herein, are also applicable for some or all on the above determinations. Examples of specific methods and modifications recinite. (1) a multi-point samples and freshed using an Orsal analyzer to analyze individual grab samples obtained at each point. (2) a method using CO_2 or O_1 and stolentometric calculations to determine day molecular weight and excess air, (3) assigning a value of 30.9 for dry undecensor weight, in her of netting in consenses, for processes burning natural gas, each, or cit. These methods and nootherations may be used, but are subject to the approval of the Administrator.

2. Importing

A an alternative to the sampling apparatus and systems described beton, other sampling systems (e.g., laying the placement may be used provided such systems be estable of obtaining a representative sample and maintaining a constant sampling face, and are otherwise capable of yielding acceptable results. I so of such stampling to the approval of the Administrator.

All Grab Sampling (Figure 3.1).

All Trobe The probe should be made of standard strength and the strength of the stampling and should be equipped with an in stack of out-stack their to femous particulate matter to plug of place wood is satisfactory for this purpose! Any other material ment to Og. COg. COg. and Signatures and for the probe, examples of such material are also should, expect, quartrigues and Tellon.

All Turns A one-way squeeze built, or equivalent, is need to transport the gas sample to the analyser.

A breteried Sampling (Figure 3.2).

There is A probe such as that described in Section

Mention of trade money or specific products does not resisting endorsument by the Environmental Protec-tion Agency.




Figure 3-1. Grab sampling train.




Figure 3-2. Integrated gas sampling train.

2.2.2 Condenser. An air-cooled or water-cooled condenser, or other condenser that will not remove $O_{\bf k}$. Co. and $N_{\bf k}$ may be used to remove excess motature which would interfere with the operation of the pump and flow melet.
223 Valve. A needle valve is used to adjust sample.

and flow meter.

2.2.4 Pump. A leak-free. disphraem-type pump, or somewhat is used to immsport sample gas flow rate.

2.2.4 Pump. A leak-free. disphraem-type pump, or somewhat is used to immsport sample gas to the floatilia have install a small surge tank between the pump and the mind a small surge tank between the pump and the intermeter to surmater the pulsation effect of the disphraem pump gos the rotameter.

2.2.6 Has a Meter. The rotameter, or equivalent rate mater, used should be capable of measuring flow rate to within a percent of the selected flow rate. A flow rate to within a percent of the selected flow rate. A flow rate rate of \$2.0 (1000 cm) from its successful.

2.2.6 First if flow any leak-free playtic see. Tedlar. Mylar, Tell or or passine-cated aumnimum is g., shiminized Mylar has a selected of the rate with the selected flow rate and time length of the test rate may be used. A capacity in the range of \$2.0 of interest with the selected flow rate and time length of the test rate may be used. A capacity in the range of \$2.0 of interest with large connect in a water manouveler and pressures the lag to \$10 minutes. Any displacement in the water manouveler tradicules a leak. An alternative lenk-thek manouveler tradicules a leak. An alternative lenk-thek in the messariret the lag to \$10 m Hell (2 to \$10. Hell and allow to stand for the flexible tag leak-thek.

2.2.7 Pressure usings A water-filled U-tube manouveler, or equivalent of a leak-thek.

2.2.8 Vaculum tradicules. A mercury manouveler of the flexible tag leak-thek.

2.2.1 Deg Molecular Weight Determination. An Orsat analyser or Fyritz type conduction gas analyzer may be used.

analyses or Fyrite type combustion gas analyzes may be

1.32 Emission Rate Correction Factor or Excess Air Determination. An Orsai analyzer until be used. For low CO: these than 40 percent; or high O: (greater than 15.0 percent, cor-criticions, the measuring burett of the Orsai must have at least 0.1 percent subdivisions.

3. Dry Molecular Bright Determination

Any of the three campling and analytical procedures described below may be used for determining the dry molecular weight

Single-reint, Grab Sampling and Analytical

3.1 Single-Foint, Grab Sampling and Allerther Procedure 3.11 The sampling point in the duct shall either be at the centroid of the cross section or at a point no closer to the walls than 100 in 13.34th, unless otherwise specified by the Administrator.

3.1.2 Set up the equipment as shown in Figure 3-1, making sure all corrections ahead of the analyzer are tight and less-free If an Ornat analyzer is used, it is recommended that the analyzer be leaked the ked by following the procedure in Section 3, however, the look-check is optional.

following the procedure in Section 5, however, the loak, he's is optional

3.1.3 Place the probe in the stack, with the tip of the probe positioned at the sampling point; burge the sampling line. From a sample into the analyter and immediately analyte; for percent Cibrand percent the betweening the percentage of the gas that is by and CO by subtracting the state of the percent CD, and percent CD from 100 percent. Calculate the dry molecular weight as indexted in Section 5.5.

indicated in Section 6.3.

3.1.4 Repeat the sampling, analysis, and calculation procedures, until the dry molecular weights of any three grab samples differ from their mean by no more than 0.3 gg-mole 0.3 is in-moles Average these three molecular weights and report the results to the nearest 0.1 gg-mole of the moles.

3.2 Single-Point, integrated Sampling and Analytical Procedure.

Oleganoie is the bonder.

3.2 Single-Point, integrated Sampling and Analytical Procedure.

3.2 The sampling point in the duct shall be located as specified in Section 3.1.1.

3.2.2 Leak check (optional) the flexible bag as in Section 3.2.1.

3.2.2 Leak check (optional) the flexible bag as in Section 2.2.5. Set up the equipment as shown in Figure 9.2. Just prior to sampling, leak check (optional) the train by plastical a staction gauge at the condenser inlet, pulling a wacuum of at least 250 mm Hg (to in, 18c), plugging the order at the squick disconnect, and then turning of the pump. The vacuum should remain stable for at least 0.5 minute. Fivariate the flexible bag Connect the prote and place it in the stack, with the up of the prote positioned at the sampling point, purse the sampling line. Next, connect the bag and make sure that all connections are techt and leak free.

3.2.3 Sample at a constant rate. The sampling rim should be similar soons with, and for the same total length of time as, the pollutant emission rate determination. Collection of at least 30 liters of 100 (19) of sample gas is recommended, however, smaller volumes may be collected, if desired.

3.2.4 Obtain one integrated fine gas sample during each pollutant emission rate determination. Within a hours after the sample is taken analyze if for perient CO₃ and percent Or using either an Creat analyzer or a Fyrite-type conduction mas analyzer. If an Orasi analyzer is used it is recommended that the trust leak check described in Section 2 be performed before this determination, however, the check is optional Determine the percentage of the gas that is N; and CO by substracting the sum of the percent CO, and percent On

from 1% percent Calculate the dry molecular weight as indicated in Section 6.3.

2.5. Repeat the analysis and calculation procedures not the individual dry molecular weights for any three malyses dofer from their mean by no more than 6.3 school 0.3 to be made it Average three these molecular motal the weights, and report the results to the nearest 0 1 g g-m

Multi-Point, Integrated Sampling and Analytical Procedure

Procedure

3.3.1 Unless otherwise specified by the Admiristrator a minimum of eight traverse points shall be used for circular stocks have a doameters less than 0.51 m 24 in 3.4 minimum of sine shall be used for rectangular stacks having equivalent diameters less than 0.61 m 24 in 1 and a minimum of twelve traverse points shall be used for all other cases. The traverse points shall be local 1 according to Method 1. The use of fewer points is subject to approve of the Administrator.

3.12 Follow the procedures milliond in Sections 3.2.2 through 3.2.5, except for the following: traverse all sampling points and sample at each point for an equal length. of time. Record sampling data as shown in Figure 3-3.

4. Emission Rule Correction Factor or Excess An Difer-

Note - A Figure-type conduction gas analyzer is not acceptable for smooth at remission tale correction factor determination, unless approved by the Administrator. If both persons 0, and persons 0, are measured, the ambitron testifs of any of the litres procedures given below may also be used for significant the deviation of the significant persons only of the significant persons only of the significant persons only only and the significant persons only only the significant contents.

wought.

A ach of the three procedures below shall be used only
when specified in an approach subpart of the canonach.
The use of these procedures for other purposes must have
specific prior approach of the Administrator.

41 Storie-Point, Grab Sampling and Analytical

4.1 Single-Point, Crab Sampling and Analytical Procedure.
4.4.1 The sampling point in the duct shall either be at the control of the cross-section or as a point in close to the wing than 1,00m (3.2%), unless otherwise specified by the Administrator.
4.1.2 Set up the equipment as shown in Figure 3.1, making sure all connections about of the analytic are both and less free. Less close the Little analytic are both and less free. Less close the Little analytic are

making sure all connections around of the analytic are bolt and leak-free. Leak-check the Great analyzer according to the procedure described in Section 5.

TIME	TRAVERSE PT.	0 1pm	% DEV.
	AVERAGE		
a % DEV =	, Q - Q avg ,	UST BE ≤ 10°	<u></u>

Figure 3.3. Sampling rate data.

4.1.3 Place the probe in the stack, with the tip of the probe positioned at the sampling point nurse the sampling line. Draw a sample in to the analyses. For emission rate correction factor determination, immediately analyse the sample, as outlined in Sections 4.14 and 4.1.5, for percent CO, or percent CO, if excess air is desired, process as follows: If immediately analyse the sample, as in Sections 4.14 and 4.1.5, for percent CO, O. 604 CO, or determine the percentage of the gas that is Ni by subtracting the sum of the percent CO, percent O. and percent CO from 160 percent and calculate percent excess six as outlined in Section 6.2.

4.14 To ensure commiste absorption of the CO, O. or if applicable, CO, make repeated passes through each absorbing solution until two consecutive condings are the aster. Everal passes (three or four) should be made between readings. If constant readings, replace the absorbing solution.

between reachings, obtained after three consecutive readings, replace the absorbing solution.)

4.15. After the analysis is completed, leak-check (mandatary) the Oreat analyser once again, as described in Section 5. For the results of the analysis to be railed, the Oreat snalyser must pass this leak test before and after the analysis, Nora.—Since this single point, grab sampling and analytical procedure to a point snaly solution of in conjunction with a single point, snall sample and analytical procedure for a pointaint, only one analysis as of ordinarity conducted. Therefore, president care must be taken to obtain a valid sample and analysis Although in most cases on the obtain a valid sample and analysis Although in most cases on the conducted of the considered and that the case of the considered and that Catathen 5 in the case of Sampling and Analytical

taken to obtain a valid sample and smalysis. Although in most cases on Oner On it recommended that his sample and Oner Sensired, and that Citation 5 in the smalytical data.

A. Z. Simile Point, integrated Sampling and Analytical Procedure.

A. Z. I be sampling point in the duct shall be located as specified in Section 4.1.1.

A. Z. I be sampling point in the duct shall be located as specified in Section 4.1.1.

A. Z. I be sampling point in the duct shall be located as specified in Section 4.1.1.

A. Z. I be sampling point in the duct shall be as in Section 7.2.5. Set up the equipment as shown in Figure 3.2. Just prior to sampling, leak-cless invariancy the train by placing a vacuum game at the condenser inlet, pulling a vacuum of at least 250 mm Fig. (10 m. Fig.), plugging the outlet at the quick disconnect, and then

turning off the pump. The vacuum shall remain stable for at least 0.5 minute. Execute the herible bag. Connect the purite and piace it in the stack, with the tip of the probe some of at the sampling point, purre the sampling line. Next, connect the bag and make sure that all connections are tiplif and leak free.

4.2.3 Sample at a constant rate, or as specified by the Administrator. The sampling run must be simultaneous with, and for the same total length of time as, the polinically emission rate determination. Collect at least 35 times (100 fit) of sample was. Smaller volumes may be collected, subject to approval of the Administrator.

4.2.4 Obtain one integrated the gas sample during each political emission rate determination. For emission rate enterprise for the sample within 4 hours after it is taken for percent (O) no outland in Sections 4.2.5 through 4.2.7). The forest analyze that subject the analysis of the constant of the percent (O), as outland in Sections 4.2.5 through 4.2.7) for percent (O), and the analysis of the sample of the percent of the constant section 5.1 before the analysis. If cross air is desired, proceed as follows: (1) within 4 hours after the sample is taken, analyse it as in Sections 4.2.5 through 4.2.7) for percent (O), and (O), (2) determine the percent conjugation of the percent (O), as on the percent (O), the constant percent proced excess are as outlied in Sections 3.4.2.5. To ensure complete absorption of the CO), (0), and the percent of the same. Several passes (three or four) should be made between readings of constant readings cannot be obtained after three consecutive readings are the same.

after three consecutive readings, replace the absorbing

in .)
Repeat the souly do until the following criterts are met.
4.5.1 For percent CO₁, repeat the analytical pro-

4.2.6.1 For percent 4.0s, repeat the annivities pro-cedure notifithe results of any three numbers differ by no more than as 0.3 percent by volume when C.Os is greater than 4.0 percent or (b) 0.2 percent by volume when C.Os is less than or equal to 4.0 percent. A veryer the times ceptable values of percent C.Os and report the results to

in magnet 0.1 percent.
4.3.6.2 For percent O₃, repeat the analytical procedure until the remits of any three analyses differ by no more

that a fixteently solume when 0 is less than 15.0 let. it r = 2.1s resultly volume when 0 is less than 15.0 let. it r = 2.1s resultly volume when 0 is greater than 1.1s is result. Average the three acceptable values of e-out 0.1 and report the results to the nearest 0.1

the transport CO repeat the analytical process of any little analytical process to an experient Average the three a spinish to the contract of a contract the three a spinish to the contract of the contract

extracted the Alexander of Section 1 and Alexander of Alexander of the Ale

The second supplies a solution of the points of the second of the second

A. J. Louis Co. in Procedure for Amount Southwest

Max of ye form," and it for frequently causes in to link, it is not an interest of the thoroughly leaktone and it is not a known and the introduced of the call of the call

, and here is only popular up to the $(-a_{ij},a_{ij})$ and the constant

and the parties of th

Bould see in the pipelie for incomment over the first 4.

Living a representation and the past the leak-chook,

I've the interface and the past the leak-chook,

I've the interface and the capitary subong during this

I've the interface in the burete must not shape

to be the transition in the burete must not change
to be reary. I've during these ministeries wall

I've analyzer basis the leak-chook procedure, all

Fibber of meetical and tempooks should be the cked

Limiter base of the leak in denothed. Leaking stopsocks

must be discuss united, deaned, and regressed. Leaking

ruther ourselves as must be exceeded. After the small yer

is reassembled, the leak-chook procedure must be

6. Culmilations

6 1 Nomenclature.

Mass Dry molecular weight, g/g mole (the fiction).

C 1 A = Percent excess air.

C 14 = Percent Orby volume (dry basis).

G = Percent Orby volume (dry basis).

G = Percent Orby volume (dry basis).

Nas Percent Nr by volume (dry basis).

Nas Percent Nr by volume (dry basis).

Sas Percent Nr by volume (dry basis).

Ad = Ratio of Orto Nr in air, v/v.

Sis Molecular weight of Ordivided by 100.

G 440 Molecular weight of Ordivided by 100.

G 440 Molecular weight of COrdivided by 100.

6.2 Percent Excess Air Calculate the potent excess air a applicable), by substituting the appropriate values of percent to, C.O. and Notobiolish from Section 4.1.3 of 4.2.6) into Expuntion 3-1.

$$C_{i} + \lambda = \begin{bmatrix} C_{i}O_{2} - 0.5^{\circ} + CO_{2} \\ 0.264^{\circ} + N_{2}(C_{1}C_{2})_{2} & 0.5^{\circ} + CC_{2} \end{bmatrix} + 000$$

Figure 6.3-1

Note—The equation above assumes that ambient are used as the source of O₂ and that the finel shees not contain appreciable amonities of N₂ has do coke oven or load further gases). For those cases when appreciable amonities of N₂ are present load, oil, and matural gas do not contain appreciable amonits of N₂ or when oxisen entachment is used, aftering methods, subject to a corosal of the Administrator, are required.

§ I try Molecular Weight, U.S. Equation 3-2 to evaluate the dry molecular weight of the stack was

 $M_{\rm A} = 0.100 (2.0 \, O_{\odot} + 0.3200 \, O_{\odot}) + 0.2800 (N_{\odot} + 0.00)$

Equation 3 2

Note -The above equation does not consider argon by ar (about to) percent, moreonar weight of 37.7). A gative entor of whost 6.4 percent is introduced. The fester may opt to include argon in the analysis using procedures subject to approval of the Administrator.

Hillingtoning

Michaglandy
 Altshuller, A. P. Sincape of Grases and Vapors in Problem 1978. Informational Jourcal of Ad and Water Problem 1978. I 1965.
 Tomer, William D. and I. S. Nader, Air Sampling Plactic Bary Journal of the American Industrial Hysiciae Association, 25-26 (200 August, Several) edition.
 Burrell Magnar for Go. Analysts, Several edition.
 Burrell Magnar for Go. Analysts, Several edition.
 Burrell Corporation, 223 (19th Avenue, Physiologic, Pa. 1529, 1961.
 Mitchell, W. J. and M. R. Midgett, Field Reliability of the Orant American Journal of Air Pollution Control Association E 301 (200 May 1976).
 Shigehara, R. T., R. M. Nombelt, and W. E. Smith, Validatury Orant Amarysis Data from Fessol Firet-Fixed Units, Stack Sampling News, 3(2) 21-26, Acquist, 1976.

METHOD 1-DETERMINATION OF MOSTURE CONTENT IN STACK GASES

1. Principle and Applicability

1.1 Principle and Applicability

1.1 Principle A was sample is extracted at a constant the from the source, investure is removed from the sample stream and determined either volumetrically or gravimetrically.

1.2 Applicability. This method is applicable for determining the moissure content of stack was.

Two procedures are given. The first — a rearrance method, for accurate determinations or moisture content to stack was.

Two procedures are given. The first — a rearrance method, for accurate determinations or moisture content teach as are medical treatment of a moisture content teach as are medical treatment to add in serting lasking treatment time. The approximation method, which principles estimates of percent measure to a political emission measurement time. The approximations method described herein a surjet a suggested approach, alternative means for approximating the maneture content, e.g., drying tubes, wet indised to hill traditions, previous experience, etc., are also acceptable.

The reference mixthod is after sandacted simultaneously with a political emission sometic, etc., for the this shall be based upon the results of the reference method of its equivalent, these calculations shall not be based upon the results of the statisfaction of the Administrator, U.S. Environments and the reference method of the equivalent, these calculations shall not be based upon the results of the approximation method, miles the approximation method is shown, to the satisfaction of the Administrator, U.S. Environments within a percent of the method may yield questionable results when applied to satisfact a second determination of the moisture vortent shall be made simulation of the moisture content shall be made simulation of the processe method, as follows: Assisted the source method for experience method, as follows: Assisted the surface of

2. Economic Method

The procedure described in Method 5 for determining moisture content is acceptable as a reference method.

2.1 Apparatus: A schematic of the sampling train used in this reference method is shown in Figure 4-1. All components shall be maintained and calibrated according to the procedure outlined in Method 5.




Figure 4-1. Moisture sampling train-reference method

2.1.1 Probe. The pube is constructed of stainless steel or glass tubing, sufficiently heated to prevent water condensation, and a equipped with a liter, either finetack (e.g., a bing of class whole inserted hum the end of the probe) or heated out-stack (e.g., as described in Meth. 45, to remove particulate matter.

When tack conditions permit, other metals or plastic tubing may be used for the probe, subject to the approval of the Administrator.

2.1.2 Condenser. The condenser consists of four impligers connected in series with ground class leak-free fittings or any similarly leak-free mon-condaminating fittings. The first, third, and fourth imminers similable of the Greenburg-Smith design, modified by replacing the tip with a 1.3 continueter (§) lich) 1D glass tube extending to about 1.3 cm [§] int from the bottom of the flack The second improve shall be of the Greenburg-Smith design, and fine fithe Greenburg-Smith design with the standard of the firending to about 1.3 cm [§] into from the bottom of the flack the account improve shall be of the Greenburg-Smith design with the standard to the condenser, using materials other transpasses to use of each of warming lines to connect the little backer to the condenser) may be used, subject to the approval of the Administrator.

The first two improvers shall contain known volumes of water, the third shall be empty, and the fourth shall contain a known weight of 6 to formeth inducing type slice pel, or equivalent desiceont. If the silica gel has been previously axed, dry at 1.72 C (3.07 F) for 2 hours. New silica gel may be used as received. A thermomenter, capable of measuring temperature to within 1°C (2°F), shall be rilaced at the outlet of the fourth improger, for monitoring purposes.

Alternatively, any system may be used isother to

shall be placed at the sutiet of the fourth impinger, for monitorine purposes.

Alternatively, any system may be used isobject to the approval of the Administrator that cools the sample as stream and allows neasurement of both the water that has been condensed and the moisture leaving the condenser, each to within 1 mi or 1 g. Acceptable means are to measure the condensed and after, either gravimetrically or volumetrically, and to measure the moisture leaving the condenser by: (1) monitoring the temperature and pressure at the exit of the condenser and using Dalton's law of partial pressures, or (2) passing

the sample gas stream through a tared silica gel for equivalent desireant) trap, with exit gases kept below 20° (198° F) and determining the weight cain. If we are other than silica gel are used to determine the ancada in massitus leaving the condenser, it is recommended that silica gel for equivalent) still be used between the condenser system and pump, he prevent moisture condenser system and pump, he prevent moisture condensation in the pump and caltering devices and to avoid the used to make corrections for moisture in the natural volume.

2.1.3 Cuoling System. An ice bath container and crushed ice (or equivalent) are used to aid in condensing massime.

2.1.3 Cueling System. An ice bath container and erushed be for equivalent) are used to aid in condensing missions.

2.1.4 Metering System. This system includes a vacuum gauge, leas-free pump, thermometers capable of missioning temperature to within 3° C (5.4° F), dry gas make capable of measuring volume to within 2 percent, and related equipment as shown in Figure 4-1. Other metering systems, capable of maintaining a constant samp log trie and determining sample gas volume, may be used, subject to the approval of the Administrator.

2.1.5 Harometer Mercurs, amend, or other barometer capable of measuring atmospheric pressure to within 2.5 mm the 40° m. His may see the differences between the weather scales from a nearby main and weather service station, in which case the station value (which is the absolute that mostro pressure) shall be requested 80d an adjustment for elevation differences between the weather scales and the sampling point shall be applied at a rate of minus 2.5 mm the 10.1 m. Het per 30 m (10) ft) elevation between the weather scales in between the seathers of the distribution to the distribution of the section of the distribution to greater than 2 ml. Miss absention the life capable of weighter to the nearest 0.5 g or less. Those that measure as suitable for use there.

2.2 Procedure The following pracedure is written for

use here.

2.2 Procedure The following procedure is written for a condenser system (such as the impager system de-

scribed in Section 2.1.2) incorporating volumetric analysis to measure the condensed moisture, and sitica rel and gravimetric analysis to measure the moisture leaving the

section 2.1.2 incorporating volumetric manyis to measure the condensed maskure, and sitics pel and
gravimetric analysis to measure the moisture leaving the
condenser.

2.2.1 Unless otherwise specified by the Administrator,
a minimum of eight traverse points shall be used for
circular stacks basing diameters less than 0.61 m/24 m/s,
a minimum of nine points shall be used for rectain stacks having equivalent diameters less than 0.61 m/24 m/s,
a minimum of nine points shall be used for rectain shall
be used in all other cases. The traverse points shall
be used in all other cases. The traverse points shall be
located according to Method 1. The gise of fewer points
is subject to the approval of the Administrator Sciect a
sautable probe and probe length such that all traverse
points can be sampled. Consider sampling from opposite
sides of the stack four total sampling ports) for large
sides of the stack four total sampling ports) for large
stacks, to permit use of shorter probe lengths. Mark the
probe with heat resistant tane or by some other method
to denote the proper distance into the stack or duct for
each sampling point. These known volumes of water in
the first two impingers. Weigh and record the weight of
the silica get to the resistant site may be a supplied to the fourth impinier, alternatively, the silica get
of the silica get in summinger recorded.

2.2.2 Scient a total sampling time such that a minimin total gias volume of 0.68 sem (21 sef) will be collected, at a rate so greater than 0.021 m/yimin 60.76 cfm).
When both monstant constant and pollutant emission rate
are to be determined, the minimum total ength of
time as, the pollutant constant mate minimum total gias volume of 0.68 sem (21 sef) will be collected, at a rate so greater than 0.021 m/yimin 60.76 cfm).
When both monstant constant and pollutant emission rate
are to be determined, the mastine determination stall
be simultaneous with, and for the same total length of
time as, the pollutant constant mate of a bout 120° C
(240° F), to pres

follows: Piscomiect the probe from the first impinger of

Figure 1 of the filter holder. This the inlet to the test impager or Older holder) and pulls 3 semin discussions are supplied that one cases led disconsistent may be used, proceeded that it is not cases led disconsistent when the rest in the rest in the second process of the test. A leakage rate is the sample point, at least once during each time.

In once do disconsistent when the rest is less, is understanted to used the probe to the second of the rest in the probe to the second the sampling the same in grown maintain a sampling and and of each sampling time increment and when him in processor of the dry gas meter reading at the beginning and end of each sampling time increment and when him therefore a disconsist of the first test of the test reading at the beginning and end of each sampling time increment and when him and the example data sheet shown in Figure 4.2.

For a true test in the local control the example of the appropriate readings at the beginning the sample point, at least once during each time allowance that the color wall event the test results of the test reading at the test results of the test reading at the test results of the test resu

PLANT	
DCATION	
OPERATOR	
DATE	
RUN NO.	
AMBIENT TEMPERATURE	
BAROMETRIC PRESSURE	116. 3-3 4 1 12.3
PROBE LENGTH m(M)	

SCHEMATIC OF STACK CROSS SECTION

				METER READING		GAS SAMPLE AT DRY	TEMPERATURE OF GAS LEAVING CONDENSER OR	
TRAVERSE POINT NUMBER	TIME (0), min.	STACK TEMPERATURE OC (OF)	DRIFICE METER (AH), mm(in) H20	CASSAMPLE VOLUME m3 (m2)	2 (413)	(MLET (min), PC (AF)	(Tmout), OC (PF)	LAST IMPINGER
					- Management			1
					1			1
		The second second						
				1				
TOTAL	1					Avg.	Avg.	

Figure 4-2. Field moisture determination reference method.

	WOLUME, mis	SILICA GEL WEIGHT, 0
FINAL		
INITIAL		
DIFFERENCE		

Figure 4.3. Analytical data - reference method.

V=slety gas volume measured by dry gas noted done doll.

AV = Their has all dry gas volume measured by dry gas meter at each traverse poorly dom idel.

V=(n)=100 gas volume measured by the dry gas meter corrected to stouched contituous, days meter corrected to stouched contentus, then day 0.

V=x(n)=100 gas volume of water valor confested in siting get corrected to Standard conditions, Sem get corrected to Standard conditions, Sem (sef).

V=x(n)=100 gas volume of conditions water, nd.

Ves Final volume of conde our water, nd. Vestinal volume, if any of condenser water,

B' which weight of silica got or silica get plus

$$\begin{split} V_{\text{Modesol}} &= \frac{(V_f - V_s) \, \rho_{\text{w}} R T_{\text{and}}}{P_{\text{and}} M_{\text{w}}} \\ &= K_1 (V_f - V_s) \end{split}$$
 Equation 4.1

where: $K_{i=0.04797}$ it and for metric units =0.04797 it and for English units
2.3.3 Volume of water vapor collected in silica get.

$$\begin{split} V_{\text{west}(\text{and})} &= \frac{(W_f - W_{\star}) \, R \, T_{\text{and}}}{P_{\text{and}} \, M_{\text{w}}} \\ &= K_{\mathfrak{p}}(W_f - W_{\star}) \end{split}$$
 Equation 4-2

where $K_2=0.001336 \text{ m}^2/s$ for metric units $=0.04718 \text{ ft}^2/s$ for English units 2.3.4 Sample gas volume.

$$\begin{split} V_{\mathbf{m}\,(\mathrm{rbd})} &= V_{\mathbf{m}} Y^{-} \frac{(P_{\mathbf{m}}) \left(T_{\mathbf{rbd}}\right)}{(P_{\mathbf{rbd}}) \left(T_{\mathbf{m}}\right)} \\ &= K_{3} Y^{-} \frac{V_{\mathbf{m}} P_{\mathbf{m}}}{T_{\mathbf{m}}} \end{split}$$

K₂=0.3858 K hum Hg for metric units =17.65 Hun. Hg for English units

Note—If the post-less leak rate (Section 2.2.6) es-receds the allowable rate, correct the value of V_∞ in Equation 4.3, as described in Section 6.3 of Method 5, 2.3.5 Mosture Content.

$$B_{-s} = \frac{V_{-s, (\text{acc})} + V_{-s, (\text{cod})}}{V_{-c, (\text{sod})} + V_{-s, (\text{cod})} + V_{\text{acc}, (\text{sod})}}$$

Equation 4-4

Note the saturated or mosture droplet-laden gas streams, two calculations of the moisture centert of the stack gas shall be made, one using a value based upon the saturated conditions (see Section 1.2), and another based upon the results of the impriger analysis. The lever of these two values of H_{sc} , shall be considered correct.

2.56 Aerification of constant sampling rate. For each function concert, determine the \$\Delta L\$ Calculate the average If the value for any time increment differs from the average by more than 16 percent, reject two results and repeat the fun.

3. Approximation Method

The approximation method described below is presented only as a suggested method (see section 1.2).

11 Apparatits.

11.1 Prote. Stainless steel or glass tabing, sufficiently heate?

2.2.1 white rether in stack or heated out stack) to remove particulate to natter A plug of glass word, anserted into the end of the prote, is a suiclastory liter.

11.2 Impropers Two midget inpingers, each with 31.3 for flain to contense and ree, to 2 d in condensation more than in managers.

a 1.3 for furn Camazine and re, to 2 or resonant ing most street in impulgates.

3.1.1 Trying Tithe, Tithe packed with new of regenerated to to Romean adjection-type silica get for equivalent desic and t, to dry the sample gas and to profect the metri and pump.

3.1.5 Valve Noedic valve, to regulate the sample gas

reminate the second of the sample gas free the metter and plump.

2.1.5 Vaive. Needle valve, to regulate the sample gas flow rate.

3.1.6 Vaive Needle valve, to regulate the sample gas flow rate.

3.1.7 Valve nearly flow of the sample the train.

2.1.7 Valvane navet. Bry gas meter, sufficiently accurate to measure the sample volume within 2%, and actually encountered during sampling.

3.1.8 Rate Meter. Retained to flow rates and conditions actually encountered during sampling.

3.1.9 Graduated Cylinder. 25 ml.

3.1.10 Graduated Cylinder. 25 ml.

3.1.11 Vacuum Gauge. At least 160 mm Hg (30 in. Hg) gauge, to be used for the sampling leak check.

3.2.1 Procedure.

3.2.1 Place exactly 5 ml distilled water in each impinger. Assemble the appearatus without the probe as shown in Figure 4.4 Leak check the train by placting a vacuum gauge at the inici to the first impinger and drawing a vacuum of at least 250 mm Hg (10 in. Hg), plugging the outlet of the rotameter, and then turning off the pump. The vacuum shall remain constant for at east one minute. Carefully release the vacuum gauge libefore implugging the rotameter end.




Figure 4-4. Moisture sampling train - approximation method.

LOCATION	COMMENTS
TEST	
DATE	
OPERATOR	
BAROMETRIC PRESSURE	

CLOCK TIME	GAS VOLUME THROUGH METER, (Vm), m ³ (ft ³)	RATE METER SETTING m ³ /min. (ft ³ /min.)	METER TEMPERATURE.
The state of the s			
		The second secon	
			The second secon

Figure 4-5. Field moisture determination - approximation method.

3.2.2 Connect the probe, insert it into the stack, and sample at a constant rate of 2 lpm (0.07) cfm). Consinue sampling until the dry gas meter registers about 30 liters (1.149) or until visible liquid droplets are carried over from the first impiner to the second. Record temperature, pressure, and dry gas meter readings as required by Figure 4-5.

3.2.3 After collecting the sample, combine the contents of the two impingers and measure the volume to the nearest 0.5 ml.

3.3 Calculations. The calculation method presented is designed to estimate the moisture in the stack gas; therefore, other data, which are only necessary for accurate moisture determinations, are not collected. The following equations adequately estimate the moisture content, for the purpose of determining isokinetic sampling rate settings.

3.3.1 Nomenclature.

3.1 Nomenclature.
B_{***} Approximate proportion, by volume, of water veror in the gas stream leaving the second impinger, 0.025.
B_{***} Water variet in the gas stream, proportion by

B... Water value in the gas stream, proportion by volume.

Mess Molecular weight of water, 28.0 g/g-mole (18.0 ½-fib-mole)

P. Absolute pressure (for this method, same as barometric pressure) at the dry gas meter.

P. Standard absolute pressure, 760 mm Hg (20.2 in Hg).

R. Adeal gas constant, 0.06236 (mm Hg) (m²)/(g-mole) ("K) for metric units and 21.85 (in. Hg) (ii²)/hb-mole) ("R) for English units.

units

T = Absolute temperature at meter, *K (*R)

T = Standard absolute temperature, 25.5 K
(5.26 R)

V = Final volume of impinger contents, ml.

V = Initial volume of impinger contents, ml.

V = Dry gas volume measured by dry gas meter, den (def).

V = (10.61) = Dry gas volume measured by dry gas meter, corrected to standard conditions, dscm

Risef).

V = (10.62) = Volume of white vapor condensed, corrected to standard conditions, dscm

$$V_{\mathrm{ws}} = \frac{(V_{t} - V_{i}) \rho_{\mathrm{w}} RT_{\mathrm{and}}}{P_{\mathrm{and}} M_{\mathrm{w}}}$$

 $= E_1 \left(V_f - V_s \right)$

Equation 4-5

where:

K=0.001203 mJ/ml for metric units

=0.04707 ftJ/ml for English units

3.3.3 Gas volume.

$$\begin{split} V_{\text{m (sid)}} &= V_{\text{m}} \left(\frac{P_{\text{m}}}{P_{\text{ski}}}\right) \left(\frac{T_{\text{su}}}{T_{\text{m}}}\right) \\ &= K_{1} \frac{V_{\text{m}} P_{\text{m}}}{T_{\text{m}}} \end{split}$$

Equation 4-6

where: Ks=0.3838 *K/mm Hg for metric units =17.64 *R/m. Hg for English units

3.7.4 Approximate moisture content.

$$\begin{split} B_{es} &= \frac{V_{we}}{V_{ee} + V_{m \, (sid)}} + B_{em} \\ &= \frac{V_{we}}{V_{we} + V_{m \, (sid)}} + (0.025) \\ 4. \text{ Subjection} \end{split}$$
 Equation 4-7

4. Julibration

6.1 For the reference method, calibrate equipment as specified in the following sections of Method 5. Section 5.3 (metering system); Section 5.5 (temperature gauges); and Section 5.7 (barometer). The recommended lead theck of the metering system (Section 5.6 of Method 5) also applies to the reference method. For the approximation method, due the procedures outlined in Section 5.1 of Method 6 to calibrate the metering system, and the procedure of Method 5. Section 5.7 to calibrate the barometer.

5. Bibliography

1. Air Pollution Engineering Manual (Second Edition).
Danielson, J. A. (ed.). U.S. Environmental Protection
Agency, Office of Air Quality Planning and Standards.
Research Triangle Park, N.C. Publication No. AP 40.

2 Devorkin, Howard, et al. Air Pollution Source Test-ing Manual. Air Pollution Control District, Los Angeles, Calif. November, 1963.
3. Methods for Determination of Velocity, Volume, Dust and Mist Content of Gases. Western Precipitation Division of Joy Manufacturing Co., Los Angeles, Calif. Bulletin W.P.-50, 1968.

METHOD 5—I) ETERMINATION OF PARTICULATE EMISSIONS FROM STATIONARY SOURCES

1

1. Principle and Applicability

1.1 Principle Particulate matter is withdrawn isometically from the source and collected on a place finer hiter maintained at a temperature in the range of 120±14° C (288±25° F) or such other temperature as specified by an applicable subject of the standards or approved by the Administrator, U.S. Environmental Protection Agency, for a particular application. The particulate mass, which includes any material that condenses at or above the filtration temperature, is determined gravimetrically removal of uncombined water.

1.2 Applicability. This method is applicable for the electromation of particulate enussions from stationary

2. Apporatus

2.1 Sampling Train. A schematic of the sampling train used in this method is shown in Figure 5.1. Complete construction details are given in APTD most (Citation 2 in Section 7); commercial models of this train are also available. For changes from APTD-9581 and for allowable modifications of the train shown in Figure 5.1, see the following subsections.

Figure 5-1, see the following subsections.

The operating and maintenance procedures for the sampling 'ain are described in APTD-0576 (Citation 3 in Section .' Since correct usage is important in obtaining valid rest. is, all users should read APTD-0576 and adopt the operating and maintenance procedures outlined in it, unless otherwise specified herein. The sampling train consists of the following components:




Figure 5 1. Particulate sampling train.

plane of the pitot tube shall be even with or above the notice cutry plane (see Method 2, Figure 2-6b) during sampling. The Type 5 pitot tube assembly shall have a snown coefficient, determined as outlined in Section 4 of Method 2.

2.1.4 Differentia Fressure Gauge Inclined manometer or e-mission devertised, as ascribed in Section 2.2 of Method 2. One manometers sail be used or vascity head (ap) readings, and the other, for ordice differential

1.1 Probe North Stainless should 3160 or glass with Larp, tappered leading edge. The angle of taper shall be \$38" and the taper shall be on the outside to preserve a constant internal diameter. The proble north shall be of the button-hook or elibow design, unless otherwise specified by the Administrator. If made of stainless sheet the north shall be constructed from semiles tubing, where materials of construction may be used, subject to the Agripoval of the Administrator.

A range of north sizes suitable for isokinetic sampling bould be available, e.g., 0.32 to 1.7 cm (54 to 1; in.)—larger if higher volume sampling trains are used—left in a fact that the content of the condition of the condition of the condition of the condition of the procedures outlined in Section 5.

2.1.2 Probe Liner, Roroschicate or quartic glass tubing with a heating system capable of maintaining a gas temperature at the esit end during sampling of 120-14° C (248±25° F), or such other temperature as specified by an applicable subpart of the standards or approved by the Administrator for a particular application. (The leater may opt to operate the equipment at a temperature lower than that specified.) Since the actual temperature and until the probes is not usually monitored during sampling, probes constructed according to APTD-656 for calibrated according to the procedure outlined in APTD-656 will be considered acceptable.

Either bornsities to quartic place probe liners may be used at higher temperatures than specified for short stack temperature to both types of mers may be used at higher temperatures than specified for short stack temperature, every effort should be made to use borosities.

metal amers to E. Ste Stations seed, incomy 8.5, or other corresion resistant metals made of scamless tubing may be used, subject to the approval of the Administrator, 21.3. Fittel Tube, Type of as described in Section 2.1 of Method 2, or other device approved by the Adminis-trator The pittel tube shall be attached to the probe (as shown in Figure 6-1) to allow constant monitoring of the stack gas velocity. The impact (high product) opening

pressure reschings.

2.1.5 Filter Holder. Borosilicate glass, with a glass trit filter support and a suscene rubber gasket. Other materials of construction leg., staniess steel, Teffon, Vitoni may be used, subject to approval of the Administrator. The holder design shall provide a positive seal scale in the state of the outside or around the filter. The holder shall be attached immediately at the outlet of the probe for cyclone, if used). 2.1.6 Filter Heating System. Any heating system carable of maintaining a temperature around the filter holder during sampling o 420±14° C (248±25° F), or such other temperature as specified by an applicable subpart of the standards or approved by the Administrator for a particular application. Alternatively, the tenter may opt to operate the equipment at a temperature lower than that specified. A temperature gauge capable of measuring temperature to within 3° C (5.4° F) shall be installed to that the temperature. be installed so that the temperature around the filter holder can be regulated and monitored during sampling. Heating systems other than the one shown in APTD-6581 may be used.

Call may be used.

2.1.7 Condenser. The following system shall be used to determine the stack gas monsture content. Four impingers connected in series with leak-free round glass futings or a.y similar leak-free non-contamonating futings. The first thred and fourth impingers shall be on the Greenburg Smith design, modified by replacing the up with 1.3 cm (2) in.) ID reas into extraction to about 1.4 cm (2) in.) ID reas into extraction to should have 10 feet in the bottom of the link. The second impanger shall be night foreigning Smith design with the standard up. Modifications (e.g., using flexible connections between the impringers, using materials other than glass, or using flexible a country to be a single to the approval of the Administrator. The first and second impangers along endance in a most property of single property of the fourth shall contain a known weight of single or equivalent desiceant. A thermometer, impalie of incasure

ing temperature to within 1° C (2° F) shall be placed at the outlet of the fourth impringer for monitoring purposes.

Alternatively, any system that cools the sample gas stream and sillows measurement of the water condensed and moisture leaving the condenser, each to within 1 mi or 1 g may be used, subject to the approval of the Administrator. Acceptable means are to measure the condensed water either gravimetrically or volumetrically and to measure the moisture leaving the condenser by:

(1) monitoring the temperature and pressure at the exit of the condenser and using Dalton's law of partial pressures; or (2) passing the sample gas stream through a tared since get for enuiralent descending the weight gain.

If means other than siles get are used to determine the amount of moisture leaving the condenser, it is recommended that since get for equivalent) still be used between the condenser system and pump to prevent moisture condensation in the pump and metering devices and to avoid the need to make corrections for moisture in the metered volume.

the included volume.

Note: -11 is determination of the particulate matter collected in the impingers is desired in addition to motiture content, the impinger system described above shall be used without medification, individual states or country agencies requiring this information shall be contacted as to the sample recovery and analysis of the

immanger content:
2.1.8 Metering System Vacuum gauge, leak-free
pump, the momenters capable of measuring temperature
to within 3°C (5.4°F) drygas meter cateble of measuring
volume to within 2 percent, and related equipment, as
shown in Figure 5-1 Other metering systems capable of
ministailing sampling rates within 10 percent of isokinetic and or determining sample volumes to within 2
percent may be used, subject to the approval or the
Administrator. When the metering system is used in
combination with a pilot tube, the system shall enable
checks or isokinctic rates.
Sampling train-validing metering systems designed for

Sampling trains utiliting metering systems designed for higher flow rates than that described in APTD-6581 or enjable to the astring atmosphere pressure to within 2.5 mm Hg (0.1 m Hg). In many cases, the barometric roading may be obtained from a nearby national weather service station, in which case the station value (which is

Mention of trade names or specific product, does not trule endorsement by the Environmental Protec-

the absolute barometric pressure) shall be requested and an adjustment for elevation differences between the ther station and sampling point shall be applied at a loof minus 25 mm [1] (6.1 in. Hg) per 30 m (100 ft). The per 30 m (100 ft) is a loof in the per 30 m (100 ft). The look increase is a look in the look of the per 30 m (100 ft). The look is a look of the look of the

eded

Probe-Liner and Probe-Nozzie Brushes. Nylon brushes with stancess steel were handles. The 221 Probe-Liner and Probe-Nuzzie Brushes Nylon bristic brushes with stainless steel were hundles. The probe brush shall have extensions sat least as long as the probes of stainless steel. Nylon, Tetlon, or samilarly inert material. The brushes shall be properly sited and shaped to brush out the probe liner and nozzie 222 Wash Bottles—Two. Glass wash bottles are recommended, polyethylene wash bottles may be used at the option of the tester it is recommended that a come not be stored in polyethylene bottles for longer than a month.

month.
223 Glass Sample Storage Containers. Chemically
resistant, berosilicate glaco bottles, for acetone waches,
800 mi or 1008 ml Sirew cap liners shall either be rotherbacked Teflon or shall be constructed so as to be leak-free
and resistant to chemical attack by sectone. Narrow
mouth glass bottles have been found to be less prone to
leakage. Alternal rely, polyethylene bottles may be
used.

ed. 224 Petri Dishes For filter samples, ginss or pold-hylene, unless otherwise specified by the Admin-

istrator 2.2.5 Graduated Cylinder and or Balance. To measure condensed wa'er to within 1 mi or 1 g. Graduated cylinders shall have subdivisions no greater than 2 ml. Most interactive becomes are expanded weighing to the nearest 0.2 g or less. Any of these balances is suitable for use fore and in Section 2.3.4.

2.2.6 Plastic Storage Containers. Air-tight containers tectors allowed.

7.2.6 Plaste Servey obsersible sel 2.2.7 Funnel and Rubber Pole-eman. To aid in under of such sel to container not necessary if silical is weighted in the field. 2.2.8 Funnel toward providilence to aid in sumple

Analysis, For analysis, t. a following equipment is

23 Analyses received to the second of the se

2.3.4 Balance To measure to within 0.3g
2.3.5 Beakers 2.20 m)
2.3.6 Hygrometer To measure the relative lumidity
of the laboratory environment.
2.3.7 Temperature Gauge To measure the respirature of the laboratory environment.

3. Rengents

3.1 Sampling. The respects used to sampling are as

5.1 Sampling The respects used in sampling are as follows

3.1.1 Filters. Glass fiber filters, without organic binder, exhibiting at least stab percent ediclement (5.0.0) percent penetration on 0.3-minors discellently (5.0.0) percent penetration on 0.3-minors discellently (5.0.0) minors from the particles. The filter efficiency test shall be conducted in accordance with ASTM standard method 19206-7.1 Test data from the supplier's quanty control program are sufficient for this parties.

3.1.2 Sides Cel. Industrial type, 6 to 16 mesh. If previously used, dry at 125° C (250° F) for 2 hours. New silving get may be used as received. Attenualizedy, other types of designants (equivalent or better) may be used, subject to the approval of the Administrator.

3.1.3 Water. When analysis of the material caught is the impringers is required, distribut water shall be used. Run binniks prior to field use to chriminate a high blank on text samples.

3.1.4 Crushed Ice.

3.1.5 Stopcook istense. Acclude-involution, bent-stable.

3.1.4 Crushed Ice.
3.1.5 Storecok Greece Aretime-broduste, heat-stable silicone grease. This is not necessary if setew-on connectors with Tection shows, or similar, are used. Alternatively, other types of suppose grease has be used, subject to the approval of the Administrator grade. Colon 2.2 Europe Kroovers Acctones reagent grade. Colon percent residue, in glass bottles—is required Acctone from metal continuers gradely base high readule bigois and should not be used. Sometimes, supplies transfer accione to glass bottle from metal positioners, thus, sectione biaries should be true prior to field use and only acctone with low blank values (C.0.90) prevent shull be used. In no case shall be annix value of greater than 0.001 percent of the weight of acctone used be subtracted from the sample weight.

3.3 Analysis Two reagents are required for the analy-

3.3.1 Acetone Same 88.3.2.
3.3.2 Desiceant Anhydrous calcium sulfate, indicating type. Alteriatively, other types of desiceants may used, subject to the approval of the Administrator.

4. Procedure

4.1 Sampling. The complexity of this method is such that, in order to obtain reliable results, testers should be trained and experienced with the test procedures.

4.11 Pretest Preparation. All the components shall be manufacted and calibrated according to the procedure described in APTD-0576, unless otherwise specified between

heretic.

Weightseveral 200 to 300 g portions of silica gell in air-tight containers to the negrest 0.5 g. Record the total weight of the silea gel pins container, on each container. As an alternative, the silea gel need not be presented, but may be weighed directly in its impinger or sampling holder.

may be weighed directly in an impose, the holder just prior to train assembly.

Once hiters visitally against high for fregularities and flaws at publish leaks. Label filters of the proper diameter on the back side near the edge using numbering machine link. As an alternative, label the shipping containers iglass or plastic periodishes, and keep the filters in these containers at all times except during sampling and

marchier.

or plastic petri dishesi and keep the filters in these more at all times except during sampling and made the filters at 20±5.0° C (68±10° F) and eat pressure for at least 26 hours and weight at interesting from previous wearing, record results or energe 0.1 mg. During each weighing the filter not be exposed to the laboratory atmosphere for a discrete than 2 minutes and a relative humidity e 50. 2001. Alternatively (tribes otherwise specibly the Administrator), the filters may be oven by the Administrator), the filters may be oven to 105° C (220° F) for 2 to 3 hours, desircated for 2 k and weighed. Procedures other than those deed which account for relative humidity effects, may set subject to the approval of the Administrator. 2 Freilminary beterminations. Select the sampled and the uninterim number of sampling points of the received which select the sample of coloridate the individual of the Administrator and the uninterim number of sampling points of the receive the stack as a specified by the Administrator of least-to-k of the part lines (see Method 2, Section 3 to 10 minutes and the effective through the sampling reas sections, or the part which all the performed iterators the inocture outcome the stack as a dry modecular weight, as desirable to stack as a dry modecular weight, as desirable than some the maintain between the stack as dry indicellar selection, the parties sample rus.

Let a north same based on the range dividently bends, in that it is not necessary to change the mazile size in or the institution broker of a capture the mazile size. High the range of the same than possible to the mazile size in orthogen the mazile size. Ensure that the per inferential prosecute and see Sevino 2.2 of Alexbor.

proper inflerential pressure range is chosen for the trap of velocity heads encountered range is chosen for the range of velocity heads encountered range is chosen for the range of velocity heads encountered range is chosen for the range of the state o

details. Other connecting systems using either 316 stain less steel or Tellon ferrules may be used. When metal liners are used, install the nozzie as above or by a leak-free direct mechanical connection. Mark the probe with heat resistant tape or by some other method to detote the proper distance into the stack or duct for each same

pling point.

Bet up the train as in Figure 5-1, using til necessary) a very light cont of allicone grease on all ground glass joints, greasing only the other portion (see APTD-6576) to avoid possibility of contamination by the silicone grease. Subject to the approval of the Administrator, a glass, yelone may be used between the probe and filter holder when the total particulate each is expected to holder when the total particulate rates is expense, as expense of 100 mg or when water droplets are present in

stack gar.

The crushed ice around the impingers.

114 Leak-Check Procedures.

414 Pretest Leak-Check A pretest leak-check is recommended, but not required. I the fester opts to conduct the pretest leak-heck, the following procedure.

shall be used.

After the sampling train has been assembled, turn on and set the filter and probe beating systems at the desired operating temperatures. After time for the temperatures to stabilize if a Viton A O-ring or other leak free connection is used in assembling the probe norzhe to the probe liner, leak-sherk the train at the sampling site by plugging the norzhe and pulling a safi nin Hg (45 in: Hg)

Note.—A lower vacuum may be used, provided that it is not exceeded during the test. If an asbestos string is used, do not connect the probe to the train during the leak-check. Instead, leak-check the train by first plugging the leak-check. Instead, leak-check the train ty first plugging the inlet to the fifter holder (eyelone, if singleable) and pulling a 380 mm Hg (15 in. Hg) vacuum (see Note immediately above). Then connect the probe to the train and leak-check at about 25 mm Hg (1 in. Hg) vacuum siternatively, the probe may be leak-checked with the rest of the sampling train, in one step at 380 mm Hg (15 in. Hg) vacuum. Loakage rates in excess of 4 percent of the average sampling rate or 0.00037 m²/min (0.02 cfm), whichever is less, are unacceptable.

rates in excess of a period of or 0.0025 m 4.000 (or 0.0025 m 4.000) (or 0.000) (or 0.000)

silien per from being cutrained big kward into the third impager.

(1.4.2 Leak Checks During Sample Bim. If, during the sampling rub, a component (e.g., filter assembly or impager the re-becomes necessary a leak-check shall be randucted inmodiately before the change is made. The leak-check shall be done according to the procedure outlined in Section 4.1.4.1 above, except that it shall be done at a vacuum squal to or greater than the maximum value recorded up to that point in the test. If the leak-age rate is bound to be no git. Fr than 0.0007 of min is 0.02 find or 4 percent of the average sampling rate (whichever is less, the results are acceptable, and no correction will need to be applied to the total volume of dry gus metered if, however, a higher leakage rate is obtained, the tester shall either record the loakage rate and plan to correct the sample volume as shown in Section 6.3 of this method, or shall void the sampling ruit.

section 6.3 of this method, or shall void the sampling rise.

Immediately after component changes, leak-checks are optional flanch look checks are done, the procedure outlined in Section 4.1.4.1 above shall be used.

4.1.4.3 That-leak leak-Check A leak-check is mandatory at the souchasion of each sampling run. The leak-check shall be done in accordance with the procedures outlined in Section 4.1.4.1 accept that it shall be conducted at a vacquim equal to or greater shan the maximum value reached during the sampling run. If the leak-check shall be done to accordance with the procedures outlined in Section 4.1.4.1, accept that it shall be conducted at a vacquim equal to or greater shan the maximum value reached during the sampling run. If the leaking rate is found to be no greater than 0.00057 m²/min. (0.02 cim) or 4 percent of the accept sampling rus (whichever is loss), the results are acceptable, and no correction need be applied to the total volume of dry gas metered. If, however, a higher leakage rate and correct the sample of the sampling run.

4.1.5 Particulate Train Section 6.3 of this inethod, or shall vind the sampling run.

4.1.6 Particulate Train Section 6.3 of this inethod, or shall vind the sampling run.

4.1.7 Particulate Train Sockmetic unless otherwise sampling run mandam an isokinetic sampling rune from the litter of 1.25±16° C (2.48+25° P), or such other temperature as specified by an applicable subjust of the mandards or approved by the Administrator.

For each run, record the data squired on a data sheet such as the nest sown in Figure 5. It is store to record the mind dry gas meter reading. Record the data sequence, when changes in flow rates are made, before and after each leak check, and when sampling is haited.

Take other readings required by Figure 5-2 at least once at each sample point during each time increment and additional readings when significant changes (20 percent ation in velocity head readings) necessitate additional adjustments in flow rate. Level and zero the lowester. Decause the manometer level and zero may due to vibrations and temperature changes, make necks during the traverse

PLANT

Clean the pertheles prior to the test run to minimise the chance of sampling deposited material. To begin sampling, remove the nossle cap, verify that the filter and probe heating systems are up to temperature, and that the pitot vulse and probe are properly positioned. Position the norske at the first traverse point with the tip pointing directly into the gas stream. Immediately start the pump and adjust the flow to isokinetic conditions. Notinggraphs are available, which aid in the capid adjust-

AMBIENT TEMPERATURE ___

ment of the isokinetic sampling rate without excessive computations. These nomographs are designed for use when the Type S priot tube coefficient is 0.85 ± 0.07 , and the stack gas equivalent density idry molecular weight is equal to 2.8 ± 0.4710 -0.05 details the procedure for using the nomographs M C_s and M_s are outside the above stated ranges do not use the nomographs unless appropriate Staps (see Citation 7 in Section 7) are taken to compensate for the deviations.

DOPERATOR DATE RUN NO. SAMPLE BOX NO. METER BOX NO. METER BOX NO. PITGT TUBE COEFFR			SCHEMATIC DE STACK PROSS SECTION				BAROMETRIC PRESSURE ASSUMED MOISTURE: % PROBE LENGTH, m (ft) NOZZLE IDENTIFICATION NO AVERAGE CALIBRATED NOZZLE DIAMETER, cm (in PROBE HEATER SETTING LEAK RATE, m³/min.(cfm) PROBE LINER MATERIAL STATIC PRESSURE, mm Hg (in, Hg) FILTER NO.			ASSUMED MOISTURE, N PROBE LENGTH, m (II) NOZZLE IDENTIFICATION NO. AVERAGE CALIBRATED NOZZI PROBE HEATER SETTING LEAK RATE, m³/min.(cfm) PROBE LINER MATERIAL STATIC PRESSURE, mm Ha (in, M			çm (in.)
TRAVERSE POINT	SAMPLING TIME	VACUUM mm Hg	5*ACK TEMPERATURE (Tg)	VELOCITY HL. O	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER mm HOO	GAS SAMPLE	E IMPLEMENT OF THE PARTY OF THE	TEMPERATURE GAS METER	FILTER HOLDER	TEMPERATURE UF GAS LEAVING CONDENSER OR LAST IMPINGER.			
NUMBER	(6), min.	(in. Hg)	eC (et)	mm:n H120	(in. H ₂ O)	m3 ((13)	*C (*F)	*C (*F)	*C (*F)	°C (*F)			
-													
	-												
			-	-					-				
			1	-	-								
TOTAL			1				Avg.	Avg.					

Figure 5-2. Particulate field data.

When the stack is under significant negative pressure

When the stack is under significant negative pressure fleight of impinger stam), take care to close the coarse adjust valve before inserting the probe into the stack to prevent water from backing into the filter holder. If measury, the pump may be turned on with the coarse adjust valve closed.

When the probe and porthole to prevent unrepresentative dilution of the gas stream.

Traverse the stack cross-section, as required by Methed I or as specified by the Administrator, being careful not to bump the probe noise institutes the stack walls when sampling near the walls or when removing or inserting the probe through the protholes; this minimizes the chance of extracting deposited material.

During the test run, make periodic adjustments to keep the temperature around the filter holder at the proper level, add more be and, if necessary, salt to maintain a temperature of less than 27°C 0.8°F flat the condenser/silice get outlet. Also, periodically check the level and zero of the manometer.

If the pressure drun across the filter becomes too high, making leskinetic sampling difficult to maintain, the liter may be replaced in the midst of a sample run, it is recommended that another complete lifer assembly be used rather than attempting to change the filter itself, before a new filter assembly is installed, conduct a leak-check usee Section 4.14.2). The total particulate weight shall include the summation of all filter assembly across the filter in cases whore simultaneous sampling is required in two or more separate ducts or at two or more different

A single train simil be used for the entire sample run-except in cases whore similariseous sampling is required in two or more separate ducts or at two or more different crations within the same duct, or, in cases where equip-ient failure necessitates a change of trains. In all other functions, the use of two or more trains will be subject to be approval of the Administrator.

Note that when two or more trains are used, separate analyses of the front half and if applicable imprises catches from each train shall be performed, unless identifications used to all trains, in which case, the front-half catches from the individual trains may be combined (as may the impringer ratches) and one analysis of front-half catch and one analysis of impringer catchings be performed. Consult with the Administrator for details concerning the calculation of results when two or more trains are used.

details concerning the calculation of results when two or more trains are used.

At the end of the sample run, turn off the coarse adjust valve, remove the probe and nortic from the stack, turn off the pump, record the fund dry kas meter reading, and conduct a post-lest lenk-sheek as outlined in Section 414.3. Also, leak-cheek the putot ince as described in Method 2, Section 3.1 the lines must pass this lask-cheek, in order to validate the velocity head data.

4.1.6 Calculation of Percent lask-netic Calculate percent isokinetic (see Calculations, Section 6) to determine whether the run was valid or another test run should be made. If there was difficulty in manipaining isokinetic rates due to source conditions, consult with the Administrator for possible variance on the mokinetic rates.

the Administrator for possible variance on the isokinetic rates.

4.2 Sample Recovery. Proper cleanup procedurategm as soon as the probe is removed from the stack at the end of the sampling period. Allow the probe to cool.

When the probe can be safety bandled, wipe off all external particulate matter near the tip of the probe mostle and place a cap over it is provent losing or gardina particulate matter. Do not cap off the probe tip lightly while the sampling train is coming down as the would create a vacuum in the filter builder, thus drawing water from the impligers into the filter builder.

Before moving the sample train to the cleanup filter remove the probe from the sample of the sample of the probes.

sillicone grease and cap the open nutlet of the probe. He careful not to see any condensate that might be present. Wipe off the timore grease from the filter inlet where the probe was furnished and cap it. Remore the timbulical coul from the last implinger and cap the impliguer. If a feather increase of the first impliner or condenser and the filter holder, disconnect the line at the differ holder disconnect the line at the differ holder of sometimes waster or liquid drain into the implicates or condenser. After wiping off the sincone grease, cap off the liter holder widels and impligate in it. Either ground-glass stoppers, plastic caps, or seen mostly as he used to close these openings.

Transfer the probe and filter in pager absorbily to the cleanup area. This area should be bean and protected from the wife to that the chances of contaminating or ioning the sample will be minimized.

Sawe a termin of the sections used for cleanup as a bians. I saw he missing the sample will the minimized.

It is a section of the sections used for cleanup as a bians. I saw he missinger and discount from the wash leastly be than a large.

late of a train prior to and during disassembly and frequent to train prior to and during disassembly and rote very a termal conditions. Treat the samples as follows

follows

Coordinate No. 1. Carefully remove the filter from the
filter modes and place at in its adminiscipetri dish conformer. Let a pair of tweezers and or simal disposable
surgood of a six to handle the filter. If it is necessary in
fold the mode is no such that the particulate case is
replaced to the product transfer to the perif dish any
particulate a siter and or filter filters which adhere to

proceedings in the random filter flaces which adhere to the filter it der pasket, by using a dry nylon bristle broch and it a sharp-edged blade. Seal the container. Container No. 8. Taking care to see that dust on the outside of the probe of other exterior surfaces does not get brig the sample, quantitatively recover particulate master of a viscoleusate from the probe norsie, probe

fitting, probe liner, and front half of the filter holder by washing these components with acctone and placing the wash in a glass container. Distilled water may be used instead of acctone when approved by the Administrator and shall be used when specified by the Administrator, in these cases, save a water blank and follow the Administrator's directions on analysis. Perform the acctone siness as follows:

and shall be used when specified by the Administrator; in these cases, save a water blank and follow the Administrator's directions on analysis. Perform the nectone insee as follows:

I arefully remove the probe nearle and clean the inside surface by finsing with a sylon bristole bush, acush until five accione riuse shows no visible particles, after which make a final riuse of the treathe author with accione. Brush and riuse the inside particles, after which make a final riuse of the inside particles, after which make a final riuse of the inside particles, after which make a final riuse of the inside particles, after which make a final riuse of the inside particles will be well accioned a racticles remain.

Riuse the probe there with accione by flying and rotating the probe while squaring accione the final rich lower end with necessary for an all inside surfaces will be well each into the sample container. A furnich where the lower end into the sample container. A furnich where the individual is the remainer. Follow the necessary first wich a probe location in both probe in an archived of pecture, square account into the upper end at the probe location is being pushed with a twisting action and the probe location is being pushed with a twisting action and the probe in a mater which is brushed from the probe far until the location function and the probe in a sample container and endeavour, the location and the probe in the probe for a wide in which is brushed from the probe for a rivered brushed mater is carried one with the passes of that forms and the probe in the invisit through in the salesy prescribed material and with situation mater is carried one with the passes of the problem of

the probe to minimize sample losses. Between sampling runs, keep brushes wan and protected from continuities from the probe to find containing that all joints have been waved lean of silicone grease, clean the morth of the front half of the filter holder by rubbing the surface is an electron filter holder by rubbing the surface is an electron filter holder by rubbing the surface is the garden brush and there by rubbing the surface is the gardene three lines or more if twethed to femera a subject particulate. Make a line ruce of the derivational dules he der. Carefully rime out the glass y late a sell larguistic for Carefully rime out the sample both and rubbing the container so that a steme win not leak out when it is shipped to the late starty. Mark the height of the find wise to determine whether of me leakage occurred duing the jost Labor the container to clearly identify its outcome.

Container No 2. Note the more of the independent of make a notation of its conductor of the strong more forth impurer to consiste the strong more forth minimer to be analysis a subject of the subject of the more point man may be used as an add in removing the subsace the analysis and the subject is that may adhere to the impuger wall and fare defend to comove the small amount of dust perturbed to remove that may adhere to the impuger wall and are defend to comove. Since the gain is weight is to be used for noisture calculation, do not see any ways of other inquids to transfer the since get life banden to which is in the last three impugers to within all may proper to be subjected on the field, follow the procedure for containers to within all may not a gravitation of any color or chamitate of the fillowing as.

Improper laster Treat the suppliers a before to within all may not a gravitation of the efficient gas.

Discard the liquid after measuring and recording the volume or seguit, unless suely as the monuter on a sheet such as the one shown in Figure is a liandice on a sheet such as the one shown in figure is a liandice on a

Plant	-
Date	
Run No.	
Filter No.	-
Amount liquid lost during transport	
Acetone blank volume, ml	-
Acetone wash volume, ml	minutes
Acetone blank concentration, mg/mg (equation 54)	-
Acetone wash blank, mg (equation 5-5)	-
	-

CONTAINER	WEIGHT OF PARTICULATE COLLECTED,						
NUMBER	FINAL WEIGHT	TARE WEIGHT	WEIGHT GAIN				
1							
2							
TOTAL			trapped of the season statement and the				

	VOLUME OF LIQUID WATER COLLECTED		
	IMPINGER VOLUME, ml.	SILICA WEIGH 9	
FINAL			
INITIAL			
LIQUID COLLECTED			
TOTAL VOLUME COLLECTED		g*	mi

^{*} CONVERT WEIGHT OF WATER TO VOLUME BY DIVIDING TOTAL WEIGHT INCREASE BY DENSITY OF WATER (1g/ml).

INCREASE, 9 = VOLUME WATER, mil 1 g/ml

Figure 5-3. Analytical data.

Alternatively the sample may be over dried at 100° C AF F: for 2 to 3 hours, cooled in the desiceator, and lighed to a constant weight, imbess otherwise specified the Administrator. The tester may also opt to over the sample, and use this "C. (220° F) for 2 to Jhours, weight he sample, and use this weight as a final weight. Conformer No F Note the level official in the container and conform on the analysis short whether or not leakage and conform on the analysis short whether or not leakage has one orred, either wood the sample or use methods, subject to the approval of the Administrator, to core-of the imal senits Measure the liquid in this container either volutherically to ±1 ml or reasistically to ±0.5 g. Transfer the rodiciant of a tared 250-ml beaker and exaperate to drynoss at ambient temperature and pressure. Desirept for 2a hours and weigh to a constant weight. Report the results to the heatest 0.5 g wasing a balance. This step may be conducted on the field.

"Accions Blank" Constance, Measure a clone in this container either voluthers to fire field.

"Accions Blank" Constance, Measure a clone in this container either voluthatocally or gravimetrically. Transfer the sectione to a tared 250-ml besker and evaporate to dryness at ambient temperature and pressure. Desirects for 24 hours and weight necessaries of 250-ml besker and evaporate to dryness at ambient temperature and pressure. Note,—At the option of the tester, the contents of Container No. 2 as well as the accions blank container may be evaporated at temperatures higher than ambient file container in a section in the contents of the tester than ambient in a section in the entered as an electric temperature files over a single point of the solvent also, to prevent "Dumpong," the evaporation process must be closely supervised, and the contents of the heater must be desired occasionally to maintain an inventemperature. I se extreme care, as sections is highly assumable and has a low flash point.

5. Callera.

5. Calibra, on

Maintain a laboratory log of all calibrations.
5.1 Probe Nortic, Frobe nortics shall be calibrated before their initial use in the field. Using a micrometer, measure the inside discreter of the nortic to the nearest.

0.025 mm (0.001 in.). Make three separate measurements using different measurements each time, and obtain the average of the measurements. The difference between the high and low numbers shall not exceed 0.1 mm (0.64 m). When nozzies become nicked, derited, or corroded, they shall be reshaped, sharpened, and recalibrated before Each norzie shall be permanently and uniquely

identified.

5.2 Fitot Tube. The Type Spitot tube ascendly shall be califiated according to the procedure outlined in Section 4 of Method 2.

Section 4 of Method 2.

5.3 Metering System. Before its initial use in the field, the metering system shall be calculated according to the procedure outlined in APTD-6.5. Instead of physically adjusting the dry gas meter dial readings to correspond to the vet test meter readings, calibration factors may be used to mathematically correct the gas meter dial readings to the proper values. Before calibrating the metering system, it is suggested that a back-check be conducted. For metering systems having diaphragm pumps, the normal leak-check procedure will not detect leakages within the pump. For these cases the following leak-check procedure is suggested, make a 40-minute calibration tun at 0.00007 m Juni 10.02 chm); at the end of the run, take the difference of the measured wet test meter and dry gas meter volumes; divide the difference by 10, to get the leak rate. The leak rate should not exceed 0.00057 in Vinio (0.02 chm).

After each field use, the calibration of the metering

0.00057 in Vinin (0.02 cfm).

After each field use, the calibration of the netering system shall be checked by performing three calibration runs at a study, intermediate article setting thased on the previous field test), with the vacuum set at the maximum value reached during the test series. To adjust the vacuum, insert a valve between the wet test meter and the inlet of the interior system. Calculate the average value of the calibration factor. If the calibration has changed by more than 5 percent, recalibrate the meter over 'e full range of unifice settings, as outlined in APTD 4576.

After ative procedures, e.g., using the orifice meter selficients, may be used subject to the approval of the

Note:—Afthodry gas motor coefficient values obtained before and after a test series differ by more than 5 percent, the test series shall either be voided, or calculations for the test series shall either be voided, or calculations for the test series shall be performed using whichever motor coefficient value of e. before or after) gives the lower value of total sample volume.

5.4 Probe Heater Calibration. The probe heating system shall be calibrated before its initial use in the field according to the procedure outlined in APTD-6581 need not be calibrated if the calibration curves in APTD-6576 need not be calibrated if the calibration curves in APTD-6576 needs.

are used.

5.5 Temperature Gauges. Use the procedure in Section 4.3 of Method 2 to calibrate in stack temperature gauges. Dist thermometers, such as are used for the dry gas meter and condenser outlet, shall be calibrated against meroury in-glass thermometers.

against mercury-in-glass thermometers.

5.6 Leak Check of Metering System Shown in Figure
5.4. That portion of the sampling tean from the pump
to the oritice meter's bould be leak checked prior to initial
use and after each shipment. Leakage after the pump will
result in less volume being recorded than is actually
sampled. The following procedure is suggested (see
Figure 5-6). Close the main valve on the meter box.
Lisert a one-hole rubber stopper with rubber tubing
attached tole the ordice exhaust pipe. Disconnect and
well the low side of the exhibit manometer. Close off the
low side ordice tap. Pressgrize the system to 13 to 18 on
to 15 to 7 in.) water column by blowing into the rubber
tubing. Finch off the tubing and observe the manometer
for one manute. A loss of pressure on the manometer
indicates a leak in the meter box, leaks, if present, must
be corrected.

5.7 Barometer. Calibrate against.

5.7 Barometer Calibrate against a mercury barom-

6. Calculations

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after the final calculation. Other forms of the quations may be used as long as they give equivalent




Figure 5-4. Leak check of meter box.

8.1 Nomenclature
 A. = Cross-sectional area of nozzle, m² (fi²),
 B. = Water vapor in the gas stream, proportion

by volume.

A cetone blank residue concentrations, mg/g.

Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, g/dsem ig/dsem.

Percent of isokinetic sampling.

Masimum acceptable leakage rate for either a pretest leak theck following a component change, equal to 0.000%7 ml/min (0.02 cfm) or 4 percent of the average sampling rate, whichever at less.

Individual leakage rate observed during the leak check conducted prior to the "star component change (i=1, 2, 3 ..., s), in the infinity of the component change (i=1, 2, 3 ..., s).

Leakage rate observed during the post-test leak theck, m² man (cfm).
 Total amount of particulate matter collected,

"Molecular weight of water, 180 g/g-mole (18 0 lb lb-mole).

*Mass of recidue of scetone after evaporation.

mg.

Birometric pressure at the sampling site, mrn Hg (in, Hg).

Absolute stack gas pressure, min Hg (in, Hg).

Standard absolute pressure, 760 mm Hg (29.92 in Hg).

Mideal gas constant, 0.06236 mm Hg-m¹/₂°K-g-mole (2l.85 in. H₂-th²/₂°R-th-mole).

A baclute average dry gas meter temperature (see Figure 5-2), "K (°R).

A baclute average stack gas temperature (see Figure 5-2), "K (°R).

Standard absolute temperature, 203" K (526°R). \boldsymbol{R}

 $T_{\rm std}$

V. Volume of acctone blank, mi.
V. Volume of acctone used in wash, mi.
V. Volume of acctone used in wash, mi.
V. Total colume of liquid collected in impingers and silice acl (see Figure 5-3), mi.
V. Volume of gas sample as measured by dry gas meter, dem (dcf).
Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscin (dcf).

deem (deef)

V*(m) = Vulums of water vapor in the gas sample, corrected to standard conditions, som (sef).

V, = Stack gas velocity, calculated by Method 2, Equation 2.9, using data obtained from Method 5, misec (fitses).

W*= Weight of residue in sectone wash, mg. 7 = Dry gas meter calibration factor.

All = Average pressure differential across the orifice meter (see Figure 5.2), num 1150 (in H₂O), s.= Density of sectone, mg.mi (see label on bottle).

e=Pensity of water, 0.9982 g/ml (0.992201 ib/ml).

#=Total sampling time, min.

Sampling time interval, from the beginning of a run until the first component change,

#. - Sampling time interval, between two successive component changes, beginning with the interval between the first and second

#, Samphing time interval, from the final (n/s) component change until the end of the sampling run, min 13 6 Specific gravity of mercury.

60 = Sec/min 100 = Conversion to percent

6.2 Average dry gas meter temperature and average orthoc pressure drop. See data sheet (Figure 5-2), 6.3 Dry Oas Volume. Correct the sample volume measured by the dry gas neter to standard conditions (20° C, 766 mm Hg or (8° F, 29.92 in Hg) by using Equation 5-1.

$$\begin{split} V_{m,(\bullet,1)} &= V_m Y \left(\frac{T_{\bullet,0}}{T_m} \right) \left[\frac{P_{bo} + \frac{\Delta H}{13.6}}{P_{\bullet,0}} \right] \\ &= K_1 V_m Y \frac{P_{bo} + (\Delta H/13.6)}{T_m} \end{split}$$

Equation 5-1

m=0.3858 K/mm Hg for metric units =17.64 R/m. Hg for English units

Note.—Equation 5-1 can be used as written unless heakage rate observed during any of the mandatory leak checks (i.e., the post-test leak check or leak checks conducted prior to component changes, exceeds L_s. If E_s or L. exceeds L_s. Equation 5-1 must be modified as follows:

(a) Case I. No component changes made during mampling run. In this case, replace I . in Equation 5-1 with the expression;

$$V_{\bullet} - (L_{\bullet} - L_{\bullet})\theta \}$$

(b) Case II One or more component changes made during the sampling run. In this case topics V_{\bullet} in Equation 5-1 by the expression

$$\begin{split} \begin{bmatrix} V_{\bullet} + (L_i - L_{\bullet})\theta_1 \\ & - \sum_{i=0}^{n} (L_i - L_{\bullet})\theta_i - (L_i - L_{\bullet})\theta_{\theta} \end{bmatrix} \end{split}$$

and substitute only for those leakage rates (L. or L_{π}) which exceed i.

64 Volume of water vapor.

$$V_{s'(s)d} = V_{1s} \left(\frac{\rho_u}{M_s} \right) \left(\frac{RT_{std}}{P_{std}} \right) = K_2V_1,$$

Where:

K1=0 001333 mbml for metr): units
=0.04707 ft*and for English mats
6.5 Moisture Content.

$$B_{e,\mathbf{z}} = \frac{V_{\mathbf{w},(\mathbf{z}),0}}{V_{\mathbf{w},(\mathbf{z}),0} + V_{\mathbf{w},(\mathbf{z})}} \ .$$

Equation 5-3 6.11 I Sokinetic Variation.

Equation 5-3 6.11.1 Calculation From Raw Pata

$$I = \frac{100 \ T_{\star} [K_{\star} V_{1\star} + (V_{m} / T_{m}) \ (P_{b\star}, + \Delta H / 13.6)]}{60 \, \ell v_{\star} P_{\star} A_{\star}}$$

There $E_{x}=0.0034/4$ mm Hg $-0.5/\mathrm{ml}^{-3}\mathrm{K}$ for metric units =0.002030 in, Hg $-10/\mathrm{ml}^{-3}\mathrm{R}$ for Fig.1sh units. 6.11.2 Calculation From Intermediate Values.

$$I = \frac{T_* V_{\text{m (sid)}} P_{\text{sid}} 100}{T_* \text{od } t_* \theta A_* P_* 60(1 B_*)}$$
$$= K_* \frac{T_* V_{\text{m (sid)}}}{P_* V_* A_* \theta (1 - B_*)}$$

where: $K_i = 4.320$ for metric units = 0.09450 for English units. = 0.09450 for English units. 6.12 Acceptable Results. If 90 percent $\leq I \leq 110$ percent, the results are acceptable. If the results are low in comparison to the standard and I is beyond the acceptable range, or, if I is less than 90 percent, the Administrator may opt to accept the results. Use Citation 4 to make judgments. Otherwise, reject the I-cults and repeat the test.

7. Billingraphy

1. Andendum to Specifications for Incherator Testing at Federal Facilities. PHS, NCAFC, Dec. 6, 1967.

2. Martin, Robert M., Construction Details of Isokinetic Source-Sampling Equipment. Environmental Protection Agency. Research Triangle Park, N.C. APTD-0581, April, 1971.

3. Rom, Jerome J. Mainterance, Calibration, and Operation of Isokinetic Source Sampling Equipment. Environmental Protection Agency. Research Triangle Park, N.C. APTD-0578, March, 1972.

4. Smith, W. S., R. T. Shigehara, and W. F. Todd. A Method of Interneting Stack Sampling Data, Paper Presented at the 53d Annual Meeting of the Air Pollution Control Association, St. Lauis, Mo. June 14-19, 1970.

5. Smith, W. S., et al. Stack Gas Sampling Improved and Simplified With New Equipment. AFCA Paper No. 67-119, 1967.

6. Specifications for Incinerator Testing at Federal Facilities. PHS, NCAPC, 1967.

7. Shigenara, R. T. Adjustments in the EFA Nomograph for Different Pitot Tube Coefficients and Dry Molecular Weights. Stack Sampling News £4-11. October, 1974.

Nove.—In saturated or water droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one from the impinger analysis (Equation 5-2), and a second from the assumption of asturated conditions. The lower of the two values of $H_{\rm sc}$ shall be considered correct. The procedure for determining the moisture content tassed upon assumption of asturated conditions is given in the Note of Section 1.2 of Method 4. For the narrowses of this method, the a orage stack gas temperature from Figure 5-2 may be used to make this determination, provided that the accuracy of the in-stack temperature suisor is \pm 1° C (2° F.).

$$C_{\mathfrak{a}} = \frac{m_{\mathfrak{a}}}{V_{\mathfrak{a}, \ell, \mathfrak{a}}}$$

Equation 5-4

Equation 5-6

6.7 Avetoric Wash Blan ...

" $W_{\bullet} = C_{\bullet} V_{\bullet}, \rho_{\bullet}$

Equation 5-5

Equation 5-5

Equation 5-5

Equation 5-5

Equation 5-6

Particulate catch from the sum of the weights obtained from containers 1 and 2 less the acctone blank (see Figure 5-3). Note.—Refer to Section 4-1.5 to assist in resimilation of results involving two or more filter assemblies or two or more sampling trains.

E.9 Particulate Concentration.

$$c_* = (0.001 \ g/mg) \ (m_n/V_{m.(ard)})$$

6 10 Conversion Factors.

Frem	To	Multiply by			
sei g/(18 g/12	m ² gr/1; 3 11:/1; 2 g/m ²	0, 02832 15, 43 2, 205 ×10 ⁻⁴ 35, 31			

8. Vollare, R. P. A Survey of Commercially Available Instrumentation. For the Scanurement of Low-Range Gas Velocities, U.S. Environmental Protection Agency, Emission Measurement Branch. Research Triangle Park, N.C. November, 1976 (unpublished paper). 9. Acquiat Book of ASTM Standards. Part 29. Gaseous Fuels, Coal and Coke, Atmospheric Analysis, American Footety for Testing and Muterials. Philadelphia, Pa. 1974, pp. 617-622.

Mittion 6-Dittems this by Stiffe Digatic

Equation 5-8 1. Principle and Applicability

1.1 Principle. A gas sample is estracted from the sampling point in the stack. The sulfure soid mist (including sulfur trioxide) and the sulfur dioxide are separated. The sulfur dioxide fraction is measured by

separated. The sulfur dioxide fraction is measured by the barium-thorin tiration method.


1.2 Applicability. This method is applicable for the determination of sulfur dioxide emissions from stationary sources. The intimium detectable limit of the insthod has been determined to be 3.4 milligrams (ing) of SO₂m³ (2.42×10⁻³ 15/4.5). Although no upper limit has been established, tests have shown that concentrations as high as 80.000 mg/m³ of SO₂ can be collected efficiently in two midget implineers, each containing 15 milliliters of 3 percent hydrogen persoite, at a rate of 1.0 pm for 20 minutes. Based on theoretical calculations, the upper concentration limit in a 20-liter sample is about 93,300 mg/m³.

concentration limit in a 20-liter mample is about \$0,300 mams.

Possible interferents are free ammonia, water-soluble cations, and fluorides. The cations and fluorides are removed by glass wool litters and an isopropanol bubbler, and hence do not affect the Sty analysis. When samples are being taken from a gas stream with high concentrations of very fine metallic times (such as in inlets to control devices), a high-efficiency glass fiber filter must be used in place of the glass wool plug it.e., the one is the probe) to remove the cation interferents.

Free ammonia interferes by reacting with SO, to form particulate sulfits and by reacting with SO, to form particulate sulfits and by reacting with the indicator. If free ammonia is present (this can be determined by knowledge of the process and noticing white particulate matter in the probe and isopropanol bubbler), salarmative methods, subject to the approval of the Administrator, U.S. Environmental Protection Agency, are required.

2. Apparatus



2.1 Sampling. The sampling train is shown in Figure 6-1, and component pacts are discussed below. The tener has the option of substituting sampling equipment described in Method 8 in place of the midget impinger equipment of Method 8. However, the Method 8 train must be modified to include a heated filter between the probe and isopropanol impinger, and the operation of the sampling train and sample analysis must be at low rates and solution volumes defined in Method 8. Lestor also has the option of determining 80; suitaneously with particulate matter and moisture determinations by (1) replacing the water in a Niethod 5 impinger system with 3 percent perionide solution, or (2) by replacing the Method 5 water impinger system with a Method 5 water impinger system with a Method 5 water impinger system. The analysis for 80; must be consistent with the procedure in Method 8.

2.1.1 Probe. Borosilicate glass, or stainless steel (other materials of construction may be used, subject to the

2.1.1 Frobe. Bornstlicate glass, or stainless steel (other materials of construction may be used, subject to the approval of the Administrator), approximately 6-min inside diameter, with a heating system to prevent water condensation and a filter (either in-tack or heated outstack) to remove particulate matter, including sulfurious did mist. A plug of glass wool is a satisfactory filter.

2.1.2 Bubbler and Impingers. One midget builtier, with medium-coarse glass frit and horosiheste or quartz glass wool packed in top (see Figure 6-1) to prevent sulfuric acid mist carryover, and three 39-mil midget impingers. The bubbler and midget impingers must be connected in series with leak free glass connectors. Silicone grease may be used, if necessary, to prevent instance. At the option of the tester, a midget impinger may be used in piace of the midget bubbler. Other collection absorbers and flow rates may be used, but are subject to the approval of the Administrator. Also, collection efficiency must be shown to be at least 80 percent for each test run and must be documented in the report. If the efficiency is found to be acceptable after a series of three tests, further documentation is not required. To conduct the efficiency seven, in extra absorber must be added and analyzed -parastely. This error absorber must not contain more than 1 percent of the total ROn.

2.1.3 Glass Wool, Borosilicate or quarts.

the total ROs.

21.3 Glass Wool, Bornellicate or quarts.

21.4 Stopcock Grasse. Acatone insoluble, heatble silicone gresse may be used, if necessary.

5 Temperature Gauge. Dial thermometer, or
braient, to measure temperature of gas leaving imfer train to within 1° C (2° F.)

21.6 Drying Tube. Tube packed with 6-to 16-mesh
indicating type silica gel, or equivalent, to dry the gas

sample and to protect the meter and pump. If the siliac gel has been used previously, dry at 175° C (350° F) for 2 hours. New silica gel may be used as received. Alternatively, other types of desiccants (equivalent or better) may be used, subject to approval of the Administrator.

21.7 Value. Needle value, to regulate sample gas flow

may be used, subject to approval of the Administrator.

2.1.7 Value. Needle value, to regulate sample gas flow

2.1.8 Pump. Leak-free disphragm pump, or equivalent, to pull gas through the train. Install a small tank
between the pump and rate meter to eliminate the
pulsation effect of the disphragm pump on the rotameter.

2.1.9 Rate Meter. Rotameter, or equivalent, orpanile
of measuring flow rate to within 2 percent of the selected
flow rate of about 1030 comin.

2.1.10 Volume Meter. Dry gas meter, anticlently
accurate to measure the sample volume within 2 percent,
calibrated at the selected flow rate and conditions
actually encountered during sampling, and equipped
with a temperature gauge (dial thermometer, or equivelent) capable of measuring temperature to within
3°C (5.4°F).

2.1.11 Barometer. Mercury, ameroid, or other barometer capable of measuring almospheric pressure to within
2.5 mm Fig (0.1 in Hz). In many cases, the barometric
reading may be obtained from a nearby national weather
service station, in which case the station value (which
is the absolute harometric pressure) shall be requissed
and an adjustment for elevation difference believed
the weather station and sampling point shall be applied
at a rate of minus 2.5 mm Hg (0.1 in Hg) per 20 m (10.4)
elevation increase or vice versa for elevation decrease.

2.1.12 Vaccum Gauge. At least 760 mm Hz (30 in
Hg) gauge, to be used for lenk check of the sampling
2.2. Sample Recovery.

2.2. Sample Recovery. 2.2.1 Wash bottles. Polyethylene or glass, 500 ml.

1wo. 222 Storage Bottles, Polysthylene, 100 ml, to store

2.2.2 Storage Battles, Polytonia, 12.3 Analysis, 2.3.1 Pipettes, Volumetric type, 5-mi, 20-mi (one per sample), and 25-mi sites, 2.3.2 Volumetric Flasks, 100 mil size (one per sample)

2.3.2 Volumetric rises.
2.3.3 Furettes 5- and 50-ml sizes.
2.3.4 Erlenneyer Flacks. 2.0 ml-size (one for each sample, blank, and standard).
2.3.5 Dropping Bottle. 125-ml size, to add indicator.
2.3.6 Graduated Cylinder 100-ml size.
2.3.7 Spectrophotometer. To measure absorbance at

\$52 nanometers

Unless otherwise indicated, all reagents must conform to the specifications established by the Committee on Analytical Reagents of the American Chemical Society Where such specifications are not available, use the best available grade.

available grade.

3.1. Sampling.

3.1.1 Water Delonised, distilled to conform to ASTM specification Dil93-74. Type 3. At the option of the analyst, the KMn03 test for oxidisable organic matter may be ountied when high concentrations of organic matter are not expected to be present.

3.1.2 isopropanol, 80 percent. Mix 80 ml of isopropanol with 20 ml of decoursed, distilled water. Check each lot of isopropanol for perovide impurities as kollows shake 10 ml of isopropanol with 10 ml of freshly prepared 10 percent polassium iodide solution. Prepare a biank by similarly treating 10 ml of distilled water. After 1 minute, read the absorbance at 352 nanometers on a spectrophotometer. If absorbance exceeds 0.1, reject sicohol for 185.

photometer. If also bance exceeds 0.1, reject alcohol for the peroxides may be removed from isopropanol by redistilling or by phasage through a column of activated alumna, however, reagent crade isopropanol with suitably low peroxide levels may be obtained from commercial sources. Rejection of contaminated lots may, therefore be a more efficient procedure.

2.1.3 Hydrogen Peroxide 3 Percent. Dilute 30 percent hydrogen peroxide 1.9 (x/y) with deionized, distilled water 49 ml is needed per sample). Prepare fresh daily, 3.1.4 Potassium lodide solution, 10 Percent Dissolve 10.0 grams K1 in deionized, distilled water and dilute to 10 ml. Prepare when needed.

3.2 Sample Receivery, 3.2.1 Water. Deionized, distilled, as in 3.1.1.

3.2.2 Isopropsinol, 80 Percent. Mis 80 ml of isopropsinol with 20 ml of deionized, distilled water.

3.3 Analysis.

Analysis Water Deionized, distilled, as in 2.1.1

331 Water Deionized, distribut, as in --332 Isopropanol, 160 percent.
233 Thorin Indicator I-to-arsonophenylazo)-2naphthol 3.6-disulfonic acid, disodium salt, or equivanaphthol 3.6-disodium salt, or equivanaphthol 3.6-dis

while.

3.3.4 Barium Perchlorate Solution, 0.0100 N. Dissolve 1.05 g of barium perchlorate tribydrate [BacClOs):
31150 in 200 ml distilled water and dilute to 1 liter with soproponol. Alternatively, 1.22 g of [Bach: 238-9] may be used instead of the perchlorate. Standardize as in Section 8.5.

2.3.5 Bulfuric Acid Standard, 0.0100 N. Purchase or standardise to #0.0002 N. against 0.0100 N. NaOH which hand previously hern standardised against potassium seld phthalate (primary standard grade).

4 Procedure

4.1 Sampling.
4.1.1 Preparation of collection train. Measure 15 ml of 80 percent isopropanol into the midget bubliler and 15 ml of 3 percent hydrogen percented into each of the first two midget impingers. Leave the final midget impinger dry. Assemble the train as shown in Figure 6-1 Adjust probe heater to a temperature sufficient to prevent water condensation. Place crushed ice and water around the

impingers.

4.1.2 Leak-check procedure. A leak check prior to the sampling run is optional, however, a leak check after the sampling run is mandatory. The leak-check procedure is

With the probe disconnected, place a vacuum gauge at

sampling run is optional, however, a leak check after the sampling run is mandatory. The leak check procedure is as follows:

With the probe disconnected, place a vacuum gauge at the inlet to the bubbler and gold a vacuum of 250 mm (30 in.) Hg; plug or pinch off the outlet of the flow meter, and then turn off the pump. The vacuum shall remain stable for at least 30 seconds. Carefully release the vacuum gauge before releasing the flow meter end to prevent back flow of the impinger find.

Other leak check procedures may be used, subject to the approval of the Administrator. U. S. Environmental Protection Agency. The procedure used in Method 5 is not suitable for disphragm pumpe.

4.1.3 Hample collection. Record the initial dry gas meter reading and barometric pressure. To begin sampling, position the tip of the probe at the sampling point, connect the probe to the bubbler, and start the pump. Adjust the sample flow to a constant rate of approximately 10 literimin as indicated by the retemeter Maintain this constant rate (=10 percent) during the entire sampling run. Take readings (dry gas meter, temperatures at dry gas meter and at impunger outlet and rate meter) at least every 5 minutes. Add more ice during the last impinger at 20° C (5% Fl.or less. At the conclusion of each run, turn off the pump, remove probe from the stack, and record the final readings. Conduct a leak check as in Sections 1.2 (This leak otherk is mandatory.) If a leak is found, wold the test run brain the less bath, and purge the remaining part of the trun by drawing clean ambient air through the system for 18 minutes at the sampling rate.

Clean ambient air can be provided by passing air through a charcoal filter or through an error midget impinger with 15 ml of 3 tercent H.O. The tester may opt to simply use ambient air, without purification.

4.2 Sample Recovery. Disconnect the impingers after purging Discard the contents of the mater the time midget impingers and the connecting tubes with delonised, distilled water, and add the washings t

(Norg.—Protect the 0.0100~N barium perchlorate solution from evaporation at all times.)

6. Outlbretton

5.1 Metering System.
5.1.1 Initial Calibration. Before its initial use in the field, first leak check the metering system drying tube, needle valve, pump, rotameter, and dry gas meter) as

follows: place a vacuum gauge at the inlet to the drying tube and pull a vacuum of 250 mm (10 in.) Hg; plug or pinch off the outlet or the flow meter, and then tun off the pump. The vacuum shall remain stable for at least 30 seconds. Carefully release the vacuum gauge before releasing the flow meter and

30 seconds. Carefully release the vacuum gauge before releasing the flow meter end.

Next, calibrate the metering system (at the sampling flow rate specified by the method) as follows: connect an appropriately sized wet test mater (e.g., 1 liter per revolution) to the inlet of the drying tybe. Make three independent calibration runs, using at least five revolutions of the dry gas meter per run. Calculate the calibration specified in the result of the dry gas meter per run. Calculate the calibration factor. Y (wet test meter calibration volume divided by the dry gas meter volume, both volumes adjusted to the same reference temperature and pressure), for each run, and average the results. If any Y value deviates by more than 2 percent from the average, the metering system is unacceptable for use. Otherwise, use the average as the calibration factor for subsequent test runs.

5.1.2 Post-Test Calibration Check, After each field test series, conduct a calibration check as in Section 5.1.1 above, eacept for the following variations: (a) the leak

test series, conduct a calibration check as in Section 5.1.1 above, except for the following variations: (a) the lend check is not to be conducted, (b) three, or more revolutions of the dry gas meter may be used, and (c) only two independent runs need be made. If the calibration factor does not deviate by more than 5 percent from the initial calibration factor (determined in Section 5.1.1), then the dry gas meter volumes obtained during the test series are acceptable. If the calibration factor deviates by more than 5 percent recalibrate the metering system as in Section 5.1.1, and for the calculations, use the calibration factor (initial or recalibration) that yields the lower gas volume for each test run.

5.2. Thermometers. Calibrate against mercury-ingless thermometers.

glas thermometers.

5.3 Rougneter. The rotameter need not be calibrated 5.3 Rounneter. The rotaineter need not be calibrated but should be cleaned and maintained according to the manufacturer's instruction.

5.4 Barometer, Calibrate against a mercury barom-

5 Barium Perchlorate Solution, Standardize the barium perchlorate solution against 25 ml of standard suilure acid to which 100 ml of 100 percent isopropanol has been added.

6 Calculations

Carry out calculations, retaining at least one extra dec mai figure beyond shat of the acquired data. Round of figures after final calculation. of Nomenciature.

Co. = Concentration of sulfur dioxide, dry basis corrected to standard conditions, ingedeen (thicker).

N=Normality of basium perchiante titraut, milliequivatents mil.

Pan = Barometric pressure at the exit orifice of the dry gas meter non-life (in. Hg).

Pan = Standard absolute pressure, 760 mm Hg (20.07 in. Hg).

T = Average dry gas meter absolute temperature, "K (* H).

*K (*R).

Trad *Standard absolute temperature, 705° K (525° R).

V=*Volume of sample aliquot titrated, mi.

V=*Dry gas volume as measured by the dry gas meter, dorn defin.

Dry gas volume measured by the dry gas meter, corrected to standard conditions, daem (dscf).

V**solume Total volume of solution in which the sulfur dioxide sample is contained, 100 mi.

V**solume of barium perchlorate titrant used for the sample, mi (average of replicate titrations).

V**solume of barium perchlorate titrant used.

titrations).

Vis=Volume of barium perchiorate titrant used for the blank, mi
Y=Dry gas meter-calibration factor.

32.63 = Equivalent weight of sulfur dioxide.

2 Dry sample gas volume, corrected to standard divisors.

conditions. $V_{\text{m (s/d)}} = V_{\text{m}} Y \left(\frac{T_{\text{sid}}}{T_{\text{m}}} \right) \left(\frac{P_{\text{bar}}}{P_{\text{sid}}} \right) = K_1 Y \frac{V_{\text{m}} P_{\text{bar}}}{T_{\text{m}}}$

K₁=0 388 ° K mm Hg for metric units. =17.84 ° R in. Hg for English units. 6.3 Sulfur dioxide cencentration.

$$C_{\text{BO}_2} = K_2 \frac{(V_i - V_{ib}) N \binom{V_{\text{cole}}}{V_e}}{V_{\text{m(cold)}}}$$

Equation 6-2

 $K_{\rm P}$ = 32.63 inv/meq. for metric units. = 7.661 × 10⁻³ 1b/meq. for English units.

7. Dibliography

Atmospheric Emissions from Sulfuric Acid Manufacturing Processes. U.S. DHEW, PHS. Division of Air Pollution.
 Public Health Service Publication No. 985-AP-13. Cincinnat, Ohio. 1965.
 Corbett, P. F. The Determination of SO₃ and SO₃ in Fluc Gases. Journal of the Institute of Fuel. 64: 237-243. 1963.

243, 1961.
3 Matty, R. E. and E. K. Diehl, Measuring Flue-Gas RO, and SOs. Power. 101: 94-97. November 1957.
4 Patton, W. F. and J. A. Brink. Jr. New Equipment and Techniques for Sampling Chemical Process Gases.
J. Air Pollution Control Association. 15: 162, 1963.
5 Rom, J. J. Maintenance, Calibration, and Operation Isode interior Source-Sampling Equipment. Office of Air Programs, Environmental Protection Agency. Research Triangle Park, N.C. APTD-0576. March 1972.
6 Hamil, H. F. and D. E. Cempan, Collaborative.

6 Hamil, H. F. and D. E. Camann. Collaborative Study of Method for the Determination of Suffur Dioxide Emissions from Stationary Sources (Fossil Fuel Fired Stram Generators). Environmental Protection Agency, Research. Triangle. Park, N.C. EPA-650/4-74-024.

7. Annual Book of ASTM Standards. Part 31; Water, trunsuberic Analysis, American Society for Testing Atmospheric Analysis, American Society for and Materials, Philadelphia, Fa. 1974, pp. 40-42.

8 Knoll, J. F. and M. R. Midgett. The Application of EFA Method 6 to High Sulfur Dioxide Concentrations. Environmental Protection Agency. Research Triangle Park, N.C. EFA 6004 78-038, July 1976.

T-DETERMINATION OF NITROGEN URIDE

1. Principle and Applicability

1.1 Principle A grab sample is collected in an evacuated flash containing a disate suffurio acid-hydrogen peroxide absorbing solution, and the introgen oxides, accept nitrous oxide, are measured colorinaterically using the phenoidisuifonic acid (PDB) procedure.

using the phenoidisationic acid (FDS) procedure.

1.2 Applicability. This method is applicable to the measurement of nitrogen oxides emitted from stationary sources. The range of the method has been determined to be 2 to 400 milligrams NO₂ (as NO₂) per dry standard cubic meter, without having to dilute the sample.

2. Apparatus

2.1 Sampling (see Figure 7-1). Other grab sampling systems or equipment, capable of measuring sample volume to within ±2.0 percent and collecting a sufficient sample volume to allow analytical reproducibility to within ±5 percent, will be considered acceptable alternatives, subject to approval of the Administrator, U.S. Environmental Protection Agency. The following equipment is used in sampling:

equipment is used in sampling:

2.1.1 Probe. Borosibinate glass tubing, sufficiently
beted to prevent water condensation and equipped
with an in-stack or out-stack filter to remove particulate
matter (a plug of glass wool is satisfactory for this
purpose). Stanties steed or Tefon * tubing may also be
used for the probe. Heating is not necessary if the probe
remains dry during the purging period.

^{*} Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.




Figure 7-1. Sampling train, flask valve, and flask

2.1.2 Collection Flask Two-liter borosilicate, round boxiom flask, with abort neck and 24:40 standard taper genuiz, producted against implosion or breakase.

2.1.3 Flask Valve, T bore stopcick connected to a 4-0 standard taper joint.

2.1.4 Temperature disage. Dial-type thermometer, or other emperature gause, capable of measuring 1° C 2° F intervals from -5 to 8° C (2° to 125° F).

2.1.5 Vacuum Line Tubing capable of withstanding a section of 5 mm Hg (3° n. Hg) atsolute pressure, with -7° connection and T bore stopcock.

2.1.6 Vacuum Gause. Utube manometer, 3 meter (28° 10.), with 1 mm (0.1-n.) divisions, or other gause capable of measuring pressure to within ±2.5 mm Hg (9.10) in Hg).

2.1.7 Pump. Capable of evacuating the collection. 2.17 Pump. Capable of evacuating the collection. Hg. 2.17 Pump. Capable of evacuating the collection. Hg. assolute. 2.18 Squeeze Built. One-way. 2.19 Volumetric Hyp. tie. 25 m. 2110 Stopaula.

2.18 Squeeze Bulb. One-way
2.19 Volumetric Pipt tie. 25 ml
2.10 Stopick and Ground Jaint Grease. A highrecurson, high-temperature chlorofluorocarbon greace is
required. Halocarbon 25-85 has been found to be effective.
2.111 Farometer Mercury, ancroid, or other baromever capable of measuring atmospheric pressure to within
2.5 mm Hg (0.1 m. Hg). In many cases, the barometric
reacting may be obtained from a nearby mational weather
service station, in which case the station value (which is
the absolute barometric pressure) stuff be requested and
an adjustment for circation differences between the
weather station and samoling point shall be applied at a
ratio of minus 2.5 mm Hg (0.1 m. Hg) per 30 m (10) for
existion increase, or vice versa for elevation decrease.
2.2 Sample Recovery. The following equipment is
required for sample recovery.
2.11 Graduated Cylinder 50 ml with 1-ml divisions.
2.22 Storage Containers. Leak free polyethylene
bottles.

bottles. 2.23 Wash Bottle Polyethylene or glass.

Glass Surring Rost.
Test Paper for Ir dicating pH. To cover the pH.

Analysis. For the analysis, the following equipent is needed

2.3.1 Volumetric Pipettee. Two 1 ml, two 2 ml, one ml, one 4 ml, two 10 ml, and one 25 ml for each sample and standard.

2.3.2 Porceiain Evaporating Dishes. 175- to 250-mi capacity with hip for pouring, one for each sample and each standard. The Coors No. 45000 (shallow-form, 195-mi) has been found to be satisfactory. Alternatively, polymethyl pentene beaters (Naige No. 1203, 150 mi), or glass beaters (150 mi) may be used. When glass beakers face vied, etching of the beakers may cause solid matter to be present in the analytical stem, the solids should be removed by filtration (see Section 4.3).

2.3.3 Steam Bath, Low-temperature overs or thermosed by filtration (see Section 4.3).

2.3.4 Dropping Flortie or Propper. Three required 2.3.5 Polyethylene Policeman. One for each sample and each standard.

2.3.6 Graduated Cylinder, 100 ml with 1-ml divisions, 2.3.7 Volumetric Flasks, 60 ml (one for each sample), 100 ml (one for each sample and each standard, and one for the working standard KNO) solution), and 1000 ml (one). 2.3.2 Porcelain Evaporating Dishes. 175- to 250 mi

(one). 23.8 Spectrophotometer. To measure absorbance at

410 am.
2.5.9 Graduated Pipette 10 ml with 0.1-ml divisions.
2.5.10 Test Paper for indicating plf. To cover the plf range of 7 to 14.

Analytical Balance To measure to within 0.1 2.3.11

8. Renorate

8. Respense

Unless otherwise indicated, it is intended that all reagents conform to the specifications established by the Committee on Analytical Reagents of the American Chemical Rociety, where such specifications are available, otherwise, use the best available grade.

3.1 Sampling. To prepare the absorbing solution, cautiously add 2R mil concentrated HysOs to 1 liter of deionized, distilled water. Mix well and add 6 mil of 3 percent hydrogen perunde, its silven prepared from 30 percent hydrogen perunde, its silven from 30 percent hydrogen perunde, solution. The absorbing solution should be used within I week of its preparation. Do not expose to extreme heat or direct sunlight.

3.2 Sample Recovery. Two reagents are required for sample recovery.

sample recovery 3.2.1 Sodium Hydroxide (IN). Disseive 40 g NaOH

in deconsed, distilled water and dilute to I liter.

3.2.2 Water, Deconsed, distilled to conform to ASTM specification Diligs 74, Type 3. At the option of the

analyst, the KMNOs test for oxidizable organic matter may be omitted when high concentrations of organic matter are not expected to be present.

3.3 Analysis. For the analysis, the following reagents are required:

3.3 Analysis. For the analysis, the following reagents are required:
3.3.1 Furning Sulfuric Acid. 15 to 18 percent by weight free sulfur troside. HANDLE WITH CAUTION.
3.3.2 Phenol. White solid.
3.3.3 Sulfuric Acid. Concentrated, 95 percent minimum assay. HANDLE WITH CAUTION.
3.3.4 Fotassium Nitrate. Dried at 165 to 110° C (220 to 23° F) for a minimum of 2 hours just prior to preparation of standard solution.
3.3.5 Standard KNO; Solution. Dissolve exactive 2 198 g of dried potassium nitrate (KNO;) in deionized, distilled water and dituse to 1 liter with deionized, distilled water in a 1,000 ml volumetric flask.
3.3.6 Working Standard KNO; Solution. Dilute 10 ml of the standard solution to 100 ml with deionized distilled water. One milliliter of the working standard solution is equivalent to 100 ml with deionized distilled water. One milliliter of the working standard solution is equivalent to 100 mg nitrogen dioxide (NO;).
3.3.7 Water. Deionized, distilled as in Bection 3.2.7 3.8 Phenoldistillonic Acid Solution Dissolve 25 g of pure white phenol in 300 ml concentrated sulfuric acid on a steam bath. Cool, add 75 ml furning sulfuric acid and host at 100° C (212° F) for 2 hours. Store in a dark, stoppered bottle. a dark, stoppered bottle

4 Procedures

4.1 Sampling.
4.11 Pipette 25 ml of absorbing solution into a sample flask, retaining a sufficient quantity for use in preparing the calibration standards Insert the flask valve slopes into the flask with the valve in the "purge" position. Assemble the sampling train as shown in Figure 7-1 and pisce the probe at the sampling point. Make sure that all fittings are tight and leak-free, and that all ground glass joints have been properly greased with a high-vacuum, high-temperature chlorofluorocarbon-based stopcock grease. Turn the flask valve and the pump valve to their "evacuate" positions. Evacuate the flask to 75 mm Hg (3 in, Hg) shoot-te pressure, or less Evacuation to a pressure approaching the vapor pressure of water at the existing temperature is desirable. Turn the pump valve to its 'vent' position and turn off the pump. Check for leakage by observing the manometer for any pressure fluctuation. (Any variation

greater than 10 mm Hg (0.4 in Hg) over a period of 1 minute is not acceptable, and the flack is not to be used until the leakage problem is corrected Pressure in the flack is not to exceed 75 mm Hg (3 in Hg) absolute at the time sampling is commenced. Record the volume of the flack and valve (V_i), the flack temperature (T_i), and the barometric pressure. Turn the flack valve consteredock also to its "purge" position and do the same with the pump valve. Purge the probe and the vacuum tube using the aguesez bulb H condensation occurs in the probe and the flack valve area, heat the probe and purge until the condensation disappears. Next, turn the pump valve to its "vent" position and record the difference in the mercury levels in the manometer. The absolute internal pressure in the flack (P_i) is equal to the barometric pressure loss the manometer reading. Immediately turn the flack valve to the "sample" position and permit the gas to enter the fack infill pressures in the flack and sample line file, duct, stack) are equal. This will usually require about 15 seconds. I have equal This will usually require about 15 seconds. I have equal This will usually require about 15 seconds. I have equal to the barnet of the flack from the sampling train. Shake the flack for at least 5 minutes.

4.1.2 If the gas being sampled contains insufficient cargen for the conversion of NO to NO; (e.g., an applicable subpart of the standard may require taking a sample of a calibration gas mixture of NO in No; then cargen for the conversion of NO to NO; (e.g., an applicable subpart of the standard may require taking a sample of a calibration gas mixture of NO in No; then cargen for the conversion of NO to NO; (e.g., an applicable subpart of the standard may require taking a sample of a calibration gas mixture of NO in No; then cargen for the conversion of the flack to mixture of NO in No; then cargen for the cargen may be introduced into the flack to the sampling flack, flush with pure cylinder cargen, then evacuate flack to 75 mm Hg

stmospheric pressure.

4.2 Sample Recovery Let the flack set for a minimum of 16 hours and then shake the contents for 2 minutes Connect the flack to a mercury filled D-tube manometer Opon the valve from the flack to the manometer and record the flack to the manometer and record the flack temperature (T), the barometric pressure, and the difference between the mercury levels not be manometer. The absolute internal pressure in the flack (P) is the barometric pressure less the manometer reading Transfer the contents of the flack to a leak-free polyethylene bottle. Rinse the flack to a leak-free polyethylene bottle. Adjust the pH to between and 12 by adding sodium hydroxide (i.N.), dropwise fabout 25 to 35 drops). Check the bil by dipping a

with 5-mi portions of deionized, distilied water and add the rinse water to the bottle Adjust the pli to between and 12 by adding sodium hydroxide it N₁, dropwise fabout 25 to 35 drops). Check the pli by dipping a siliring rod into the solution and then touching the rod to the pli test paper Remove as little material as peculial suring this step. Mark the height of the liquid level so that the container can be checked for leakage after ensport. Label the container to checked for leakage after ensport. Label the container for shipping.

4.3 Analysis. Note the level of the liquid in container and confirm whether or not any sample was lost during shipment; note this on the analytical data sheet. If a noticeable amount of leakage has occurred, either void the sample or use methods, subject to the approval of the Administrator, to correct the final results. Immediately prior to analysis, transfer the contents of the shipping container to a solul volumetric flask, and rinse the container twice with 5-ml portions of delonized, distilled water. Add the rinse water to the flask and dilute to the mark with delonized, distilled water; mix knownlyst price a 25-ml sliquot into the procedain evaporating dish. Return any unused portion of the sample to the polyethylene storage bottle. Evaporate the 25-ml sliquot to dryness on a steam bath and allow to cool. Add 2 ml phenoidianlifonic acid solution to the dried residue and triturate thoroughly with a poviethylene policeman. Make sure the solution contacts all the residue. Add 1 ml delonized, distilled water and four drops of concentrated sulfure acid. Heat the solution on a steam bath for 3 minutes with occasional stirring. Allow the solution to cool, add 20 ml delonized, distilled water, mix well by stirring, and add concentrated ammonium hydroxide, dropwise, with constant stirring. It is sample contains solids, these must be removed by filter through whatered sulfure and add the filter washings to the contents of the summistrator, as follows filter through by attributed to

5.1 Flask Volume. The volume of the collection flask-mak valve combination must be known prior to sam-ling. Assemble the flask and flask valve and fill with

water, to the stopcock. Measure the volume of water to ±10 ml. Record this volume on the flask.

5.2. Spectrophotometer t aliteration.

5.2.1. Optimum Wavelength Determination: For both flaed and variable wavelength spectrophotometers, calibrate against standard certified wavelength of 410 hm. every 6 months. Alternatively, for variable wavelength spectrophotometers, sometime between 400 and 416 nm using a 200 ag. NO attandard so ution (see Section 5.2.2). If a peak does not occur, the spectrophotometer is probably mailmetioning, soid should be repaired. When a peak is obtained within the 100 to 416 hm range, the wavelength at which this peak occurs shall be the optimum wavelength for the measurement of absorbance for both the standards and samples.

5.2.2. Determination of Spectrophotometer Calibra KNO: working standard solution (1 ml = 100 ag. NO) in a sense of five porcelain evaporating dishes. To each add KNO: working standard solution (1 ml = 100 ag. NO) in a sense of five porcelain evaporating dishes. To each add water, and sodium hydroxide (1N), dropwise, until the oH is between 9 and 42 (about 25 to 25 drops each).

wast, and sodium hydroxide (1N), dropwise, until the off is between 8 and 12 labout 25 to 35 drops each). Beginning with the evaporation step, follow the analysis procedure of Section 4.3, until the solution has been transferred to the 100 ml volumetric flass and dutted to the mark. Measure the absorbance of each solution, at the optimum wavelength, as determined in Section 5.2.1. This calibration procedure must be repeated on each day that samples are analyzed. Calculate the spectrophotometer calibration factor as follows.

$$K_{c} = 100 \frac{A_{1} + 2A_{2} + 3A_{3} + 4A_{4}}{A_{1}^{2} + A_{2}^{2} + A_{3}^{2} + A_{4}^{2}}$$

K .= Calibration factor

A:= A borbance of the 100 ag N Oo standard
A:= A borbance of the 200 ag N Oo standard
A:= A borbance of the 300 ag N Oo standard
A:= A borbance of the 300 ag N Oo standard
A:= A borbance of the 400 ag N Oo standard
5.3 Barometer. Calibrate against a mercury barometer

ter.
5.4 Temperature Gauge, Calibrate dial thermometers gainst mercury drughas thermometers.
5.5 Vacuum, Gauge, Calibrate mechanical gauges, if sed against a mercury manumeter such as that spect.

fied in 2.1.6.
5.6 Analytical Balance. Calibrate against standard

6. Calculations

Carry out the calculations, retaining at least one extra decimal ogure beyond that of the sequired data. Round off figures after final calculations.

6.1 Nomenclature.

A a Absorbance of sample.

C = Concentration of N.O. as N.O. dry basis, corrected to standard conditions, nighteen thirdseft.

Chidsef)

F=Dilution factor (i.e., 25.5, 26.10, etc., required only if sample dilution was needed to reduce the absorbance into the range of calibration)

K = Spectrophotometer calibration factor

m = Hass of NG, as NG in gas sample, as

P = Final absolute pressure of the k, non-Hg (in-Hg)

Lig)

Standard absolute pressure, 760 non-11g (2002 in He)

He) 1 mal absolute temperature of flask (K (SR) 1 m. limit absolute temperature of flask (K (SR) 1 m. limit absolute temperature of flask (K (SR) 1 m. Standard absolute temperature, 23° K (8.8° K) k as sumile volume at standard conditions (dry basis) mi 1 = Volume of flask and valve, mi 1 = Volume of flask and valve, mi 1 = Volume of absorbing solution, 28 mi 2 = 50:25, the aliquot factor (if other than a 25 m) aliquot was used for analysis, the corresponding factor must be substituted).

$$\begin{split} \boldsymbol{V_{\bullet}} &= \frac{\boldsymbol{T_{\bullet \circ t}}}{\boldsymbol{P_{\bullet \circ t}}} \left(\left. \boldsymbol{V_{I}} - \boldsymbol{V_{e}} \right) \left[\begin{array}{c} \boldsymbol{P_{I}} \\ \boldsymbol{T_{I}} - \boldsymbol{T_{i}} \end{array} \right] \\ &= K_{1} \left(\left. \boldsymbol{V_{I}} - 25 \text{ m} \right| \right) \left[\begin{array}{c} \boldsymbol{P_{I}} - \boldsymbol{P_{i}} \\ \boldsymbol{T_{i}} - \boldsymbol{T_{i}} \end{array} \right] \end{split}$$

 $K_1 = 0.3858 \frac{K}{\text{mm Hg}}$ for metric units

= 17.64
$$\frac{^{\circ}R}{in.H_{B}}$$
 for Linglish units

6.3 Total og NO, per sample

$$m=2K, AF$$

Equation 7-3

Note - If other than a 25-ml abquot is used for analysis, the factor 2 must be replaced by a corresponding

6.4 Sample concentration, dry basis, corrected to standard conditions

$$C = K_2 \frac{m}{V_{sc}}$$

Equation 7-4

where

$$K_2 = 10^3 \frac{\text{mg/m}^4}{\text{mg/ml}}$$
 for metric smits

=6.243
$$\times$$
10⁻³ $\frac{lb/scf}{\mu g/ml}$ for English units

7. Fillingray by

1 Standard Methods of Chemical Analysis 6th ed. New Yor p. 329-336

Standard Method of Test for Oxides of Nitrogen in Osseous Combustion Products (Planoidisulfonic Acid Procedure). In 1968 Book of ASTM Standards, Part 25, Philadelphia, Pa. 1968. ASTM Designation D-1608-60,

Jacob, M. B. The Chemical Analysis of Air Pollut-s. New York. Interscience Publishers, Inc. 1960.

3. Jacob, M. B. The Chemical Analysis of Air Pollutants. New York. Interscience Fublishers, Inc. 1960.
4. Boatty, R. L., L. B. Berger, and H. H. Schrenk.
Determination of Oxides of Nitrogen by the Phenoidisulionic Acid Method. Bureau of Mines, U.S. Dept. of Interior. J. 3687. February 1943.
5. Hamil, H. F. and D. E. Camann. Collaborative Study of Method for the Determination of Nitrogen Oxide Emissions from Stationary Sources (Fossil Fuel-Fired Steam Generators). Sout' west Research Institute report for Environmental Protection Agency. Research Triangle Park, N.C. October 5, 1973.
6. Hamil, H. F. and R. E. Thomas. Collaborative Study of Method for the Determination of Nitrogen Oxide Emissions from Stationary Sources (Nitric Acid Plants). Southwest Research Institute report for Environmental Protection Agency. Research Triangle Park, N.C. May 8, 1974.
METHOD 8.—DETERMINATION OF SULPURIC ACID MET

METHOD 8 DETERMINATION OF SULPURIC ACID MIST AND SULPUR DIOXIDE EMISSIONS FROM STATIONARY SOURCES

1. Principle and Applicability

11 Frinciple A gas sample is extracted isokinetically from the stack. The suifure and mist (including sulfur trioxide) and the sulfur dioxide are separated, and both fractions are measured separately by the barium-thorin titration method.

itration method.

1.2 Applicability. This method is applicable for the determination of sulfure acid mist (including sulfur trioxide, and in the absence of other particulate matter) and sulfur dioxide emissions from stationary sources. Collaborative tests have shown that the minimum detectable limits of the method are 0.05 milligramis/cubic meter 10.05 to 2 pounds/cubic foot) for sulfur dioxide. No hipper limits have been established, based on theoretical calculations for 200 millidiers of 3 percent hydrogen peroxide solution, the upper concentration limit for sulfur dioxide in a 1.0 m² (25.3 fc!) gas sample is about 12.500 mg/sci (2.75.05 b)/sci). The upper limit can be extended by increasing the quantity of peroxide solution in the improves.

Possible interfering agents of this method are fluorides.

Toositic interfering agents of this method are fluorides, free animonia, and dimethyl anime. If any of these bundering are its are present (this can be determined by knowledge of the process), alternative methods, subject to the approval of the Administrator, are required. Filternite particulate matter may be determined along with Sch and SO₂ (subject to the approval of the Administrator), however, the procedure used for particulate matter must be constitent with the specifications and procedures given in Method 5.

2.1 Sampling. A schematic of the sampling train used in this method is shown in Figure 8-1, it is similar to the Method 5 train except that the filter position is different and the filter holder does not have to be heated. Commercial models of this train are available. For those who desire to build their own, however, complete construction details are described in AFTI-4681. Changes from the AFTI-4681 document and allowable modifications to Floure 8-1 are discussed in the following subsections. tubsections

The operating and maintenance procedures for the sampling train are described in APTIM576. Since correct issue is important in obtaining valid results, all users should read the APTIM576 document and adopt the operating and maintenance procedures outlined in it, unless otherwise specified herein. Further details and guidelines on operation and maintenance are given in Method 5 and should be read and followed whenever they are applicable.

21.1 Probe Nozzie Same as Method 5, Section 2.1.1.

24.2 Probe Liner. Borodlicate or quartz glass, with a heating system to prevent visible condensation during sampling. Do not use metal probe liners.

24.3 Prob Liner. Same as Method 5, Section 24.3.

8.8.5 Sulfuric Acid Standard (0.0100 N). Purchase or standardize to ±0.0002 N session 0.0100 N NaOH that has previously been standardized against primary standard potassium acid phthalate.

4. Procedure

4. Procedure
4.1 Sampling.
4.1.1 Pretest Preparation. Follow the procedure outlined in Method 5. Section 4.1.1 filters should be inspected, but need not be desiceated, weighed, or identified. If the effluent gas can be considered dry 1.2, moisture free, the silica gel need not be weighed.
4.1.2 Preliminary Determinations. Follow the procedure outlined in Method 5. Section 4.1.2
4.1.3 Preparation of Collection Train Follow the procedure outlined in Method 5. Section 4.1.2 (secept for the second paragraph and other obviously inapplicable parts) and use Figure 8.1 instead of Figure 5.1. Replace the second paragraph with Flace 100 mi of 30 percent isopropanol in the first impliner, 100 mi of 35 percent bydragen peroxide in both the second and third im-

pingers: retain a portion of each reagent for use as a blank solution. Place about 200 g of silica gel in the jourth Impinger

Norg.-If moisture content is to be determined by impinger analysis, weigh each of the first three impingers (plus absorbing solution) to the nearest 0.5 g and record these weights. The weight of the siting gel (or silica gel plus container) must also be determined to the nearest 0.5 g and recorded.

4.14 Pretest Leak-Check Procedure Follow the basic procedure outlined in Method 5, Section 4.14.1, noting that the probe beater shall be adjusted to the noting that the probe beater shall be adjusted to the minimum temperature required to prevent condensation, and also that verbage such as. "* * " plugging the inlet to the filter holder * * "," shall be replaced by, " * " plugging the inlet to the first impinger * * "." The pretest leak-check is optional.

4.1.5 Train Operation. Follow the basic procedures outlined in Method 5, Section 4.1.5, in conjunction with the following special instructions. Data shall be recorded

on a sheet similar to the one in Figure 8-2. The sampling rate shall not exceed 0.630 mi/min (1.0 cfm) during the run. Periodically during the test, observe the connecting line between the probe and first impinger for signs of condensation. If it does occur, adjust the probe heater setting apward to the minimum temperature required to prevent condensation. If component changes become necessary during a run, a leak-check shall be done immediately before each change, according to the procedure outlined in Section 4.14.2 of Method 5. (with a procedure outlined in Section 4.1.4.2 of Method 5 (with appropriate modifications, as mentioned in Section 4.14 of this method); record all leak rates. If the leakage rate(s) exceed the specified rate, the tester shall either void the run or shall plan to correct the sample volume as outlined in Section 6.3 of Method 5. Immediately after component changes, leak-checks are optional. If these leak-checks are done, the procedure outlined in Section 4.1.4.1 of Method 5 (with appropriate modifications) shall be used.

PLANT						STATIC PRESSU	IRE, mm Hg (in.	Hg)	
LOCATION			The state of the s						
OPERATOR					1				
DATE					1				
RUN NO.					1	PROBE LENGT	H, m (ft)		
SAMPLE POVED					- 1	NOZZLE IDENT	TIFICATION NO)	
SAMPLE BOX NO.	The same of the sa				- 1				, em (in.)
METER BOX NO METER A H@		-			1				
C FACTOR					i				
PITOT TUBE COEFF						PROBE LINER	MATERIAL	-	
71101 1002 6027	TUTENT, UP		SCHEMATIC OF	STACK CRO	SS SECTION	FILTER NO			
	SAMPLING	VACUUM	STACK TEMPERATURE	VELOCITY HEAD (\DPs),	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER	GAS SAMPLE		TEMPERATURE GAS METER	TEMPERATURE OF GAS LEAVING
TRAVERSE POINT NUMBER	YIME (0), min.	mm Hg (in. Hg)	*C (0F)	mm H2U (in. H2O)	mm H20 (in. H20)	VOLUME,	INLET.	OUTLET,	CONDENSER OR LAST MAPINGER, CC (OF)
						And the same and a second and a second			
		-							
							1		
							-		
							1		
					The state of the s	1			
					-				
						-	-		
				Mark Carrier Capabilities of the					
		The state of the s		Mr. commission on the		-			
THE CONTRACTOR OF THE PARTY OF									
THE RESERVE OF THE PARTY OF THE									
****	-						Ava	Ava	
TOTAL	1		1						

Figure 8-2. Field data

After turning off the pump and recording the final readings at the conclusion of each run, remove the probe from the stack. Conduct a post-test translatory), leak-check as in Section 4.1.4 of Method 5 (with appropriate modification) and record the leak rate. If the post-test leakage rate exceeds the specified acceptable rate, the tester shall either correct the sample volume, as outlined in Section 6.2 of Method 5, or shall void the run.

Drain the ice both and, with the probe disconnected, purpe the remaining part of the train, by drawing clean ambient air through the system for 15 minutes at the average flow rate used for sampling.

Note.—Clean ambient air can be provided by passing

Note.—Clean ambient air can be provided by passing air through a charcost filter. At the option of the tester, ambient air (without cleaning) may be used.

4.1.6 Calentation of Percent Isokinetic. Follow the procedure outlined in Method 5, Section 4.1.6.

4.2 Sample Recovery.

4.2.1 Container No. 1. If a moisture content analysis

is to be done, weigh the first impinger plus contents to the hearest of gand record this weight.

Transfer the contents of the first impinger to a 25%-mi graduated cylinder. Rinse the probe, first improper all innecting glackware heare the filter, and the bent half of the filter holder with sapercent sopropanol. Add the rinse solution to the cylinder. Dilute to 250 all with so percent isopropanol. Add the filter to the shiften, not, and transfer to the storage container. Frotect the solution spanist expansion. Mark the level of liquid on het container as a identify the sample container.

4.22 Container No. 2 If a mosture content analysis is to be done weigh the second and third impingers to the content spanish of the spinishing spins of the solutions from the second and third impingers to a 1000-mi graduated cylinder. Rinse all impingers to a 1000-mi graduated cylinder.

plus impingers to the nearest 0.5 g Transfer the solutions from the second and third impingers to a 1000-ml graduated cylinder. Rinse all connecting glassware including back half of filter holder) between the filter and slica gel impinger with deconted,

distilled water, and add this rinse water to the cylinder. Dilute to a volume of 1600 m) with detonized, distilled water. Transfer the solution to a storage container. Mark the level of liquid on the container. Seal and identify the sample container.

sample container.

4.3 Analysis.

Note the level of liquid in containers I and 2, and confirm which er or not any sample was lost during shipment note the on the analytical data sheet. If a notice-ship amount of leakage has occurred, either wold the sample or use methods, subject to the approval of the Administrator, to correct the familierariles.

4.3.1 Container No. 1. Shake the container holding the isopropished solution and the filter. If the filter breaks up, allow the finginents to settle for a few minutes before removing a sample. Pipette a 100 ml aliquid of this solution into a 255-ini Erlanmeyer flash, add 2 to 4 drops of thorn indicator, and titrate to a pink endpoint using 0.0100 N burium perchlorate. Repeat the titration with a second aliquot of sample and average the titration with a second aliquot of sample and average the titration




Figure 8-1. Sulfuric acid mist sampling train.

2.1.4 Differential Pressure Cauge. Same as Method 5,

2.1.4 Differential Pressure Gauge, Same as Method 5, Section 2.1.4.

2.1.5 Filter Holder. Borosilicate glass, with a glass of the support and a silicone rubber gasket. Other gasket materials, e.g., Tefon or Viton, may be used subject to the approval of the Administrator. The holder design shall provide a positive seal against leakage from the outside or around the filter. The filter bolder shall be placed between the first and second impingers. Note: Do not heat the filter holder.

2.1.6 Impingers—Four, as shown in Figure 8-1. The first and third shall be of the Greenburg-Smith design with standard tips. The second and fourth shall be of the Greenburg-Smith design, modified by replacing the insert with an approximately 13 millimeter (0.5 in.) ID glass tube, having an unconstructed tip located 13 mm (0.5 in.) from the bottom of the flask Similar collection systems, which have been approved by the Administrator, may be used.

2.1.7 Metering System. Same as Method 5, Section 2.1.9.

2.1.8

2.1.9 Gas Density Determination Equipment Same as Method 5, Section 2.1.9.

2.1.9 Gas Density Determination Equipment Same as Method 5, Section 2.1.10.

2.1.10 Temperature Gauge. Thermometer, or equivalent, to measure the temperature of the gas leaving the impinger train to within 1° C (2° F).

2.2 Sample Recovery.

2.2.1 Wash Bottles. Polyethylene or glass, 500 ml. (two).

2.7.2 Oraduated Cylinders. 250 ml, 1 liter. (Volumetric flasks may also be used.)

Storage Bottles. Leak-free polysthylene bottles, al size (two for each sampling run).

2.2.4 Trip Balance, 500 gram capacity, to measure to ± 0.5 g (necessary only if a moisture content analysis is to be done).

2.3 Analysis.
2.3.1 Pipettes. Volumetric 25 ml, 100 ml.
2.3.2 Burrette. 50 ml.
2.3.3 Erlenmeyer Flask. 250 ml. (one for each sample blank and standard).

2.3.4 Graduated Cylinder, 100 ml.

2.3.5 Trip Balance, 500 g capacity, to measure to

±0.5 g.
2.36 Dropping Bottle. To add indicator solution,

125-ml size 8. Reagents

Unless otherwise indicated, all reagents are to conform to the specifications established by the Committee on Analytical Reagents of the American Chemical Society, where such specifications are available. Otherwise, use the test available grade.

the best available grade.

2.1 Bampling.

3.1.2 Filters. Same as Method 5. Section 3.1.1.

3.1.2 Filters. Same as Method 5. Section 3.1.2.

3.1.3 Water. Deforited, distilled to conform to ASTM specification Dilay-24. Tipe 2. At the option of the analyst, the KMnOr test for oxidizable organic matter may be omitted when high concentrations of organic matter are not expected to be present.

3.1.4 Isopropanol. 80 Percent. Mix 800 ml of isopropanol with 200 ml of deionized, distilled water.

Nove.—Experience has shown that only A.C.S. grade.

Notz.—Experience has shown that only A.C.S grade isopropanol is satisfactory. Tests have shown that isopropanol obtained from commercial sources occa-casionally has peroxide impurities that will cause er-

roneously high sulfuric acid mist measurament. Use
the following test for detecting peroxides in each lot of
isopropanol Shake 10 ml of the isopropanol with 10 ml
of freshly prepared 16 percent potestium iodide solution.
Prepare a blank by similarly treating 10 ml of distilled
water. After 1 minute, read the absorbance on a spectrophotometer at 352 nanometers. If the absorbance caceceds
0.1 the isopropanol shall not be used. Peroxides frang be
removed from isopropanol by redistilling, or by passage
through a column of activated alumina. However, reagent-grade isopropanol with suitably low peroxide levels
is readily available from commercial sources, therefore,
rejection of contaminated lots may be more efficient
than following the peroxide removal procedure.
3.1.5 Hydrogen Peroxide, 3 Parcent. Dilute 100 ml
of 30 percent hydrogen peroxide to 1 liter with deionized,
distilled water. Prepare fresh daily.
3.1.6 Crushed Ice.
3.2 Eample Recovery.
3.2.1 Water. Same as 3.1.3.
3.2.2 Isopropanol, 80 Percent, Bame as 3.1.4.
3.3.3 Analysis.
3.3.1 User industry 1. (e. propropophenylages) 2 perb.

3.3.1 Water, Same as 3.1.3.
3.3.2 Lapropanol, 100 Parcent.
3.3.3 Therm indicator, 1-(o-aromophenyiazo)-2-naphthol-3, 6-disulforuc acid, disodium sait, or equivalent.
Dissolve 0.0 gm in 00 ml of deionized, distilled water.
3.3.4 Barium Perchlorate (0.0100 Normai). Dissolve
1,96 gc barium perchlorate trihydrate (BacClo)-384-0)
in 200 ml deionized, distilled water, and diinte to 1 liter
with isopropanol. 1.22 g of barium chloride dihydrate
(BaCl-2114)) may be used instead of the barium perchlorate. Standardize with sulfuric seid as in Section 5.2.
This solution must be protected against evaporation at
all times.

8.5.5 Sulfuric Acid Standard (0.0100 N). Purchase or standardize to ±0.0002 N against 0.0100 N NaOH that has previously been standardized against primary standard potassium acid phthalate.

4. Procedure

PLANT

4.1. Sampling.
4.1.1 Frenest Preparation. Pollow the procedure outlined in Method 5. Section 4.1.1, filters should be specied, but need not be desicosted, weighted, or id-to-field. If the effluent gas can be considered dry, i.e. 100s, ture tise, the silica gel need not be weighted.
4.1.2 Preliminary Determinations. Follow the procedure outlined in Method 5. Section 4.1.2 Creept for the second pararraph and other obviously inapplicable parts and use Figure 8.1 instead of Figure 5-1 Replace the second paragraph with Flace 100 ml of 80 percent isopropanol in the first implinger, 100 ml of 3 percent isopropanol in the first implinger, 100 ml of 3 percent

pingers; retain a portion of each reagent for use as a blank solution. Place about 200g of silicage in the fourth

impinger.

Note.—If moisture content is to be determined by impinger analysis, weigh each of the first three impingers (plus absorbing solution) to the nearest 0.5 g and record these weights. The weight of the silica gel for silica gel a container) must also be determined to the nearest 0.5 g and recorded. dág, ad recorded

9.5 g. ad recorded.

4.1.4 Pretest Leak-Check Procedure. Follow the basic procedure outlined in Method 5, Section 4.1.4.1. noting t at the probe heater shall be adjusted to the minimum i temperature required to prevent condensation, and also that verbage such as. "* plugging the fallet to the first impager * " bugging the inlet to the first impager * 1.5. Train Operation. Pollow the basic procedures outlined in Method 5, Section 4.1.5, in conjunction with the following special instructions. Data shall be recorded

on a sheet similar to the one in Figure 8-2. The sampling rate shall not exceed 0.020 m/min (1.0 cfm) during the run. Periods ally during the test, observe the connecting line between the probe and lirst impinger for signs of condensation. If it does occur, adjust the probe heater setting upward to the uniforum temperature required to prevent condensation. If component changes become teccessary during a run, a leak-check shall be done immediately before each change, according to the procedure outlined in Section 4.1.4.2 of Method 5 (with appropriate modifications, as mentioned in Section 4.1.4 of this outlined in Section 4.1.4.2 of Method 5 (with appropriate modifications, as mentioned in Section 4.1.4 of this method), record all hak rates. If the leakage rate(s) exceed the specified rate, the tester shall either void the run or shall plan to correct the sample volume as outlined in Section 6.3 of Method 5. Immediately after composite the sample specified in Section 6.3 of Method 5. Immediately after composition of the sample specified in Section 4.1.4.1 of Method 5. (with appropriate modifications) 4.14.1 of Method 5 (with appropriate modifications) shall be used

STATIC PRESSURE, mm Hg (in. Hg)

LOCATION						AMBIENT TEN	MPERATURE_				
OPERATOR						BAROMETRIC	PRESSURE				
DATE						ASSUMED MOISTURE, %					
RUN NO.						PROBE LENGTH, m (t)					
SAMPLE BOX NO.						NOZZLE IDEN	TIFICATION N	0			
METER BOX NO _		-			- 10	AVERAGE CA	LIBRATED NO	ZZLE DIAMETER	, cm (in.)		
METER A HO						PROBE HEATE	R SETTING				
C FACTOR						LEAK RATE, m3/min, (cfm)					
PITOT TUBE COEFF	FICIENT Co	L				PROBELINER	MATERIAL				
			SCHEMATIC OF	F STACK CR	OSS SECTION	FILTER NO		Contraction between the state of the state of			
TRAVERSE POINT	VERSE POINT TIME	SAMPLING VACUUM TEMPER	STACK TEMPERATURE	STACK WEAD	PRESSURE DIFFERENTIAL ACROSS GRIFICE METER	GASSAMPLE	GAS SAMPLE TEMPERATURE		TEMPERATURE OF GAS LEAVING		
NUMBER.		TIME mm Hg (5), min. (in. Hg) *C	(TS). *C (OF)	mm H ₂ () (in. H ₂ ())	mm HaD	VOLUME, m3 (ft3)	OC (OF)	CUTLET, PC (PF)	CONDENSER OR LAST IMPINGER *C (°F)		
					A color material control of the street				The second secon		
		-	-						The state of the s		
				***************************************			Torre Service Management				
	-										
	-			-							
		-		***************************************							
			-								
-			-			-					
	-	-	-								
TOTAL						The second secon	Avo	Avo			

Figure 8-2. Field data.

After turning off the pump and recording the final readings at the consequence of each run, remove the profession the stack. Consider a port-tent it and altery leak clock axis Section 4.1.4.3 of Method a reach appropriate modification) and record the lesk rate. If the post-tent modification, and record the lesk rate. If the post-tent leak are rate exceeds the specified acceptable rate, the lesker shall either correct the samples volume, as sufficient in Section 6.3 of Method 5, or shall void the run. Drain the ice bath and, with the profile disconnected, purpose the remaining part of the train, by drawing clean ambient air through the system for 15 minutes at the average flow rate used for sampling.

Note—Clean ambient air can be provided by passing air through a charcoal filter At the option of the tester, ambient air (without cleaning) may be used.

4.1.6 Calculation of Fercent Isokinetic Follow the procedure outlined in Method 5, Section 4.1.6.

4.2 Sample Recovery

4.2.1 Container No. 1. If a moisture content analysis

is to be done, weigh the first improper plus contents to the insertile of anothered the weight are more allowed and the first improper to a 2-4-m graduated cylinder. Find the first improper to a 2-4-m graduated cylinder. Find the first improper to a 2-4-m graduated cylinder Find the first improper to a 2-4-m graduated cylinder. Find the first improper a content with a percent asoptoposoid. Add the raise solution to the cylinder Dante to 2-6 of with so percent asoptoposoid. Add the filter to the solution and distributed to the solution and the first to the solutions of the maintainer and and stirrel impropers a solution to the solutions from the second and third impropers to a 10-6 mil graduated cylinder. Hincomic first whether or not an an entitled duta sheet. If a notice and a solution and the first to another the filter before the solutions from the second and third impropers to a 10-6 mil graduated cylinder. Hincomic solution and the filter. If the filter is solution and the filter if the filter before the more first, and third the solution too above the filter if the filter before the more first, and the filter for a few minutes before the solutions from the second and third impropers to a 10-6 mil graduated cylinder. Hincomic solution and the filter if the filter before the more first, and the filter for a few minutes before the more first, and the filter for a few minutes before the filter and allowed to the solutions and the filter. If the filter before the solution are successful.

values. Replicate titrations must agree within 1 percent or 0.2 ml, whichever is greater.

4.3.2 Container No. 2. Thoroughly mix the solution in the container holding the contents of the second and third impliners. Pipette a 10-ml siliquot of sample into a 250-ml Erlettmeyer flask. Add ml of isopropanol, 2 to 4 drops of thorn inclicator, and titrate to a pink endpoint using 0.01-20 N barium perchlorate. Repeat the titration with a second aliquot of sample and average the titration values. Replicate titrations must agree within 1 percent or 0.2 ml, whichever is greater.

4.3.3 Blanks. Frepare blanks by adding 2 to 4 drops of thorin indicator to 100 ml of 80 percent isopropanol. Titrate the blanks in the same manner as the samples.

5 Out theating

5.1 Calibrate equipment using the procedures speci-fied in the following sections of Method 5: Section 5.3 (metering system); Section 5.5 (temperature gauges); Section 5.7 (barometer). Note that the recommended leak-check of the metering system, described in Section 5.5 of Method 5, also applies to this method. 5.2 Standardize the barium perchlorate solution with 25 ml of standard sulfuric acid, to which 100 ml of 100 percent isopropanol has been added.

6. Calculations

Note —Carry out calculations retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

61 Nomenciature.

A. Cross-sectional area of norrie, m² (ft²).

B. Water wapor in the gas stream, proportion by volume.

CH3O.=Sulfuric acid (including SO₂) concentration, g/dscm (ib/dscf).

CSO₂=Sulfur dioxide concentration, g/dscm (ib/dscf).

CSO₁= Suffer dioxide concentration, g/dscm (b)/
dscf).

I= Percent of isokinetic sampling.

N= Normality of barium perchlorate titrunt, gequivalents/liter.

Phar= Barometric pressure at the sampling site,
min Hg (in Hg).

P.= Absolute stack gas pressure, mm Hg (in Hg).

Pstd = Standard absolute pressure, 760 mm Hg
(29.92 in Hg).

T= Average absolute dry gas meter temperature (see Figure 8-2), % K (% K).

T= Average absolute stack gas temperature (see Figure 8-2), % K (% R).

Tstd = Standard absolute temperature, 293° K
(22° R).

V= Volume of sample aliquot titrated, 100 ml
for H+SO₄ and 10 ml for SO₇.

V= Volume of gas sample as measured by dry
gas meter dem (dcf).

V= Volume of gas sample as measured by dry
gas meter dem (dcf).

V= (std) = Volume of gas sample measured by the dry
gas meter dem (dcf).

\$\text{\$\text{\$4\$}\$}\$ calculated by
Method 2. Equation 2-9, using data obtained

deem (dsef).

***, A verage stack gas velocity, calculated by Method 2. Equation 2-9, using data obtained from Method 8, th/sec (ft/sec).

**Vsoin = Total volume of solution in which the sulturic acid or sulfur dioxide sample is contained, 2:0 ml or 1,000 ml, respectively.

**Vsolume of barium perchlorate titrant used for the sample, ml.

**Vis Volume of barium perchlorate titrant used for the biank, ml.

**Y Dry gas meter calibration factor.

**Aff = A verage pressure drop across orifice meter, mm (in.) H₂O.

6 = Total sampling time, min.

10 = E ourseryon to retreate.

13 6= Specific gravity of mercury.
60= sec/min.
100= Conversion to percent.
6.2 A verage dry gas meter temperature and average orfice pressure drop. See data sheet (Figure 8-2).
6.1 Dry Gas Volume. Correct the sample volume measured by the dry gas meter to standard conditions (CF C and 760 mm lig or 68° F and 29.92 in. Hg) by using Equation 8-1.

$$\begin{split} V_{\text{m (end)}} = V_{\text{m}} Y \left(\frac{T_{\text{end}}}{T_{\text{m}}} \right) \frac{P_{\text{bar}} + \left(\frac{\Delta H}{13.6} \right)}{P_{\text{end}}} \\ = K_1 V_{\text{m}} Y \frac{P_{\text{bar}} + \left(\Delta H / 13.6 \right)}{T_{\text{m}}} \end{split}$$

Equation 8-1

where K₁: 0.3856 6 K/mm Hg for metric units = 17.64 6 K/m. Hg for English units.

Note —If the leak rate observed during any manda-tory leak-checks exceeds the specified acceptable rate, the tester shell either correct the value of V_{∞} in Equation 5-1 (as described in Section 6.3 of Method 5), or shall invalidate the test run.

8.4 Volume of Water Vapor and Moisture Content. Calculate the volume of water vapor using Equation 5-2 of Method 5: the weight of water collected in the impingers and allies gel can be directly converted to milliliters (the specific gravity of water is 1 g/ml). Calculate the moisture content of the stark gas, using Equation 5-3 of Method 5. The "Note" in Section 5-5 of Method 5 also applies to this method. Note that if the efficient gas stream can be considered dry, the volume of water vapor and moisture content need not be calculated.

6.5 Sulfuric acid mist (including SO₂) concentration.

$$C_{\rm B_2SO_4}\!=\!K_2\,\frac{N(V_t\!-\!V_{tb})\left(\frac{V_{\rm sols}}{V_{\rm o}}\right)}{V_{\rm m\,(sid)}}$$

Equation 8-2

where:

K=0.04906 g/milliequivalent for metric unite.

=1.061×10-1b/meq for English units.

6.6 Buffur diaxide concentration.

$$C_{80_3} = K_3 \frac{N(V_t - V_{tb})}{V_{\text{m (atd)}}} \left(\frac{V_{\text{sole}}}{V_{\text{o}}}\right)$$

Equation 8-3

where:

K≥0.03203 g/meq for metric units.

≈7.061×10→11/meq for English units.

6.7 I Isokinetic Variation.

6.7.1 Calculation from raw data.

$$I = \frac{100 T_{\bullet} [K_{\bullet} V_{1r} + (V_{m}/T_{m}) P_{bar} + \Delta H/13.6)]}{60 \theta V_{\bullet} P_{\bullet} A_{m}}$$

Equation 8-4

 $K_i = 0.003464$ mm Hg-mWml-6K for metric units. =0.002676 in. Hg-ft4/ml-7R for English units. 6.7.2 Calculation from intermediate values.

$$\begin{split} I &= \frac{T_{\star}V_{m \, (\mathrm{wid})}P_{\star^{1}\mathrm{d}} \, 100}{T_{\mathrm{mid}}v_{\star}\theta \, A_{n}P_{\star} \, 60 \, (1-B_{\mathrm{w}\star})} \\ &= K_{5} \, \frac{T_{\star}V_{m \, (\mathrm{wid})}}{P_{\star}v_{\star} \, A_{n}\theta \, (1-B_{\mathrm{w}\star})} \end{split}$$

Equation 8-5

where: $K_1=4.320$ for metric units. =0.69450 for English units.

6.8 Acceptable Results. If 90 percent $\leq 1 \leq 110$ percent, the results are low in comparison to the standards and I is beyond the acceptable range, the Administrator may opt to accept the results. Use Citation 4 in the Bibliography of Method 5 to make judgments. Otherwise, reject the results and repeat the test.

7. Bibliography

Atmospheric Emissions from Sulfuric Acid Manufacturing Processes. U.S. DHEW, PHS, Division of Air Pollution. Public Health Service Publication No. 999-AP-13. Cincinnati, Ohio. 1965.
 Corbett. P. F. The Determination of SO: and SO: in Flue Gases. Journal of the Institute of Fuel. 24:237-243.

1961.
3. Martin, Robert M. Construction Details of Isokinetic

3. Martin, Robert M. Construction Details of Isokinetic Source Sampling Equipment. Environmental Protection Agency. Besearch Triangle Park. N.C. Air Poliution Control Office Publication No. APTD-4381. April, 1971.

4. Patton, W. F. and J. A. Brink, Jr. New Equipment and Techniques for Sampling Chemical Process Gases. Journal of Air Poliution Control Association. 15.162. 1963.

5. Rom, J. J. Maintenance, Calibration, and Operation of Isokinetic Source-Sampling Equipment. Office of Air Programs, Environmental Protection Agency. Research Triangle Park, N.C. APTD-076. March, 1972.

6. Hamil, H. F. and D. E. Camann, Collaborative Study of Method for Determination of Sulfur Dioxide Emissions from Stationary Sources (Poss.) Fuel-Fired Steam Generators). Environmental Protection Agency. Research Triangle Park, N.C. EPA-3509-74-024. December, 1973.

7. Annual Book of ASTM Standards, Part 31; Water,

December, 1973.
7. Annual Book of ASTM Standards, Part 31; Water,
Atmospheric Analysis, pp. 40-42. American Society
for Testing and Materials, Philadelphia, Pp. 1976.

(Secs. 111, 114, 301(a), Clean Air Act, sec. 4(a) of Pub. L. 91-45M, 84 Stat. 1683; sec. 4(a) of Pub. L. 91-46M, 84 Stat. 1687; sec. 2 of Pub. L. 90-148, 81 Stat. 504 [42 U.S.C. 1857c-6, 1857c-9, 1857g(a)].)

[FR Doc 77-13608 Filed 8-17-77,8:45 am]



2.0 MONITORING METHODOLOGY (continued)

STACK DATA FORMATS


VELOCITY TRAVERSE DATA

PLANT					
	ETER OR DIMENS				
BAROMETRIC	PRESSURE, mm	Hg (in. Hg	g)		
CROSS SECT	IONAL AREA, m ²	(ft ²)			
OPERATORS					
PITOT TUBE	I.D. NO				
AVG. COR	EFFICIENT, Cp=			SCHEMATIC OF	CTACV
	TE CALIBRATED_			OULIDITALITY OF	
Traverse	Vel. Hd., p	Stack Ter	mperature	Pg	
Pt. No.	mm (in.) H ₂ 0	ts, oc(oF)	Ts,OK(OR)	mm Hg (in.Hg)	VΔP
			NAS.ELE		
-		-			
					-
-					-
					-
					-
		-			-
					-
					1
					1
					1
	driver in				
			1.3.4.3.3.21		
			. 1.75.51.5		
7	THE POTE THE		19.3		

Average

TRAVERSE POINT LOCATION

DATE			
AMPLING LOCAT	ION		
TAD	1.7 A 1 1 1 1 1 1 1	OT A NOT	1)
OUTSIDE OF	IPPLE, (DI:	STANCE	A)
THE PARTY AND ASSESSMENT ASSESSME	1.7.5.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.		
		STANCE	ICE B)
ament T D (D	STANCE A -	DISTUR	107 11
The second state of the second	CAN 111 % 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	PRINTED TO BEET AND ADDRESS OF	The State of the S
NEAREST DOWNS	TREAM DISTU	KRANCE	
CALCULATOR			



SCHEMATIC OF SAMPLING LOCATION

TRAVERSE POINT NUMBER	FRACTION OF STACK I.D.	STACK I.D.	PRODUCT OF COLUMNS 2 AND 3 (TO NEAREST 1/8 INCH)) B	TRAVERSE POINT LOCATI FROM OUTSIDE OF NIPE (SUM OF COLUMNS 4 &
		-			
					*
407		-			
					And the second s
				1	

SAMPLING TRAIN DATA AND CALCULATIONS

TES	r NO		FILTER NO.					
SAMPL	ING STATION		DATE					
	1	AS METER						
TIME	READING CU. FT. V _M	VAC. IN. HG	TEMP.	SAMPLING RATE CFM	APPEARANCE OF PLUME	SAMPLING POINT		
	7							
		-						
C. CONDEN	SATE VOLUME,	ML						
J. COND.	VAPOR VOL.,	.00267 x C	X (400	+ 1 _M) / (29	.9-P _M), CU. I	1.		
E. TOTAL F. SAMPLE	SAMPLED VOL. D VOL., 520	$\times E \times (29)$	CU. FT. 9-P _M) /	29.9 x (460	+ T _M), SCF_			
G. CONCEN	TRATION, 15	.43 x A/F,	GRAINS/S	SCF				
H. MATERI	AL FLOW RATE	E, 60 x G >	B / 700	OO, LBS./HR.		THE TAX PROPERTY OF THE PARTY O		
. SAMPLI		AM	2. W	EATHER CONDI	TIONS			

NOMOGRAPH DATA

PLANT		
DATE		*
SAMPLING	LOCATION	

CALIBRATED PRESSURE DIFFERENTIAL ACROSS ORIFICE, in.H20	∆H _@
AVERAGE METER TEMPERATURE (AMBIENT + 20°F),°F	T _{mavg} .
PERCENT MOISTURE IN GAS STREAM BY VOLUME	B _{wo}
BAROMETRIC PRESSURE AT METER, in.Hg	P _m
STATIC PRESSURE IN STACK, in.Hg $(P_m \pm 0.073 \times STACK GAUGE PRESSURE in in.H_20$	Ps
RATIO OF STATIC PRESSURE TO METER PRESSURE	P _s /P _m
AVERAGE STACK TEMPERATURE, OF	Tsavg.
AVERAGE VELOCITY HEAD, in.H20	ΔP _{avg} .
MAXIMUM VELOCITY HEAD, in.H20	ΔP _{max} .
C FACTOR	
CALCULATED NOZZLE DIAMETER, in.	
ACTUAL NOZZLE DIAMETER, in.	
REFERENCE △p, in.H ₂ 0	

TO DETERMINE SAMPLING RATE WITHOUT NOMOGRAPH

S.R. = 0.33 x
$$V_s \times D^2 \times \frac{T_m}{T_s} \times \frac{P_s}{P_m} \times (1 - \frac{W.V.}{100})$$

S.R. = Isokinetic sampling rate ft^3/min .

Vs = Stack gas velocity, ft/sec.

D = Nozzle diameter in inches

 T_s = Temperature in stack ${}^{\circ}R$ (460 + ${}^{\circ}F$)

T_m = Temperature at meter ^OR (460 + ^OF)

 P_s = Absolute pressure in stack $(P_b + \frac{P_{static}}{13.6})$

P_b = Barometric pressure at sampling point (measured)

 P_{m} = Pressure at meter = P_{b} - P_{meter}

W.V. = Water vapor in stack gas % by vol.

$$D = 1/8'' = 0.125 \text{ in.}$$
 $D^2 = 0.0156$ $.33D^2 = 0.00515$

$$D = 1/4$$
" = 0.250 in. $D^2 = 0.0625 \text{ in}^2$.33 $D^2 = 0.0206$

$$D = 3/8$$
" = 0.375 in. $D^2 = 0.141 \text{ in}^2$.33 $D^2 = 0.0465$

$$D = 1/2'' = 0.500 \text{ in.}$$
 $D^2 = 0.250 \text{ in}^2$ $.33D^2 = 0.0825$

For 1/4" Nozzle

S.R. =
$$V_s \times (0.0206 \times \frac{460 + T_m}{460 + T_s} \times \frac{P_b \pm P_{static}}{P_b \pm P_m} \times \frac{1 - W.V.}{100})$$

0.0206 x
$$\frac{460 + T_{m}}{460 + T_{s}}$$
 x $\frac{P_{b} \pm P_{static}}{P_{b} \pm P_{m}}$ x $\frac{1 - W.V.}{100} = K$

FIELD DATA

PLANT	PROBE LENGTH AND TYPE
DATE	NOZZLE 1.D.
SAMPLING LOCATION	ASSUMED MOISTURE, %
SAMPLE TYPE	SAMPLE BOX NUMBER
RUN NUMBER	METER BOX NUMBER
OPERATOR	METER ΔH_{0}
AMBIENT TEMPERATURE	C FACTOR
BAROMETRIC PRESSURE	
STATIC PRESSURE, (P _S)	HEATER BOX SETTING
FILTER NUMBER (s)	REFERENCE Δ p
FILTER NUMBER (8)	

SCHEMATIC OF TRAVERSE POINT LAYOUT
READ AND RECORD ALL DATA EVERY MINUTES

TRAVERSE	SAMPLING (24-hr TIME,min CLOCK)		VELOCITY HEAD (Δp _s),in.H ₂ 0 DESIRED ACTUAL ORIFICE PRESSURE TEMPERATURE (T _s), F		DRY GAS METER TEMPERATURE INLET (Tmin), of (Tmout), of		PUMP VACUUM,	SAMPLE BOX TEMPERATURE,	TEMPERATURE	
POINT S	SAMPLING (24-hr TIME, min CLOCK)	(V _m), It3	(Δp _s), in. H ₂ 0	DESIRED ACTU	O (T _S), OF	(Tmin), or	(T _{mout}), of	in. Hg		·
						+				
						-		-		
								-	-	
								-		
			7 1-61							
			-							
								+		
								-	+	+
-									-	1
			1							1
			+							
			1	-						
						1				
							-	-		
-							1			
										+
-				1 2 2 3 2						
1			-							
1				_				-		

COMMENTS

PLANT	
LOCATION	
OPERATOR	
DATE	
RUN No.	
SAMPLE BOX No	
METER BOX No	
METER A H@	

C FACTOR	
AMBIENT TEMPERATURE	
BAROMETERIC PRESSURE	
ASSUMED MOISTURE, %	
HEATER BOX SETTING	
PROBE LENGTH, m	
NOZZLE DIAMETER, in	
PROBE MEATER SETTING	

SCHEMATIC OF STACK CROSS SECTION

	SAMPLING TIME (e) min.	PRESSURE	STACK TEMP. (T _S)*F	VELOCITY HEAD (ΔP _S)	ORIFICE PRESSURE DIFFER- ENTIAL (AH) In. H ₂ 0	GAS	GAS SAMPLE TEMPERATURE AT DRY GAS METER		SAMPLE BOX	TEMPERA- TURE OF CAS LEAVING
POINT							INLET (Tm _{in})°F	OUTLET (Tm _{out})°F	TEMPERA- TURE OF	LAST IMPINGER OF
									*	
				-						
				-						
				-	-					
				17940						
TOTAL							avg.	avg.	-	
AVERAGE							avg.		1	1

NOMOGRAPH DATA

PLANT			
DATE		*	
SAMPLING	LOCATION		

CALIBRATED PRESSURE DIFFERENTIAL ACROSS ORIFICE, in.H20	ΔHG
AVERAGE METER TEMPERATURE (AMBIENT + 20°F), °F	T _{mavg} .
PERCENT SISTURE IN GAS STREAM BY VOLUME	B _{wo}
BAROMETRIC PRESSURE AT METER, in.Hg	P _m
STATIC PRESSURE IN STACK, in.Hg $(P_{\rm m} \pm 0.073 \times {\rm STACK~GAUGE~PRESSURE}$ in in.H ₂ 0	Ps
RATIO OF STATIC PRESSURE TO METER PRESSURE	P _s /P _m
AVERAGE STACK TEMPERATURE, OF	Tsavg.
AVERAGE VELOCITY HEAD, in.H20	△P _{avg} .
MAXIMUM VELOCITY HEAD, in.H20	△P _{max} .
C FACTOR	
CALCULATED NOZZLE DIAMETER, in.	
ACTUAL NOZZLE DIAMETER, in.	
REFERENCE △p, in.H ₂ 0	

TO DETERMINE SAMPLING RATE WITHOUT NOMOGRAPH

S.R. = 0.33 x
$$V_S \times D^2 \times \frac{T_m}{T_S} \times \frac{P_S}{P_m} \times (1 - \frac{W.V.}{100})$$

S.R. = Isokinetic sampling rate ft^3/min .

Vs = Stack gas velocity, ft/sec.

D = Nozzle diameter in Inches

 T_s = Temperature in stack $^{\circ}R$ (460 + $^{\circ}F$)

 T_m = Temperature at meter ${}^{\circ}R$ (460 + ${}^{\circ}F$)

 P_s = Absolute pressure in stack $(P_b + \frac{P_{static}}{13.6})$

P_b = Barometric pressure at sampling point (measured)

 P_{m} = Pressure at meter = P_{b} - P_{meter}

W.V. = Water vapor in stack gas % by vol.

$$D = 1/8" = 0.125 \text{ in.}$$
 $D^2 = 0.0156$ $.33D^2 = 0.00515$

$$D = 1/4$$
" = 0.250 in. $D^2 = 0.0625 \text{ in}^2$.33 $D^2 = 0.0206$

$$D = 3/8'' = 0.375 \text{ in.}$$
 $D^2 = 0.141 \text{ in}^2$ $.33D^2 = 0.0465$

$$D = 1/2'' = 0.500 \text{ in.}$$
 $D^2 = 0.250 \text{ in}^2$ $.33D^2 = 0.0825$

For 1/4" Nozzle

S.R. =
$$V_s \times (0.0206 \times \frac{460 + T_m}{460 + T_s} \times \frac{P_b + P_{static}}{P_b + P_m} \times \frac{1 - W.V.}{100})$$

0.0206 x
$$\frac{460 + T_{m}}{460 + T_{s}}$$
 x $\frac{P_{b} + P_{static}}{P_{b} + P_{m}}$ x $\frac{1 - W.V.}{100} = K$

FIELD DATA

PLANT	NOZZLE I.D.
DATE	ASSUMED MOISTURE, %
SAMPLING LOCATION	SAMPLE BOX NUMBER
SAMPLE TYPE	METER BOX NUMBER
RUN NUMBER	METER AHa
OPERATOR	C FACTOR
AMBIENT TEMPERATURE	PROBE HEATER SETTING
BAROMETRIC PRESSURE	HEATER BOX SETTING
STATIC PRESSURE, (Ps)	REFERENCE Δ p
FILTER NUMBER (S)	

SCHEMATIC OF TRAVERSE POINT LAYOUT
READ AND RECORD ALL DATA EVERY MINUTES

RAVERSE POINT NUMBER	SAMPLING (24-hr TIME,min CLOCK)	METER READING (V _m), ft ³	VELOCITY HEAD (Aps),in.H20	ORIFICE DIFFER (AH),i DESIRED	PRESSURE ENTIAL n. H ₂ 0 ACTUAL	STACK TEMPERATURE (T _S), F	DRY GA TEMPE INLET (Imin), F	S METER RATURE OUTLET (Tm jut), of	PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE,	TEMPERATUR
					-		1				
						-	-				
							-				
							-		1		
	the state of the s									-	
											-
			+	1							
					+						
					-	-					1
					1		+				
	-				1		-	1			
							+	+	+		
									-	-	-
											-
											-
			-	1	-						
				-	+						
				-	-	+	-				
	_		A STATE OF THE PARTY OF THE PAR		_		1	.1			
OMMENT!	•										1

PLANT	
LOCATION	
OPERATOR	
DATE	
RUN No.	
SAMPLE BOX No	
METER BOX No.	
METER A HO	

C FACTOR	
AMBIENT TEMPERATURE	
BAROMETERIC PRESSURE	
ASSUMED MOISTURE, %	
HEATER BOX SETTING	
PROBE LENGTH, m	
NOZZLE DIAMETER, in	
PROBE HEATER SETTING	

SCHEMATIC OF STACK CROSS SECTION

POINT					ORIFICE PRESSURE DIFFER-	GAS	SA! TEMPI	AS MPLE ERATURE GAS METER	SAMPLE BOX	TEMPERA- TURE OF GAS LEAVING
	SAMPLING TIME (e) min.	PRESSURE	STACK TEMP. (T _S)*F	VELOCITY HEAD (ΔP _S)	ENTIAL (ΔH) In. H ₂ 0	SAMPLE VOLUME (Vm)ft.3	INLET (Tmin)°F	OUTLET (Tm _{out})°F	TEMPERA- TURE OF	LAST IMPINGER OF
				-						
						-				
					-					
				-	1			Station of		6 5 6
A 1.14		THE STREET		L. Ani.		1 -11-21				
TOTAL	WHITE W.						avg.	avg.		
AVERAGE							avg.			

NOMOGRAPH DATA

PLANT		
DATE		
SAMPLING	LOCATION	

CALIBRATED PRESSURE DIFFERENTIAL ACROSS ORIFICE, in.H20	ΔHG
AVERAGE METER TEMPERATURE (AMBIENT + 20°F),°F	T _{mavg} .
PERCENT MOISTURE IN GAS STREAM BY VOLUME	B _{wo}
BAROMETRIC PRESSURE AT METER, in.Hg	P _m
STATIC PRESSURE IN STACK, in.Hg $(P_{\rm m} \pm 0.073 \times {\rm STACK} \; {\rm GAUGE} \; {\rm PRESSURE} \; {\rm in} \; {\rm in}.{\rm H}_2{\rm O}$	Ps
RATIO OF STATIC PRESSURE TO METER PRESSURE	P _s /P _m
AVERAGE STACK TEMPERATURE, OF	Tsavg.
AVERAGE VELOCITY HEAD, in.H20	$\triangle P_{avg}$.
MAXIMUM VELOCITY HEAD, in.H20	ΔP_{max} .
C FACTOR	
CALCULATED NOZZLE DIAMETER, in.	
ACTUAL NOZZLE DIAMETER, in.	
REFERENCE △p, in.H ₂ 0	

TO DETERMINE SAMPLING RATE WITHOUT NOMOGRAPH

S.R. = 0.33 x
$$V_s \times D^2 \times \frac{T_m}{T_s} \times \frac{P_s}{P_m} \times (1 - \frac{W.V.}{100})$$

S.R. = Isokinetic sampling rate ft^3/min .

V_s = Stack gas velocity, ft/sec.

D = Nozzle diameter in inches

 $T_s = Temperature in stack {}^{\circ}R (460 + {}^{\circ}F)$

 $T_{\rm m}$ = Temperature at meter ${}^{\rm O}R$ (460 + ${}^{\rm O}F$)

 P_s = Absolute pressure in stack $(P_b \pm \frac{P_{static}}{13.6})$

P_b = Barometric pressure at sampling point (measured)

P_m = Pressure at meter = P_b - P_{meter}

W.V. = Water vapor in stack gas % by vol.

$$D = 1/8'' = 0.125 \text{ in.}$$
 $D^2 = 0.0156$ $.33D^2 = 0.00515$

$$D = 1/4'' = 0.250 \text{ in.}$$
 $D^2 = 0.0625 \text{ in}^2$ $.33D^2 = 0.0206$

$$D = 3/8$$
" = 0.375 in. $D^2 = 0.141 \text{ in}^2$.33 $D^2 = 0.0465$

$$D = 1/2'' = 0.500 in.$$
 $D^2 = 0.250 in^2$ $.33D^2 = 0.0825$

For 1/4" Nozzle

S.R. =
$$V_s \times (0.0206 \times \frac{460 + T_m}{460 + T_s} \times \frac{P_b \pm P_{static}}{P_b \pm P_m} \times \frac{1 - W.V.}{100})$$

0.0206 x
$$\frac{460 + T_m}{460 + T_s}$$
 x $\frac{P_b + P_{static}}{P_b + P_m}$ x $\frac{1 - W.V.}{100} = K$

PLANT	C FACTOR
LOCATION	AMBIENT TEMPERATURE
OPERATOR	BAROMETERIC PRESSURE
DATE	ASSUMED MOISTURE, %
RUN No.	HEATER BOX SETTING
SAMPLE BOX No.	PROBE LENGTH, m
METER BOX No	NOZZIE DIAMETER, in
METER A H@	PROBE HEATER SETTING

SCHEMATIC OF STACK CROSS SECTION

					ORIFICE PRESSURE DIFFER-		GAS SAMPLE TEMPERATURE AT DRY GAS METER		THE REAL PROPERTY.	TEMPERA- TURE OF GAS LEAVING
POINT	SAMPLING TIME (e) min.	STATIC PRESSURE (P _S)inHg	STACK TEMP. (T _S)*F	VELOCITY HEAD (ΔP _S)	ENTIAL (AH) In. H ₂ 0	SAMPLE VOLUME (Vm)ft.3	INLET (Tm _{in})°F	OUTLET (Tm _{out})°F	TEMPERA- TURE OF	LAST IMPINGER OF
			14,43						*	12114
				List the						
				budies 5						
	MELLE									
TOTAL							avg.	avg.		
AVERAGE							avg.			1

RAVEI POINI NUMBER	AMPLING (TIME, min C	TIME (24-hr LOCK)	GAS METER READING (V _m),ft ³	VELOCITY HEAD (P _S),in.H ₂ 0	ORIFICE DIFFER (H),in DESIRED	SURE H ₂ 0) ACTUAL	STACK TEMPERATURE (T _S), o _F	RY GA TEMPE INLET (Tmin), of	RATURE OUTLET (Tmout), of	PUMP VACUUM in. Hg	SAMPLE BOX. TEMPERATURE, OF	IMPINGER TEMPERATURI OF
										-		
		-										
					-							

DRY MOLECULAR WEIGHT DETERMINATION

PLANT	COMMENTS:
DATE	
SAMPLING TIME (24-hr CLOCK)	
SAMPLING LOCATION	
SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS	
ANALYTICAL METHOD	
AMBIENT TEMPERATURE	
OPERATOR	

RUN	1			2		3	AVERAGE	MULTIPLIER	MOLECULAR WEIGHT (
GAS	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET	VOLUME		STACK GAS (DRY BAS:
co ₂								44/100 -	
O2 (NET IS ACTUAL O2 READING MINUS ACTUAL CO2 READING)								32/100	
CO (NET IS ACTUAL CO READING MINUS ACTUAL O ₂ READING)								28/100	
N2(NET IS 100 MINUS ACTUAL CO READING)								28/100	

TOTAL

SAMPLIN	MARY	SHEET
---------	------	-------

LOCATION _ PLANT.

SAMPLED SOURCE

RUN	DATE	$N_{\mathbf{p}}$	P _m	Pb	V _m	T _m	$v_{M_{ m std}}$	V _W	V _{Wgas}	% _M	M _d

RUN	riw d	NIM	st	S	p	Year's A Vis	8	S	t	
				Т						

$$v_{m_{std}} = \frac{17.7 \times V_{m} (P_{b} - P_{m})}{(T_{m} + 460)} = \frac{100 \times V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}}$$

$$v_{w_{gas}} = 0.0474 \times V_{w} = \frac{100 \times V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}}$$

$$MW_d = (200_2 \times \frac{44}{100}) + (20_2 \times \frac{32}{100}) + (200 + 20_2) \times \frac{28}{100}$$

$$MW - MW_d \times M_d + 18 (1 - M_d)$$

$$V_s = V_b + V_{st}$$

 $V_s = 5128.8 \times Cp \times \sqrt{NP_g \times (T_g + 460)} \left[\frac{1}{P_s \times MW} \right]^{1/2}$

$$\pi_1 = \frac{1,032 \times (T_s + 450) \times V_{m_{std}}}{V_s \times T_t \times P_s \times M_d \times (D_n)^2}$$

$$P_{b}$$
 Barometric Pressure, in. Γ . Absolute

Ts

Molecular Weight of Stack Gas, Dry Basis

$$T_{\rm t}$$
 Net Time of Test, Min.

apry standard cubic feet at 70°F, 29.92 in. Hg.

bStandard conditions at 70°F, 29.92 in. Hg.

 $^{\text{CVAP}_{\text{S}}}$ x $(T_{\text{S}}$ + 460) is determined by averaging the square root of the product of the velocity head (Ps) and the absolute stack temperature from each sampling point.











PLANT	
DATE	
RUN NO.	

CONTAINER NUMBER	WEIGHT OF PARTICULATE COLLECTED mg								
NORDER	FINAL WEIGHT	TARE WEIGHT	WEIGHT GAIN						
1									
2									
TOTAL									

		OF LIQUID COLLECTED
	IMPINGER VOLUME ml	SILICA GEL WEICHT g
FINAL		
INITIAL		
LIQUID COLLECTED		
TOTAL VOL. COLLECTED	g*	m1

*CONVERT WEIGHT OF WATER TO VOLUME BY DIVIDING TOTAL WEIGHT INCREASE BY DENSITY OF WATER. (1 g/ml):

INCREASE g = VOLUME WATER ml

Figure 5-3. Analytical data.

SIGNIFICANCE OF ERRORS IN STACK SAMPLING MEASUREMENTS

Measurement	Maximum Error, %
Stack Temperature, ts	1.4
Meter Temperature, t _m	1.0
Stack Gage Pressure, Pgs	0.42
Meter Gage Pressure, Pgm	0.42
Atmospheric Pressure, Patm	0.21
Dry Molecular Weight, M _d	0.42
Moisture Content, d Bws (absolute)	1.1
$d B_{WS}/1 - B_{WS}$	1.0
Pressure Head, △p	10.0
Orifice Pressure Differential, Δm	5.0
Pitot Tube Coefficient, Cp	2.4
Orifice Meter Coefficient, Km	1.5
Diameter of Probe Nozzle, Dn	0.80

2.0 MONITORING METHODOLOGY (continued)

STACK SAMPLING FORMULAS

FOR STACK SAMPLING

EQUATION 1-1

equivalent dlameter = 2 ((length) (width)) (length + width)

EQUATION 2-1 - Pitot Tube Coefficient

$$C_{\text{P}}$$
 = C_{P} $\sqrt{\frac{\Delta P}{\Delta P_{\text{test}}}}$

where:

= Pitot tube coefficient of Type S Pitot Tube

= Pitot tube coefficient of standard type pitot tube Pstd (if unknown, use 0.99).

ΔPstd = Velocity head measured by standard type pitot tube.

 $^{\Delta P}$ test = Velocity head measured by Type S pitot tube.

EQUATION 2-2 - Gas Stack Velocity

$$(V_s)$$
avg. = K_pC_p $(V\Delta P)$ avg. $V\frac{(T_s)}{P_s}$ avg.

where:

(V)avg. = Stack gas velocity, feet per second (F.P.S.).

 $K_p = 85.48 \frac{\text{ft.}}{\text{sec.}} (\frac{1\text{b.}}{1\text{b.} \text{mole-}^{\circ}R}) 1/2$ when these units are used. $C_p = \text{Pitot}$ tube coefficient dimensionless.

(T_s)avg. = Average absolute stack gas temperature, CR.

 $(\sqrt{\Delta P})$ avg.= Average velocity head of stack gas, inches H_0O (See Fig. 2-2).

= Absolute stack gas pressure, inches Hg.

Ms = Molecular weight of stack gas (wet basis), 1b./1b.-mole. M_d (1-B_{wo}) + 18B_{wo}

= Dry molecular weight of stack gas (from Method 3).

= Proportion by volume of water vapor in the gas stream (from Method 4).

EQUATION 2-3 - Stack Gas Volumetric Flow Rate

$$Q_s = 3600 (1-B_{wo}) V_s A \begin{pmatrix} T_{std} \end{pmatrix} \begin{pmatrix} P_s \end{pmatrix} \begin{pmatrix} P_s \end{pmatrix} \begin{pmatrix} P_s \end{pmatrix}$$

where:

 Q_s = Volumetric flow rate, dry basis, standard conditions, ft³/hr.

A = Cross-sectional area of stack, ft.²

T_{std} = Absolute temperature at standard conditions, 530°R.

Pstd = Absolute pressure at standard conditions, 29.92 inches Hg.

EQUATION 3-1 - Percent Excess Air

%EA=

$$(\% O_2) - 0.5 (\% CO)$$

 $0.264 (\% N_2) - (\% O_2) + 0.5 (\% CO)$ × 100

where:

% EA = Percent excess air.

% O_2 = Percent oxygen by volume, dry basis.

 $% N_2 = Percent nitrogen by volume, dry basis.$

% CO = Percent carbon monoxide by volume, dry basis.

0.264 = Ratio of oxygen to nitrogen in air by volume.

EQUATION 3-2 Dry Molecular Weight

$$Md = 0.44 (\% CO2) + 0.32 (\% O2) + 0.28 (\% N2 + % CO)$$

where:

Md = Dry molecular weight, lb./lb-mole.

%CO₂ = Percent carbon dioxide by volume, dry basis.

 $%0_2$ = Percent oxygen by volume, dry basis.

 $%N_2$ = Percent nitrogen by volume, dry basis.

0.44 = Molecular weight of carbon dioxide divided by 100.

0.32 = Molecular weight of oxygen divided by 100.

0.28 = Molecular weight of nitrogen and CO divided by 100.

EQUATION 4-1 - Volume of Water Vapor Collected

$$V_{wc} = \frac{(V_f - V_i) pH_2O RT_{std}}{P_{std}M_{H_2O}} = 0.0474 \frac{ft.^3}{ml.} (V_f - V_i)$$

where:

Vwc = Volume of water vapor collected (standard conditions), cu. ft.

Vf = Final volume of impinger contents, ml.

Vi = Initial volume of impinger contents, ml.

R = Ideal gas constant, 21.83 inches Hg - cu. ft./lb. mole- $^{\circ}R$.

pHoO = Density of water, 1 g./ml.

Tstd = Absolute temperature at standard conditions, 530° R.

Pstd = Absolute pressure at standard conditions, 29.92 inches Hg.

MH20 = Molecular weight of water, 18 1b./1b.-mole.

EQUATION 4-2 -Dry Gas Volume

$$V_{\text{mc}} = V_{\text{m}} \begin{pmatrix} P_{\text{m}} \\ P_{\text{std}} \end{pmatrix} \begin{pmatrix} T_{\text{std}} \\ T_{\text{m}} \end{pmatrix} = 17.71 \frac{O_{\text{R}}}{\text{in} \cdot \text{Hg}} \begin{pmatrix} V_{\text{m}} & P_{\text{m}} \\ T_{\text{m}} \end{pmatrix}$$

where:

V_{mc} = Dry gas volume through meter at standard conditions, cu. ft.

 V_{m} = Dry gas volume measured by meter, cu. ft.

 P_{m} = Barometric pressure at the dry gas meter, inches Hg.

Pstd = Pressure at standard conditions, 29.92 inches Hg.

 T_{std} = Absolute temperature at standard conditions, 530° R. T_{m} = Absolute temperature at meter (°F + 460), °R.

Moisture content.

EQUATION 4-3 - Proportion By Volume of Water Vapor.

$$B_{WO} = \frac{V_{WC}}{V_{WC} + V_{MC}} + B_{WM} = \frac{V_{WC}}{V_{WC} + V_{MC}} + (0.025)$$

where:

B = Proportion by volume of water vapor in the gas stream, dimensionless.

B_{wm} = Approximate volumetric proportion of water vapor in the gas stream leaving the impingers, 0.025.

Moisture Determination (Hygrometer)

To determine the water vapor content of the gas with the Hygrometer - wet and dry bulb apparatus, a probe is inserted into the duct and a source of aspiration used to pull a gas sample into the probe past the dry and then the wet thermometers. A mercury manometer is used to measure the vacuum in the system, which in this application will be the static pressure.

To maintain optimum conditions in the apparatus the length of hose between the probe and the apparatus should be varied so that the dry bulb reading is $180^{\rm O}{\rm F}$ or more.

The flow rate through the apparatus should be maintained at 16 FPS, for a $\frac{1}{2}$ " ID tube this would require 1.33 CFM.



Pva - Water vapor pressure in Hygrometer (In. Hg.)

Pvd - Water vapor pressure in duct (In. Hg.)

Pv (wb) - Saturated water vapor pressure at tw (In. Hg.)

Pd - Pressure in duct (static) at sampling point (In. Hg.)

Pb - Barometric pressure (In. Hg.)

Pa - Static pressure in Hygrometer (In. Hg.)

td - Temperature dry bulb (OF)

tw - Temperature wet bulb (°F)

 $P_{\rm va}$ may be obtained from a standard psychrometric chart or calculated from the following formula.

$$P_{va} = P_{v \text{ (wb)}} - \frac{(P_b - P_a - P_{v \text{ (wb)}}) (t_d - t_w)}{2800 - 1.3t_w}$$

$$P_{vd} = \frac{P_b - P_d}{P_b - P_a} \times P_{va}$$

% H2O (volume percent moisture in gas)

$$= \frac{P_{\text{vd}}}{P_{\text{b}} - P_{\text{d}}} \times 100$$

TABLE OF VAPOR PRESSURES OF WATER

In Inche of Mercury

					II Aliciic			1 14 6			9 \$
7	Temp.		1	2	3	4	5	6	7	8	2 1
(-20 -10	.0126 .0.22 .0376	.0119 .0209 .0359	.0112 .0199 .0339	.0106 .0187 .0324	.0100 .0176 .0306	.0095 .0168 .0289	.0089 .0158 .0275	.0084 .0150 .0259	.0080 .0142 .0247	.007 5 .0134 .0233
	0 10 20 30 40	.0376 .0531 .1J25 .1647 .2478	.0398 .0660 .1080 .1716 .2576	.0417 .0696 .1127 .1803 .2677	.0441 .0728 .1186 .1878 .2732	.0463 .0768 .1248 .1955 .2891	.0489 .0810 .1302 .2035 .3004	.0517 .0846 .1370 .2118 .3120	.0541 .0892 .1429 .2203 .3240	.0571 .0932 .1502 .2292 .3364	.0598 .0932 .1567 .2383 .3493
C	50 60 70 80 90	.3626 .5218 .7392 1.032 1.422	.3764 .5407 .7648 1.066 1.467	.3906 .5601 .7912 1.102 1.513	.4052 .5802 .8183 1.138 1.561	.4203 .6009 .8462 1.175 1.610	.4359 .6222 .8750 1.213 1.660	.4520 .6442 .9046 1.253 1.712	.4686 .6669 .9352 1.293 1.765	.4858 .6903 .9666 1.335 1.819	.5035 .7144 .9989 1.378 1.875
	100 110 120 130 140	1.932 2.596 3.446 4.525 5.381	1.992 2.672 3.543 4.647 6.034	2.052 2.749 3.642 4.772 6.190	2.114 2.829 3.744 4.900 6.350	2.178 2.911 3.848 5.031 6.513	2.243 2.995 3.954 5.165 6.680	2.310 3.081 4.063 5.302 6.850	2.379 3.169 4.174 5.442 7.024	2.449 3.259 4.289 5.585 7.202	2.521 3.351 4.406 5.732 7.384
	150 170 180 190	7.569 9.652 12.00 15.29 19.01	7.759 9.885 12.48 15.63 19.42	7.952 10.12 12.77 15.98 19.84	8.150 10.36 13.07 16.34 20.27	8.351 10.61 13.37 16.70 20.70	8.557 10.86 13.67 17.07 21.14	8.767 11.12 13.98 17.44 21.59	8.981 11.38 14.30 17.82 22.05	9.200 11.65 14.62 18.21 22.52	9.424 11.92 14.96 18.61 22.99
0	200 210 220 230 240	23.47 28.75 35.00 42.31 50.84	23.96 29.33 35.68 43.11 51.76	24.46 29.92 36.37 43.92 52.70	24.97 30.52 37.07 44.74 53.65	25.48 31.13 37.78 45.57 54.62	26.00 31.75 38.50 46.41 55.60	26.53 32.38 39.24 47.27 56.60	27.07 33.02 39.99 48.14 57.61	27.62 33.67 40.75 49.03 58.63	28.18 34.33 41.52 49.93 59.67
	250 260 270 280 290	60.72 72.13 85.22 100.2 117.2	61.79 74.36 86.63 101.8 119.0	62.88 74.61 88.06 103.4 120.8	63.98 75.88 89.51 105.0 122.7	65.10 77.16 90.97 106.7 124.6	66.23 78.46 92.45 108.4 126.5	67.38 79.78 93.96 110.1 128.4	68.54 81.11 95.49 111.8 130.4	69.72 82.46 97.03 113.6 132.4	70.92 83.83 98.61 115.4 134.4
	300 310 320 330 340	136.4 158.2 182.6 209.8 240.3		140.6 162.8 137.8 215.6 246.8			147.0 170.0 195.8 224.6 256.7	172.5 198.5 227.7	151.4 175.0 201.3 230.8 263.6	233.9	155.9 180.0 206.9 237.1 270.6
4	350 360 370 380 390 400		357.4 403.4 453.9	319.5 361.8 408.2 459.2	323.5 366.2 413.1 464.6	327.5 370.7 418.1 470.0	292.3 331.7 375.2 423.1 475.5 532.9	335.9 379.8 428.1 481.0	340.1 384.4 433.1 486.6	344.4 389.1 438.2 492.2	307.7 348.7 393.8 443.4 497.9 557.3

$$V_{m_{std}} = V_{m} \left(\frac{T_{std}}{T_{m}}\right) \left(\frac{P_{bar} + \Delta H}{13.6}\right) = \frac{V_{mstd}}{V_{mstd}} = \frac{V_{$$

$$(17.71 \frac{o_R}{\text{in. Hg}}) V_m \left(\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m}\right)$$

where:

= Volume of gas sample through the dry gas meter v = Volume or gas sample ... ft. mstd (standard conditions), cu. ft.

V = Volume of gas sample through the dry gas meter (meter conditions), cu. ft.

T_{std} = Absolute temperature at standard conditions, 530°R.

T_m = Average dry gas meter temperature, R.

par = Barometric pressure at the orifice meter, inches Hg.

ΔH = Average pressure drop across the orifice meter, inches H,O.

13.6 = Specific gravity of mercury.

Pstd = Absolute pressure at standard conditions, 29.92 inches Hg.

EQUATION - 5-2 - Volume of Water Vapor

$$v_{\text{wstd}} = v_{1} \cdot \left(\frac{\rho_{\text{H}_{2}}}{M_{\text{H}_{2}}}\right) \cdot \left(\frac{\rho_{\text{Std}}}{\rho_{\text{std}}}\right) = \left(0.0474 \cdot \frac{\text{cu. ft.}}{\text{ml.}}\right) v_{1} \cdot c$$

where:

V = Volume of water vapor wstd (standard conditions) cu. ft. = Volume of water vapor in the gas sample

= Total volume of liquid collected in impingers and silica gel (fig. 5-2 ml.

PHO = Density of water, 1 g./ml.

= Molecular weight of water, 18 lb/lb mole. MH20

= Ideal gas constant, 21.83 in Hg-cu. ft./lb. mole-OR. = Absolute temperature at standard conditions, 530°R.

pstd = Absolute pressure at standard conditions, 29.92 in Hg. EQUATION 5-3 - Moisture Content

$$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$$

where:

B = Proportion by volume of water in the gas stream.
dimensionless.

 V_{w} = Volume of water in the gas sample (standard conditions), cu. ft.

V_m = Volume of gas sample through the dry gas meter std (standard conditions) cu. ft.

EQUATION 5-4 - Concentration in gr./s.c.f.

$$C_{s}^{\bullet} = \begin{pmatrix} 0.0154 & \frac{gr.}{mg.} \end{pmatrix} \begin{pmatrix} M_{n} \\ V_{m} \end{pmatrix}$$

where:

Mn = Total amount of particulate matter collected, mg.

V = Volume of gas sample through dry gas meter
mstd (standard conditions), cu. ft.

EQUATION 5-5 - Concentration in 1b./cu. ft.

$$C = \frac{\frac{(1 \quad 1b.)}{(453,600 \text{ mg.})} M_{n}}{V_{m}} = 2.205 \times 10^{-6} \frac{M_{n}}{V_{m}}$$

where:

453,600 = Mg/1b.

M, = Total amount of particulate matter collected, mg.

V = Volume of gas sample through dry gas meter std (standard conditions), cu. ft.

EQUATION 5-6 - Isokinetic Variation

$$I = \frac{T_{s} \left[\frac{V_{1_{c}}(P_{H_{2}O})R}{M_{H_{2}O}} + \frac{V_{m}}{T_{m}}(P_{bar} + \frac{H}{13.6})\right] \times 100}{\frac{\theta V_{s}P_{s}A_{n}}{Sec.}}$$

$$T_{s} \left(\frac{1.667 \text{ min.}}{Sec.}\right) \left[\frac{(0.00267 \text{ in.Hg. cu. ft.}) V_{s} + \frac{V_{m}}{T_{m}}(P_{bar} + \frac{\Delta H}{13.6})}{m1.-^{O}R.}\right] \times \frac{V_{m}}{Sec.}$$

where:

I = Percent of isokinetic sampling.

V₁ = Total volume of liquid collected in impingers

c and silica gel, ml.

 ρ H₂O = Density of water, 1 g/ml.

R = Ideal gas constant, 21.83 inches Hg-cu. ft./lb. mole-R.

MH20 = Molecular weight of water, 18 1b./1b.-mole.

T_m = Absolute average dry gas mater temperature (see page 40), R.

Pbar = Barometric pressure at sampling site, inches Hg.

 ΔH = Average pressure drop across the orifice (see page 40), inches H_0O .

T_s = Absolute average stack jas temperature (see page 40), OR.

 θ = Total sampling time, min.

V_s = Stack gas velocity calculated by Method 2, Equation 2-2, ft./sec.

Ps = Absolute stack gas pressure, inches Hg.

 $A_n = Cross-sectional$ area of nozzle, sq. ft.

EQUATION 8-1 Dry Gas Volume

$$V_{m_{std}} = V_{m} \stackrel{(I)}{\leftarrow} \stackrel{(I)}{\leftarrow} \stackrel{(P_{bar})}{\stackrel{(P_{bar})}{\leftarrow}} = 17.71 \stackrel{\circ}{=} \frac{N_{m_{std}}}{\text{in.Hg.}} \stackrel{(V_{m_{bar}})}{\stackrel{(P_{bar})}{\leftarrow}}$$

where:

we std (standard conditions), cu. ft. = Volum of gas sample through the dry gas meter

= Volume of gas sample through the dry gas meter (meter conditions), cu. ft.

= Absolute temperature at standard conditions , cu. ft.

= Average dry gas meter temperature, OR.

= Barometric pressure at the orifice meter, in. Hg.

P_{std} = Absolute pressure at standard conditions, 29.92 in. Hg.

EQUATION 6-2 - Sulfur Dioxide Concentration

$$C_{so2} = \begin{cases} 7.05 \times 10^{-5} & \frac{1b.-1.}{g.-ml.} \end{cases} \frac{(V_t - V_{tb})}{\frac{V_t}{v_{ab}}} \frac{(V_soln)}{V_a}$$

where:

Cso, = Concentration of sulfur dioxide at standard conditions, dry basis, lb./cu. ft.

7.05X10-5 = Conversion factor including the number of grams per gram equivalent of sulfur dioxide (32 g./g.-eq.), 153.5 g./lb., and 1,000 ml./l,1b.-1./g.-ml.

V = Volume of barium perchlorate titrant used for the sample, ml.

V_{tb}= Volume of barium perchlorate titrant used for the blank, ml.

N = Normality of barium perchlorate titrant, g.-eg./1.

V soln = Total solution volume of sulfur dioxide, ml.

Va = Volume of sample aliquot titrated, mi.

v std = Volume of gas sample through the dry gas meter (standard conditions), see Equation 6-1, cu. ft. EQUATION 7-1 - Sample Volume

$$v_{sc} = \frac{T_{std}}{P_{std}} \frac{(v_{f} - v_{a})}{(T_{f}T_{i})} = \frac{(v_{f}P_{i})}{(v_{f}T_{i})} = \frac{(v_{f}P_{i})}{(v_{f}T_{i})$$

where:

V = Sample volume at standard conditions (dry basis), ml.

T_{std} = Absolute temperature at standard condtions, 530°R.

Pstd = Pressure at standard condtions, 29.92 in. Hg.

 V_f = Volume of flask and valve, ml.

V = Volume of absorbing solution, 25 ml.

P = Final absolute pressure of flask, in. Hg.

P. = Initial absolute pressure of flask, in. Hg.

T_f = Final absolute temperature of flask, Ok.

T; = Initial absolute temperature of flask, OR.

EQUATION 7-2 - Sample Concentration

$$C = \frac{(m)(\frac{1}{100})(\frac{1}{1.6\times10^{4}})}{(\frac{1}{1.6\times10^{4}})} = \frac{(6.2\times10^{-5})}{(6.2\times10^{-5})} = \frac{(m)(\frac{m}{100})}{(6.2\times10^{-5})}$$

C = Concentration of NO as NO (dry basis), lb./s.c.f.

m = Mass of NO, in gas sample, ug.

V = Sample volume at standard conditions (dry basis), ml.

EQUATION 8-1 - Dry Gas Volume

$$V_{m_{std}} = V_{m} \frac{\left(\frac{T_{std}}{Std}\right)\left(\frac{P_{bar} + \Delta H/13.6}{P_{std}}\right)}{\left(\frac{T_{m_{std}}}{T_{m_{std}}}\right)} = \left(\frac{17.71 \frac{O_{R}}{In.Hg.}}{In.Hg.}\right)\left(\frac{P_{bar} + \Delta H/13.6}{T_{m_{std}}}\right)$$

where:

= Volume of gas sample through the dry gas meter (standard mstd conditions), cu. ft.

V_m = Volume of gas sample through the dry gas meter (meter conditions), cu. ft.

T_{std} = Absolute temperature at standard conditions, 530°k.

T_m = Average dry gas meter temperature, °k.

bar = Barometric pressure at the orifice meter, in. Hg.

AH = Pressure drop across the orifice meter, in. Hou.

13.6 = Specific gravity of mercury.

Pstd = Absolute pressure at standard conditions, 29.92 in. Hg.

EQUATION 8-2 - Sulfuric Acid Concentration

$$C_{H_2SO_4} = (1.08 \times 10^{-4} \frac{1b.-1.}{g.-ml.}) \frac{(v_t - v_{tb})(N)(\frac{v_{soln}}{v_a})}{v_{mstd}}$$

where:

CH₂SO₄ = Concentration of Sulfuric acid at standard conditions dry basis, lb./ cu. ft.

1.08.10⁻⁴ = Conversion factor including the number of grams per gram equivalent of sulfuric acid (49 g./g.-eq.), 453.6 g./lb., and 1,000 ml./l., lb.-l.g.-ml.

V_t = Volume of barium perchlorate titrant used for the sample, ml.

Vtb = Volume of barium perchlorate titrant used for the blank, ml.

N = Normality of barium perchlorate titrant, g.-eq./1.

V_{soln} = Total solution volume of sulfuric acid (first impinger and filter), ml.

V = Volume of sample aliquot titrated, ml.

V = Volume of gas sample through the dry gas meter std (standard conditions), cu. ft.. see Equation 8-1.

EQUATION 8-3 - Sulfur Dioxide Concentration

$$C_{so_2} = (7.05 \times 10^{-5} \frac{1b.-1.}{b.-ml.}) \frac{(v_t - v_{tb})(\underline{N})(\frac{v_{soln}}{v_a})}{v_{mstd}}$$

where:

C = Concentration of sulfur dioxide at standard conditions, dry basis, lb./cu. ft.

7.05X10⁻⁵= Conversion factor including the number of grams per gram equivalent of sulfur dioxide (ew g./g.-eq.) 453.6 g./lb., and 1,000 ml./l., lb.-l/g.-ml.

V_t = Volume of barium perchlorate titrant used for the sample, ml.

Vtb Volume of barium perchlorate titrant used for the blank, ml.

N = Normality of barium perchlorate titrant, g.-eq./1.

V_{soln} = Total solution volume of sulfur dioxide (second and third impingers), ml.

V = Volume of sample aliquot titrated, ml.

V = Volume of gas sample through the dry gas meter (standard conditions), cu. ft., see Equation 8-1.

TO DETERMINE SAMPLING RATE WITHOUT NOMOGRAPH

S.R. = 0.33 x
$$V_s \times D^2 \times \frac{T_m}{T_s} \times \frac{P_s}{P_m} \times (1 - \frac{W.V.}{100})$$

S.R. = Isokinetic sampling rate ft 3/min.

V_s = Stack gas velocity, ft/sec.

D = Nozzle diameter in inches

 T_s = Temperature in stack ${}^{\circ}R$ (460 + ${}^{\circ}F$)

 $T_m = Temperature at meter {}^{\circ}R (460 + {}^{\circ}F)$

 P_s = Absolute pressure in stack $(P_b \pm \frac{P_{static}}{13.6})$

P_b = Barometric pressure at sampling point (measured)

P = Pressure at meter = P = P meter

W.V. = Water vapor in stack gas % by vol.

$$D = 1/8" = 0.125 \text{ in.}$$
 $D^2 = 0.0156 \cdot 33D^2 = 0.00515$

D =
$$1/4$$
" = 0.250 in. D^2 = 0.0625 in² .33 D^2 = 0.0206

$$D = 3/8" = 0.375 \text{ in.}$$
 $D^2 = 0.141 \text{ in}^2 .33D^2 = 0.0465$

$$D = 1/2" = 0.500 \text{ in}$$
. $D^2 = 0.250 \text{ in}^2 .33D^2 = 0.0825$

For 1/4" Nozzle

S.R. =
$$V_s \times (0.0206 \times \frac{460 + T_m}{460 + T_s} \times \frac{P_b + P_{static}}{P_b + P_m} \times \frac{1 - W.V.}{100})$$

$$0.0206 \times \frac{460 + T_{m}}{460 + T_{s}} \times \frac{{}^{4}b + {}^{5}static}{{}^{2}b + {}^{4}m} \times \frac{1 - w.v.}{100} = K$$

$$S \cdot R \cdot = K V_{S}$$

2.0 MONITOFING METHODOLOGY (continued)

DESCRIPTION,
OPERATING INSTRUCTIONS,
AND PROCEDURES

Leak Test	16
Sample Run	16
Shutdown	1.7
Shutdown	
Figures	
	Figure No.
Meter Control Case	
Stak Samplr Flow System	2
Wiring Diagram	3
Pitobe	4
120000	
Probe Temperature Curves	5
Sample Case Outline Dimensions	6
Monorail End Plate Assembly	7
Monorail Assembly	
nonverse nobelinely	
Sample Case Assembly	• • • • • • 9
Sample Case Identification List	9-A
Thermocouple Placement	10

Appendix

Supplemental

Operating Instruction Magnehelic Gage Staksamplr (Optional)....Supplement A

Operating Instructions for Staksamplr with Digital Temperature Readout (Optional)Supplement B

NOTE: Supplemental instruction supplied with manual apply only to units supplied with either/or of the above options.

INSTRUCTIONS

- 1. <u>Preliminary Inspection</u>: Upon unpacking, please inspect all parts for damage in shipment. If damage has occurred, please notify carrier immediately. Save all packing material for their inspection.
- 2. Factory Guarantee: You are protected by a one year factory guarantee against defective material or workmanship, subject to inspection and replacement F.O.B. factory. If the unit appears defective, whether new or old, it should be returned to the factory for inspection. This is less expensive than unauthorized field repairs, which may void the guarantee or render minor parts replacement impossible due to damage to major parts.
- 3. <u>Introduction</u>: The R.A.C. Train Stacksamplr was developed by the Emissions Testing Branch of the Office of Air Programs, E.P.A. It is specified in Volume 42, Number 160 of the <u>Federal Register</u> under the topic "Standards of Performance for New Stationary Sources," "Method 5 Particulate Sampling," and with slight modification "Method 8 Determination of SO₂, SO₃, and Sulfuric Acid Mist," "Method 102 Determination of Particulate and Gaseous Mercury Emissions," "Method 104 Determination of Beryllium Emissions."

The sampling train has four major imponents: (1) The pitobe assembly includes the probe nozzle, a heated, glass lined (optional) probe, and an "S" type pitot tube for monitoring gas velocity during sampling. (2) The sample case has a heated portion for the filter, cyclone and flask, and an ice bath portion for the impingers. (3) The umbilical cord connects the sample box with the meter box. It is a development of the aquanaut program called "Life Line." (4) The meter case consists of a dual inclined vertical manometer, an orifice meter, vacuum pump, dry gas meter, thermometers and electrical controls for sampling.

4. Assembling the Unit: After the unit has been completely unpacked and checked for breakage and exclusion of parts (use the included packing slip for this purpose) a trial assembly should be completed in the following manner. Not all the procedures presented here need to be completed with a new unit. However, they do help familiarize oneself with the unit and they comprise the necessary maintenance which must be performed as the stacksamplr ages.

Meter Control Case: #201009 - A schematic of the meter case plumbing is shown in Figure 2. The components and a brief description of their function are given below.

The pitot tube lines of the umbilical cord connect through a quick-disconnect fitting to an inclined/vertical manometer in the meter case and the umbilical cord sample line connects through a quick disconnect to the vacuum pump.

The pump intake vacuum, and indirectly the pressure drop across the collection apparatus, is monitored with a vacuum gauge just after the quick disconnect. The pressure drop across the sample apparatus is the gauge vacuum less the stack draft.

A bypass valve is in parallel with the vacuum pump to give fine flow control and to permit recirculation of gases at low sample rate so that the pump motor is not overloaded. Downstream of the pump and bypass valve are a thermometer, dry gas meter, another thermometer, and a calibrated orifice with an inclined manometer in parallel. The calibrated orifice and inclined manometer read in inches of water and are used to indicate the instantaneous sampling rate. The dry gas meter gives an integrated gas-sample volume. The average of the two temperatures on each side of the dry gas meter gives the temperature at which the volume is sampled. The meter pressure is the atmospheric pressure.

The electrical circuitry for the meter case is shown schematically in Figure 3. The electrical controls are shown in Figure 1. The meter case has a pilot light to indicate when the meter case is energized. Five toggle switches are located on the front of the meter case. They are as follows:

- 1. Vacuum pump and pilot light.
- Fan in the sample case and a pilot light on the meter case.
- 3. Heating element in the sample case and a pilot light on the meter case, all in series with the toggle switch for the sample case fan. This prevents the heating element from operating without the fan; however, the fan can operate without the heating element.
- 4. Probe heating element controlled by a variable transformer and a pilot light.
- Orifice meter, manometer, by-pass valve assembly, and pitot light.

Power for the sample case fan, heating element, and the probe heating element along with a common ground are connected to a fourpronged female amphenol in the meter case for ready connection to the umbilical cord.

The meter control case is shipped completely assembled, however, there are several items which should be checked. Unlock the door, open it, and lift it up off the pin type hinges. Remove the cabinet by removing screws around the bottom and the two screws in the upper right and left corners of the front panel and lift the cabinet off. The chassis and front panel will stay intact. Check the general condition of the unit paying particular attention to the tubing and electrical connections.

Check the pump oil, fill to mark if low, note the cabinet has a door on the side so that the oil may be checked regularly, and changed if dirty, without removing the entire cabinet. The door also allows access to the pump filter, which should be cleaned regularly.

Check the dry-gas meter thermometers against a mercury-inglass thermometer. They should read room temperature.

Make sure the quick disconnects are clean. A drop of penetrating oil helps keep them in good working order.

After the manometer is opened, attach the manometer lines to the dual inclined vertical manometer. They are numbered to correspond to the manometer ports. Specific instructions for this procedure are found on the front of the manometer. <u>CAUTION</u>: Always close the ports before transporting the meter control case, this simple procedure will save a large clean-up job and/or costly repair.

Manometer fluids are color-coded: red is used for the pitot tube manometer and yellow is for the orifice manometer for ease of reading in the field.

After making sure the manometer ports are open and the manometer lines connected, level the manometer and check the fluid level. The manometer can be filled with fluid by removing the screw on the left side. When the manometer is zeroed, the fluid-level plunger should have about 1/4-to-1/2-inch travel inward.

Blow through the pitot tube quick connects to check for obstructions. The pitot tube manometer should respond.

After sampling, always check the pitot and orifice manometer lines. They should be free of fluid. Check for leaks, especially around the fluid-level plunger and drain screws. Replace the fluid

level plunger or O-rings, when this becomes necessary. Wipe the dual manometer clean. If the dual manometer is unusually dirty, clean as recommended by the manufacturer. Replace the red manometer fluid, if it is faded.

Plug the meter box power cord into a 110-volt outlet. The power indicator light should go on and a click should be heard. The click is the sound of the solenoid valves moving into the position. If the clicking sound does not occur, check the fuse power source, plug, power cord and connections, bulb and solenoid valve.

The valve switch operates the solenoid valve assembly, which contains three 2-way solenoid valves. Two are usually closed and one is open. When the valve switch is turned off, the two open valves close and the flow into the manometer is blocked and the closed solenoid valve opens to allow the pressure to equalize. This allows the manometer to be zeroed while the pump is running.

The solenoid assembly operates only on the orifice manometer. To zero the pitot tube manometer, the pitot tube lines can be disconnected at the quick connects on the meter case.

Turn the coarse-adjust valve to the <u>OFF</u> position, for a short period only and fully open the fine-adjust valve. Turn on all switches to check the lights. The heater light should not go on until the fan switch is also on. If any of the lights do not function, check for defective parts, including switches, light fuses and wiring.

Turn off all switches except the pump switch. Turn on the valve switch and carefully adjust the coarse-adjust and fine-adjust valves. The orifice meter manometer should respond to valve controls. If no movement is observed, check the solenoid valves or the orifice meter system.

Check the Amphenol outlet with a voltmeter or check light by connecting the leads to the different terminals. When connected across the variable transformer, the voltage meter or check light should respond.

Check for leakage by inserting a plugged male quick connect into the sample port. Make sure that the valve switch is off and then activate the pump. Turn the coarse-adjust valve to the <u>ON</u> position and close fully the fine-adjust valve. The vacuum gauge should read about 27 inches of mercury for a barometric pressure of 30 inches of mercury. Check the leakage rate using the reading on the dry gas meter and a watch. If leakage exceed 0.02 cubic foot per minute, find and correct the leak or leaks. Parts to check are the pump, vacuum gauge, metering valves and pipes.

Umbilical Cord: The umbilical cord connects the last modified Greenburg-Smith impinger, the pitot tube, and the heating element at the sampling case to the meter case which is located in a convenient place within 300 feet of the sample port. The umbilical cord consists of five parts:

- A 3/8 inch vacuum hose with a quick disconnect to the sample head and a quick disconnect cornection to the meter case.
- 2. Two 1/4 inch lines made of tygon tubing with quick disconnects on both ends of the tubing (connects pitot tube to the meter case manometer).
- 3. Five multistrand insulated conductors with Amphenol connector on both ends(connects sample case circuit to meter case power supply).
- 4. Ground wire.

5. Sample Head: 996109 - The socket connection of the sample head connects the last impinger to the umbilical cord. It consists of a thermometer, check valve, stainless steel tubing, and a quick-disconnect connection.

The umbilical cord is checked out in the following manner:

Wipe the vacuum line and pitot line (1-2) quick connects clean. A drop of penetrating oil on each helps keep them in good working condition.

Check the dial thermometer on the sample head. The temperature should check against room temperature when a mercury-in-glass thermometer is used as the standard.

Check the electrical lines for continuity using an ohmmeter or a battery-light system. Make sure that the leads are connected to the proper prongs. If there is no continuity in any of the lines, check the Amphenol connections.

Disconnect the joint at the check valve and add a drop of lubricating oil on the valve.

Test the vacuum line for leaks by blocking the inlet of the sample head with a plugged ball joint. Connect the line to the meter case vacuum. If leakage is noted, check all connections first and then, if necessary, check the tubing. If the cause is not readily identified, slightly pressurize the line and check for leaks using soapy water.

Connect one end of the pitot-tube line to a 36-inch U-tube mercury manometer or a similar device. Pull a vacuum of at least 10 inches, seal the tubing at the pump end, and check for leaks by noting the mercury manometer. Do the same for the other pitot-tube line and the vacuum line.

Sample Case: Figure 9 and 9A - The ball joint from the pitobe onnects directly to a glass cyclone located in the sampling box, which is designed to remove large particles. The cyclone is followed by a glass filter holder with coarse-porosity fritted glass—ter support. Both the cyclone and filter are positioned in the heate, portion of the sampling box, which is usually maintained at 250°F. The filter is usually glass fiber of 0.3 micron porosity. Catalog #994553, 2.5", #994554, 3", #994555, 4".

A separate ice bath impinger case is attached to the heated sample case with vertical moving slides. The outlet of the filter in the heated sample case attaches to four Greenburg-Smith impingers in the ice bath case. Only the second impinger has the original tip, the other three have been made without the tip in order to decrease the pressure drop through them. Other glass configurations are available to comply with other test methods.

The front panel assembly houses the heater, fan and motor, adustable thermostat, and electrical circuitry. A hinged door with two quarter turn fasteners permits easy access to the cyclone and filter assembly.

The sample case is checked in the following manner:

Using an Amphenol adapter, plug into a 110-volt source. The fan and heater should go on. Failure to operate may be caused by a faulty electrical source, a poor connection, a defective fan, or a defective heating element. Check the thermostat operation by monitoring the dial thermometer in the heated section of the case. The temperature will generally fluctuate 20 to 30° about the average after it stabilizes. The usual setting is 250°F, but the thermostat can be adjusted to the setting desired.

Check the probe heater socket with a voltmeter or with a 110-volt check light. Its output voltage is determined by the probe voltage control setting on the meter control case panel. This socket should only be used for the probe as other electrical loads might damage the voltage control.

For recording purposes, the cases should be numbered. At least three sets of the impinger case assemblies, including all the glassware should be on hand for a stack test and preferably more, depending on the number of runs required in a day. The availability of several sets increases efficiency during the test since the sample train can be cleaned while the second run is being made or the trains can be cleaned after all runs have been completed.

Glassware: See Figure 2 - Wash the cyclone, flask, filter holder, frit, glass connectors, and impingers with glass cleaning detergent. After sampling, the hard-to-clean parts are cleaned with dichromate sulfuric acid cleaning solution. Rinse all parts with distilled, deionized water, and then acetone; air dry. Reassemble the impingers using a thin coat of acetone-insoluble silicone stopcock grease on the upper half of the taper joints. After sampling the stopcock grease should be wiped off before washing. When the glassware is stored before sampling, cover exposed openings to avoid contamination.

Assemble the glassware placing the cyclone, filter, and flask in the heated sample case. The side inlet of the cyclone faces the probe outlet, the flask attaches to the bottom of the cyclone and the right angle bend of the filter holder attaches to the top of the cyclone. The impingers are then placed in the ice bath case, standard Greenburg-Smith plated impinger is second if the set up is for particulate sampling. A glass right angle bend connects the filter to the first impinger and glass "U's" connect the impingers in series. Make sure the elbow and "U's" are positioned so that a small exit, either ball or socket is always attached to a larger entrance, either ball or socket, this orientation prevents the sample from hanging up if ball and sockets are not properly aligned.

Probe: See Figure 4 - The following procedure is not absoltely necessary with a new probe, however, the procedure is strongly recommended since it allows familiarization with the new unit. This procedure should be followed after the probe has been used.

To disassemble the pitobe, first remove the Swagelok union except for the welded nut. The nozzle is usually removed in the field and carried separately. Check for broken glass chips in pitobe with optional glass liner.

Remove the glass liner from the sheath and check visually for broken or fractured sections. The most common area of broken or ractured sections is within 1-1/2 inches from the front and approximately 3 inches from the rear. Some fractures on the back end are hard to see because of the tape and rubber stopper. One way of checking is to gently twist the glass probe and listen for grating sounds. Inspect the electrical system of the probe for visible shorts or burned spots shown by uniform darkening of the high-temperature insulation pe, and the power cord connection. Then plug the power cord into a ariable transformer and set the power rating at about 55 volts. The probe should become warm to the touch over its entire length in a few minutes. If the probe does not heat, check the variable transformer for proper voltage and for loose connections in the plug and Nichrome re. Shorts are indicated by partial heating in the rear portion of the probe. Breaks in the Nichrome wire can be checked with an ohmmeter or a battery-light system.

After sampling, if the probe is in good order, per the above procedure, proceed with the cleaning process. Wipe the grease from the ball joint. Clean the probe internally by brushing, first using tap water, then distilled, deionized water followed by acetone. Rinse the probe with acetone and allow it to dry in the air. Inspect visually for cleanliness and repeat the procedure if necessary.

Remove the quick connects from the pitot tube and wipe them clean. rop of penetrating oil helps keep them in good working condition.

^{*}RAC Probe brush available (201062)

Use compressed air to blow out the pitot tube. Both the pitot tube and sheath should be wiped or washed clean with water and air dried. Inspect the pitot tube openings for damage and misalignment, and if necessary, repair and recalibrate the tube.

After the parts are cleaned and inspected, assemble the pitobe components except the nozzle. Insert the liner into the sheath, making sure that the rubber stopper seats properly onto the sheath. The front end of the glass liner should be about flush with the front end of the welded union nut. This prevents the union from pushing against the probe and chipping the end or unseating the rubber stopper. Replace the Swagelok union. The union should be only finger tight. The use of a wrench can cause cracks within the first 1/2 inch of the probe.

Cover the open ends of the probe with serum caps or similar covers to avoid contamination.

The graphs in Figure 5 may be used to determine the probe heat setting required. If the probes are not constructed as outlined or a calibration of the probes is required, similar graphs can be constructed by using a heat source and measuring the inlet and outlet temperatures at several variable transformer settings while passing air through at about 0.75 cubic foot per minute.

Inspect the edge of the nozzles for damage. If damaged, repair and recalibrate. Clean the nozzle by scrubbing and rinse with distilled, deionized water, and then with acetone; air dry. Cover the open ends with serum caps or similar covers to avoid contamination or damage to the knife edge.

 $\underline{\text{Monorail:}}$ The Monorail is composed of the following parts, please locate them with the assistance of Figs. 7 and 8.

(1.) Monorail; 5 ft. length for 3 ft. probe, 7 ft. length for 5 ft. probe, and 12 ft. length for 10 ft. probe.

- (2.) Pulley assembly (on pulley bar)
- (3.) End plates (2)
- (4.) Position nuts with springs (2)
- (5.) Position bolts (2)
- (6.) $1/4 20 \times 1$ in. with nut and washer (1)
- (7.) Slotted steel angles (2) 6 ft. lengths
- (8.) Slotted steel angle (1) 2 ft. length
- (9.) 5/16 X 5/8 in. with nuts (7)

End Plate Assembly: To one end plate, as orientated in Fig. 2, apply the following procedures, (see Figs. 7 and 8).

- A. Insert the position bolt through the opening in the tab which is perpendicular to the "T" shaped end plate so that the head of the bolt is outside the "T".
- B. Screw position nut (spring toward inside of "T") on bolt so that it catches only the first few threads.
- C. Slide Monorail, open end down, over the tab on the end plate and under the position nut so that the grooves in the nut are aligned with the edges of the Monorail and are holding the Monorail as shown in Fig. 7.
- D. Tighten position bolt and Monorail will be held firmly to end plate. Make sure end plate is butted to Monorail.
- E. Slide pulley assembly, preassembled to pulley bar, into the Monorail as shown in Fig. 8.
- F. Repeat steps A through D with second end plate. This will hold pulley a sembly captive on Monorail.

Mounting Monorail: Figure 6 - There are many ways of attaching the Monorail to the stack and of supporting the other end. These procedures depend on the type of stack and the location of the sampling port with reference to a roof top or cat-walk. Outlined below are several general procedures which should be followed when mounting the unit.

- A. Either end plate may be attached to the stack, however, the direction in which the prongs on the pulley bar are pointed, to the left or right with respect to the sides of the Monorail, will determine the orientation of the sample case. When looking down the length of the Monorail toward the stack the prongs of the pulley bar should point to your left. Thus when the sample case is hung on the pulley bar with the Monorail orientated in this manner the probe will be pointed in the appropriate direction.
- B. Mount appropriate end plate to the stack. Consult Fig. 7 for hole sizes and locations.
- C. The end plate not attached to the stack may be supported in various ways. The two 6 ft. slotted angles are generally attached to the end plate and these legs spread to form an "A", the 2 ft. section being used as the cross member of the "A" to add rigidity. The 6 ft. sections may be attached to the end plate anywhere along their length depending on the desired height of the Monorail. Use the 7 - 5/16 X 5/8 in. bolts with nuts to secure the slotted angles in the desired position.

Mounting the Sample Case: It is suggested that the sample case be mounted before water and ice are added to the condensing section to eliminate unnecessary strain.

A. Lift the sample box to the height of the pulley bar and slip the prongs through the corresponding holes in the T-bar on the Monorail cabinet support. B. Push in on the mounting handle until it mates with the captive nut on the pulley bar and tighten.

The sample case can be removed from the Monorail by simply reversing the two above steps.

Field Operation: Presurvey:

Sampling sites on the stack should be selected so that there is a uniformity of gas mixture and the stack gases should be as free as possible from turbulence. When selecting a site the usual rule is for measurements to be made, eight diameters downstream from a disturbance and three diameters upstream. Disturbances are usually caused by inlets, outlets, bends or constrictions in a stack. This rule cannot always be adhered to and in such cases compromises must be made. In doing this, flow measurements and sampling techniques must be carefully applied to minimize errors.

Because sampling approaches vary, the description of the operation of the isokinetic sampling equipment will be confined to the use of the nomographs, assembly of the components, and adjustment of the flow rate to isokinetic conditions once the probe is positioned at the desired sampling point.

Nomographs:

Slide rule nomograph Side 1 and 2 (Standard) #201014 Consult the instruction booklet titled "Programmed Stack Calculator Instruction Book" which accompanied your slide rule nomograph. Instruction booklet can be found in the leather carrying case that is provided for your nomograph.

E.P.A. type nomograph (Optional) #997600 Consult the instruction sheet which accompanied your E.P.A. nomograph.

Pitobe Assembly:

Remove the cover from the nozzle side of the stainless steel union on the probe sheath.

Remove the cover from the shank end of the selected nozzle (obtained from the nomograph), insert the nozzle in the probe sheath union, and finger tighten the union. Avoid the use of wrenches as this would bind the ferrules to the nozzle shank and could cause the glass probe to crack. Keep the nozzle tip and the ball joint on the glass probe covered until the assembly of the equipment is complete and sampling is about to begin. Mark the probe with heat-resistant tape or by some other method to denote the proper distance into the stack or duct for each sampling point. This distance was determined when the stack was divided into sampling areas.

Attach a temperature probe to the metal sheath of the sampling probe so that the sensor does not touch any metal. Its position should be in accordance with Figure 10 to avoid interference with the gas flow. Probes with pyrometers in place can be supplied by Research Appliance Company.

Sample Box Assembly:

Place the tared filter in the filter holder and record the filter number on a data sheet. Tighten the clamps around the filter holder to prevent leakage around the rubber gasket.

Assemble the collection system, as shown in Figure 2, or as dictated by the requirements of the test, using a very light coat of silicone grease (acetone non-reactive) on the lower half of all the male ball joints.

Leak Test:

Place the meter case in a convenient position up to 300 feet

oint stopper in the inlet to the cyclone to check for possible leakage.

Turn the coarse-adjust valve on the meter box to the OFF position and open the fine-adjust valve slowly until fully opened. Partially close the fine-adjust valve until the vacuum gauge read 10 inches of mercury; then check the dry gas meter for flow. If the flow through the dry gas meter exceed 0.02 cubic foot per minute at 10 inches of mercury gauge pressure, the leak or leaks must be found and corrected.

Final Sampling Train Assembly:

Remove the cover from the ball joint on the probe, lightly grease the lower half of the ball joint with silicone grease, and connect the probe. Make sure that the rubber stopper is snug in the opening in the sample case. Secure the probe by tightening the probe holding clamp.

Make all necessary electrical and pitot-tube line connections.

Let the variable transformer on the meter case so that the desired probe temperature is obtained (use Figure 5 as a guide). Set the Thermostat on the sample box at 250°F or at the desired temperature. Turn on the heater, blower, and probe switches on the meter case.

Allow the sample case and probe to heat for at least 15 minutes before starting the test and make periodic checks and adjustments to assure the desired sample case temperature.

Fill the impinger section of the sample case with ice and a little water. Add ice periodically during testing to maintain the temperature of the gas leaving the last impinger at less than 70°F.

Sample Run:

Record all necessary initial data such as that shown on the sample data sheets in Appendix A, including the initial dry gas

meter reading. Turn off the coarse-adjust valve on the meter case, fully open the fine-adjust valve. Remove the cover from the nozzle tip and place the pitobe at the first sampling point. Record the clock time, read ΔP on the pitot tube manometer, and determine ΔH from the nomograph as shown previously.

Turn the pump on and set ΔH on the meter box first by adjusting the coarse-adjust valve and then the fine-adjust valve.

The sample run plan should consider the number of traverse points and the sampling time at each point. A good rule of thumb to follow is to collect a weight of particulate matter equal to about 20 per cent of the filter weight. The upper limit is usually set by the pressure drop across the filter and the amount of condensate the impingers can hold. Generally the length of sampling time at each traverse point is 10 minutes.

During the sample traverse the pitobe is moved from point to point without turning the pump cff except when changing ports. The ΔP should be monitored and adjustments made on the orifice meter with the aid of the nomograph when necessary. Besides the regular time interval recordings, a set of readings should be recorded when the ΔP changes by more than 20 per cent.

Shutdown:

When testing has been completed, take a final set of readings, turn off the adjusting valves and then the vacuum pump. Turn off the heater, blower, and probe heat switches and remove the probe from the sampling port and read the dry gas meter. Cover the nozzle tip as soon as it is cool en ugh in order to avoid contamination or loss of sample. Disconnect the probe from the cyclone inlet and cover both the end of the probe and the inlet to the cyclone. Disconnect the umbilical cord from the sample case and cover the last impinger outlet. The probe and sample case are then ready for cleanup and the analytical procedure.


FIGURES ONE THROUGH TEN


MODEL 2414

STAKSAMPLR WITH MODULAR SAMPLE CASE

RESEARCH APPLIANCE COMPANY

P.O. Box 265 Cambridge, Maryland 21613





3. VACUUM PUMP

2. OILER

. FINE FLOW ADJUST VALVE

16 ORIFICE TUBE


17. INCLINE MANOMETER

18 SOLENOID VALVES

21 PYROMETER


22. THERMOMETER

FIGURE W




NOTE:


- 1. PITOBE LENGTH CAN BE ANY SUITABLE SIZE.
- 2 NOZZLE DIAMETER AND CONFIGURATION CAN BE A VARIETY OF SIZES, BUT IT MUST HAVE A 54" SHANK.





NOTE: Flow rate held constant at 0.75; 50% change in flow rate has little effect on probe temperature.





FIGUER 6











PROPE THEROCUPLE PLACEMENT TO

PREVENT INTERFERENCE; D. BETWEEN

0.48 AND 0.95 CM (3/16 AND 3/8 IN.).

FIGURE 10

 Sect
 1.4

 Page
 of

 Revision:
 Zero

 Date:
 1/85

3.0 CALIBRATION

Calibration of stack sampling equipment as done at White Mesa, on a periodic basis, is as per the attached forms. During full operation, the equipment is checked on a semi-annual basis, and during partial operating periods, calibration frequency is annually. During non-operational periods, calibration of the equipment is not performed.

CALIBRATION PROCEDURES

ORIFICE AND METER

<u>Initial Check</u>: A preliminary check is made of the following for proper operation before trial test: pump, pump oil, quick connects, valves, manometers, dry test meter, thermometers, lights, electrical check amphenol, variac, vacuum gauge, leakage at 27".

COVER OFF

PLUG IN POWER: Bottom light on, solenoid click.

PUMP OIL: Minimum level.

PUMP: Provides sufficient suction when in

operation.

QUICK CONNECTS: Proper locking operation.

VALVES: Proper opening and closing.

MANOMETERS: Fluid level and zeroing.

DRY TEST METER: Thermometers (inlet, outlet) do not hang up.

THERMOMETERS: Calibrate to a known temperature.

LIGHTS: Turn fan, heater, probe on; turn fan off and heater light also goes out. Turn fan

on and heater off. Lights should indicate

position.

ELECTRICAL CHECK AMPHENOL: Continuity check.

VARIAC: Connect neon bulb electrically to amphenol

and turn variac up beyond 45 watching neon

increase in brightness.

VACUUM GAGE: Turn selector valve (course) to "on"

position, fine adj. to fully open; insert plug (plug input line); turn fine adj. until gage reads 27" and hold for 15-30 seconds, observe dry meter for movement,

check for leaks.

Introduction: You are now ready to follow calibration procedures. $\Delta H@$ and Y can be obtained simultaneously. After warmup and wetting, set wet meter at zero, start stop watch when dry meter reading is at a convenient position and record all information required on the following page. When 10 CF_W have gone through the meter stop the stop-watch and note dry meter for CF_{d} . Perform all calculations, and if readings are not within tolerance make adjustments as outlined.

TERMINOLOGY:

CFM	Cubic foot/minute .
∆H@	Orifice pressure differential in inches of water that gives 0.75 CFM of air at 70°F and 29.92 in. Hg.
Y	Dry meter differential (in. H20)
Pb	Barometric pressure (in. Hg.)
CF _W	Cubic feet (wet test meter)
CFd	Cubic feet (dry test meter)
Tw	Temperature (wet test meter)
ITd	Input temperature (dry) ^O F
OTd	Output Temperature (dry) OF
T avg.	(IT _d + OT _d)/2 °F
T	Time (minutes)
WTM	Wet test meter

Procedure: With the meter and pump enclosed and a wet test meter attached (1 cubic foot er revolution), allow the equipment to warm up and dry parts of WTM to become wetted (approximately 1/2 hour). Level the box by turning the adjusting screw in the lower right front corner. Then zero the manometer by placing the manometer switch in the up position and adjusting fluid level if necessary. After the warmup period run a trial test at an orifice manometer setting of 2 in. H_2O and CF_w of 10 to obtain $\Delta H@$ and Y. See Fig. 1 for test set-up.

Step One:

 $\Delta H@$ is calculated by using the formula:

$$\Delta H@ = \frac{0.0634 \text{ (manometer orifice)}}{P_b \text{ (OT}_d + 460)} \left[\frac{(T_w + 460)t}{CF_w} \right]$$

A different factor is used for the manometer orifice for each successive ΔH set on the orifice manometer in accordance with the following table:

Set AH	Manometer Orifice Factor
.5" H ₂ 0	.01585
1	.0317
2	.0634
4	.1268
ó	.1902
8	.2536

If the value is not within 1.6 to 2.1 (1.84 nom. desired) the orifice can be drilled in increments of 64ths to lower the value, or if the value is below 1.6, then the orifice should be replaced and the procedure repeated.

Step Two:

Y is calculated by using the formula:


$$Y = \frac{CF_w P_b (T_{d avg.} + 460)}{CF_d (P_b + 0.147) (T_w + 460)}$$

and is obtained during the trial run along with $\Delta H \Theta$.

The factor 0.147 is replaced in the formula as the ΔH is changed. The following table lists the factors to be used with the various ΔH settings.


Set ∆H	Formula Factor
.5" но	.0368
1	.0737
2	0.147
4	0.294
6	0.431
8	0.588

If the value is not within 0.99 and 1.01 (1.00 nom. desired) then adjustments must be made to the meter. If the umit is still under warranty return to the factory, adjustments in the field will void the warranty. To adjust the meter, remove the four (4) screws on the top of the meter, carefully remove the lid, and exposing the lever mechanism make sure that the adjusting nuts "A" and "B" are in position, see Fig. 2. To adjust the meter, "A" and "B" are turned clockwise to decrease the value of Y and countercle kwise to increase the value of Y. After making the adjustment replace the lid and screws and run another trial test.



WHEN REMOVING LID FOR ADJUSTMENT USE CAUTION IN REMOVING GASKET SO IT DOES NOT BREAK. WHEN ADJUSTING NUTS HAVE STRING ATTACHED TO WRENCHES.

TEST SET UP SCHEMATIC



WHEN PERFORMING VACUUM CHECK PUT PLUG (QUICK-CONNECT) ON INPUT SIDE OF PUMP

Sect	1.4	
Page 8	of 11	-
Revison:	Zero	
Date:	1/85	-

4.0 RECORD KEEPING

Record maintenance as per the formats shown in Section 2.0, are maintained in the WHITE MESA AMBIENT ENVIRONMENTAL notebook maintained in the Environmental Office. A summary log is maintained of each monitoring run results and the same for a history log of that particular stack's performance. This data is also on the computer system.

Data located on a run summary log includes:

- 1. Stack and Run ID:
- 2. Date and Sampler;
- 3. Sampled Air Volume at standard conditions:
- 4. Sampled Water Volume at standard conditions:
- 5. Moisture Content; Volume Basis;
- 6. Stack Gas Molecular Weight (wet basis);
- 7. Stack Gas Velocity;
- 8. Stack Gas Volumetric Flow Rate, dry basis at standard conditions;
- 9. Particulate Concentration;
- 10. Percent IsoKinetics; and
- 11. Emission Rates for Particulates, Uranium-Nat., Thorium-230, Radium-226 and Lead-210.

The history log maintains a record summary for each stack of the following data:

- Data Sampled;
- 2. Stack Gas Volumetric Flow Rate, dry basis at standard condition;
- Percent IsoKinetic:
- Emission Rates for Particulates, Uranium-Nat., Thorium-230, Radium-226 and Lead-210.

Data is calculated to give emission rates in pounds per hour for particulates and picoCuries per hour for radionuclides.

Sect	1.4
Page 9	of 11
Revison:	Zero
Date:	1/85

5.0 MONITORING LOCATION AND FREQUENCY

During non-operational periods, monitoring is not done.

5.1 Yellow Cake Stacks

The exhaust stack for the drying and packaging equipment associated with the yellow cake calciner is sampled on a quarterly basis during operations. The sample ports are located on the roof of the main mill building.

Samples are analyzed for: Natural Uranium, Lead-210, Raclum-226, and Thorium-230 on a semi-annual basis and for Natural Uranium on a quarterly basis.

5.2 Crusher Stacks

The crusher stacks are located at:

- 1. Ore Buying Station (3) and,
- 2. Ore Hopper Feed (1)

These stacks are accessible from stack platforms and are sampled on a semi-annual basis during operations. Samples are analyzed for: Natural Uranium, Lead-210, Radium-226, and Thorium-230.

6.0 ANALYSIS PROCEDURE

The lab analytical procedures utilized are as presented in the Representative Analytical Laboratory Procedure Manual.

Field sample handling consists of sampled air volume moisture determination, sampled gas volume, percent isoKinetic, stack air emission rate, particulate weight sampled, particulate emission rates determinations, measuring collected condensate volumes, rinsing glassware, and collection of condensate and rinse solutions for analysis.

All glassware is pre-rinsed with O.lN nitric acid, and all solutions used in impinger traps contain O.lN nitric acid.

After sampling, the glassware and stainless steel units are rinsed with 0.1 nitric acid, with the rinse added to the condensate solutions. The glassware is then rinsed with isopropyl alcohol and stored.

Samples submitted for analysis for each run are:

- 1. Glassfiber filters, net gain weight determined at White Mesa;
- Condensate and rinse solutions (volumes of each determined at White Mesa);

Sect	1.4	
Page 10	of	11
Revison:	Zero	-
Date:	1/85	

6.0 ANALYSIS PROCEDURE (continued)

- 3. Glassfiber filter blank; and
- 4. (). IN Nitric Acid blank.

Results received from the analytical laboratory are in picoCuries per filter amd/or picoCuries per milliliter of sample. With knowledge of volumes of condensate and rinse used, along with blank values, a tabulation is made to determine net isotope gain for the run in picoCuries. This value divided by the known sampled volume (dscfm) gives the emission concentration in activity per standard air volume. This value, in turn, multiplied by the known standard air volume stack emissions rate gives activity emission rates for that particular sampling period.

7.0 QUALITY ASSURANCE METHODOLOGY

7.1 Equipment Operation

Prior to performing an emission point sampling run, the sampling equipment is subjected to a dry run test to determine leakages or equipment malfunction. Calibration of equipment is checked on a periodic basis. Probe tips are protected by a protective cap while not in use to protect accuracy determinations. Muring transport of equipment, all openings are sealed to prevent comtamination. Calculations utilized during runs to maintain isoKinetic conditions are reviewed and dry run tested prior to the actual run. All containers and probes are washed prior to each usage.

Malfunction of sampling equipment, excessive malfunctions of normal operations being monitored, or percent isokinetic sampling rates greater than plus or minus ten percent error indicate mandatory voiding of the run or data involved.

7.2 Operations

Operations such as the calciner or crushers that appear, in the judgement of the sampler, to be functioning in a manner mot consistent with normal operations shall void the sampling run.

7.3 Chemical Sample Control

Analyses on each period's sample shall include blanks for both the filters, impinger solutions, and the rinse solutions. A field log book shall be maintained listing data generated, determinations of volumes measured, and net gain weights of filters to provide a backup to summary data records. Filters are transmitted within plastic enclosed petri dishes.

Sect	1.4	
Page 11	of I	1
Revison:	Zero	
Date:	1/85	MINNEY PO LAN

7.0 QUALITY ASSURANCE METHODOLOGY (continued)

Handling of filters is only done using tweezers.

7.4 Calculations

All calculations are done using a Texas Instruments 59 calculator and programs written for that purpose. The calculations are rechecked by another member of the staff to minimize data numerical transposition.

Sect	1.5
Page 1	of 2
Revison:	Zero
Date:	1/85

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINES ENVIRONMENTAL

ANALYTICAL BALANCES

1.0 EQUIPMENT

Equipment used is:

- 1. Sartorius Model 2432 Electronic Balance 200 gram capacity 0.1 milligram sensitivity Serial Number 2903004
- OHAUS Triple Beam Balance 2610 gram capacity 0.1 gram sensitivity
- Standard Calibration Weights

The electronic anal tical balance is mounted on a heavy shock-proof table and balance level is checked prior to each use and adjusted when necessary. The interior of the balance housing is maintained in a clean condition.

2.0 PROCEDURES FOR USE

The procedures for using the analytical electronic balance are:

- 1. Check for levelness, re-level if necessary.
- Clean pan using camel-hair brush and shut doors.
- Check zero: Set all controls to zero. Turn release lever down. If scale does not stop on zero, adjust with zero control knob (right side behind micrometer control knob).
- 4. Weighing an unknown:
 Place object on pan with release lever in OFF position. Ensure object does not touch sidewalls. Shut doors. Turn release lever to "1/2" position. Dial in weights, starting with largest series. When too much weight is added, the scale moves below zero; go back one step (if 30 is too much, go to 20). Then use next lower series (1-9 grams).
- 5. Reading the result:
 When all weights are used, turn release lever to "l" or down

Sect	1.5	
Page 2	of 2	name or a
Revison:	Zero	-
Date:	1/85	

2.0 PROCEDURES FOR USE (continued)

position. When scale stops, use micrometer knob to superimpose scale pointer on next lower division. Read total weight from left to right observing decimal point.

- 6. Make all adjustments smoothly: Stop momentarily in "arrested" position before "full release." If pan swings too much, arrest once more.
- 7. Never dial weights in full-release position.
- 8. Clean chamber after use, using camel-hair brush and shut doors.
- 9. When not in use, the release lever should be in OFF position. The procedures for using the triple beam balance are:
 - 1. Place balance on level surface.
 - 2. Clean scale surface.
 - Check zero balance, adjust using zero adjust knob under scale-head.
 - 4. Place unknown on scale-head.
 - Adjust weights on triple arm until needle balances at zero.
 - Summate weight readings on all three scales to achieve total weight value.
 - Return weights to zero position.
 - 8. Store balance where it won't be damaged.

3.0 QUALITY CONTROL METHODOLOGY

The analytical balance is verified to be level and zeroed prior to each use. The balance is located on a heavy shockproof table anchored into a concrete foundation. Balance temperature is equilibrated to room temperature. Special precautions are taken to avoid spillage of corrosive chemicals on the pan or inside the balance case. The balance is checked monthly against standard weights. A periodic calibration is performed with Sartorious.

The triple beam balance is leveled and zeroed before each usage and is stored in a safe location.

2.0 WATER MONITORING

 Sect
 2.1

 Page
 1
 of
 4

 Revison:
 Zero

 Date:
 1/85

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINES

ENVIRONMENTAL

SURFACE WATER HYDROLOGY

1.0 EQUIPMENT

Equipment used for monitoring surface hydrology is:

- Beckman Model 20 pH meter and probe;
- 2. YSI Model 33 temperature and conductivity meter and probe;
- Linear polyethylene containers;
- 4. Sample Bucket;
- 5. 142mm diameter filter holder;
- 0.45 micron membrane filters;
- 7. 0.8 micron glassfiber filters; and
- 8. Masterflex Peristalic Portable Pump.

2.0 MONITORING METHODOLOGY

2.1 Flow Measurement

No flow measurements are taken of the two drainage creeks: Westwater Canyon and Cottonwood Creek.

2.2 Water Quality

Westwater Canyon and Cottonwood Creek are monitored at two locations adjacent to the White Mesa Mill facility. Samples are obtained quarterly using grab sampling. A five gallon sample is obtained, following rinsing of the sample bucket several times in the monitored stream. A liter unfiltered aliquot is obtained for total suspended solids analysis. Specific conductivity, temperature and pH data is bucket contents are then well mixed as an aliquot is field pumped, by point five micron membrane filter, into new polyethylene containers for a soluble, or dissolved sample.

Sect	2.1
Page 2	of 4
Revison:	Zero
Date:	1/85

2.0 MONITORING METHODOLOGY (continued)

The filter(s) are retained in a sealed, labeled peto dish container for suspended radionuclide determinations.

The peristaltic pump tubing and filtration unit are rinsed with distilled water prior to being utilized at each site. The equipment is pre-rinsed with a known volume of the sampled stream prior to collection of the dissolved sample portion.

In the event that the sampled streams contain excessive turbidity for proper filtration with the 0.45 micron filters, the samples are pre-filtered using the 0.8 micron filters prior to re-filtering using the 0.45 micron filters; in either case, the filters are retained/composited for suspended radionuclide analysis.

Soluble aliquots are preserved using nitric acid to adjust the sample solution to a pH less than two and storage at four degrees Celsius.

Samples are submitted to the analytical laboratory on a quarterly basis for:

- 1. Total Suspended Solids:
- Soluble: U-Natural, Thorium-230, Radium-226, Lead-210, Polonium-210; and,
- Suspended: U-Natural, Thorium-230, Radium-226, Lead-210, Polonium-210.

Field data is obtained for:

- 1. Temperature, oc
- Specific Conductivity, µmhos at 25°C;
- 3. pH, at 25°C;
- 4. Sample date;
- 5. Sampler ID; and,
- 6. Filtrate Volume.

Sect	2.1	
Page 3	of 4	-
Revison:	Zero	-
Date:	1/85	_

2.0 MONITORING METHODOLOGY (continued)

Sample containers are labeled with:

- 1. Site ID:
- 2. Date;
- 3. Field Data;
- 4. Filtration Specs; and
- 5. Preservation Method.

3.0 RECORD KEEPING

3.1 Water Quality

Radiological and chemical quality data is maintained in the Hydrology-Stream notebook within the Environmental Office. Data is maintained in summary form listing:

- 1. Sample location,
- 2. Sample date,
- 3. Field pH,
- 4. Field temperature,
- 5. Field conductivity,
- 6. Total Suspended Solids concentration,
- 7. Soluble Radionuclide Concentrations*, and,
- 8. Suspended Radionuclide Concentrations*.

*U-Nat., Thorium-230, Radium-226, Lead-210, Polonium-210.

4.0 MONITORING LOCATION AND FREQUENCY

The monitoring locations are shown on the monitoring topographic map. They are listed as:

- 1. Lower Cottonwood Creek, and
- 2. Lower Westwater Creek.

Samples are obtained once per quarter; except when the creeks are dry.

Sect		2.1	
Page	4	of	4
Revison:		Zero	
Date:		1/85	

5.0 ANALYSIS PROCEDURE

5.1 Water Quality

The laboratory analytical procedures utlized are presented in the procedures manuals of the appropriate laboratory.

Field procedures are discussed in subsection 2.0 of Section 2.1 and in Section 2.4.

Data is reviewed and graphed on a quarterly basis to observe abnormalities.

6.0 QUALITY ASSURANCE METHODOLOGY

6.1 Water Quality

Monitoring of pH, temperature, and conductivity procedures is done each quarter. Review of procedures involved with sample preservation is checked each quarter. Sample composition bottles are not re-used and sample contents are maintained in a locked cooler. All filtration equipment is rinsed with distilled water prior to each site use and rinsed with a known stream volume prior to obtaining a dissolved content aliquot for analysis.

On a semi-annual basis, one site sample is split in the field and submitted as a blind duplicate for analytical and sample collection quality assurance. Deviations greater than ten percent result in review of procedures.

Sect	2.2
Page 1	of 6
Revison:	Zero
Date:	1/85

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINES

ENVIRONMENTAL

GROUNDWATER HYDROLOGY

1.0 EQUIPMENT

Monitor wells to be utilized for the groundwater monitoring system consist of narrow diameter PVC cased wells with locking surface caps.

Sampling equipment consists of:

- 1. 1.8 inch O.D. Air Driven Bennett Model 180-500 Sampling Pump;
- 2. 260 psi air compressor and ancillary equipment;
- Beckman Model 20 pH meter and probe;
- 4. YSI Model 33 temperature and conductivity meter and probe;
- Hand air vacuum pumps;
- 6. Peristaltic pumps; and
- 7. Field filtration and preservation equipment.

Measurement of phreatic elevations is by use of water level indicators:

- 1. Built into Bennett Model 180-500 pumping system;
- Slope Indicator Co. Model 5143-200' Water Level Indicator; and,
- 3. SOILTEST, INC.
 Model DR-760A
 800 ft. capability

Sect	2.2	
Page 2	of	6
Revison:	Zero	
Date:	1/85	

2.0 MONITORING METHODOLOGY

2.1 Phreatic Elevation

Phreatic elevations are monitored on a quarterly basis with a water level indicator meter. Field log books are maintained listing depth to water from top of casings. Readings are taken by lowering the sensor into the rasing until the electrical sensor contact shows that a conductive liquid has been reached. Distance from the point where the electrical wire touches the top of the casing, at point of contact, to a known five-foot interval marker on the wire is determined using a tape measure. This distance plus the five-foot interval marking is total depth to water from top of casing. Data is recorded as phreatic elevation above sea level in the respective section in the Hydrology Data Notebook maintained in the Environmental Office or maintained on computer files.

There are no action levels associated with monitor wells. The water supply well is not equipped for phreatic measurements.

2.2 Groundwater quality is monitored on a quarterly basis by pumping a minimum of two casing volumes or until three successive samples show stabilized readings on pH, temperature, and conductivity.

When the well water has reached equilibrium, the flow is passed through a filtration unit utilizing a point-four-five micron membrane filter. The water is filtered through the unit into polyethylene jugs as the sample.

Field Sample Treatment Procedure is:

- 1. Rinse all field probes with distilled water.
- 2. Rinse new filter with distilled water.
- 3. Rinse sample containers with distilled water.
- Rinse graduated cylinders.
- Place new membrane and/or prefilter on glass or plastic frit at base of filtration unit.
- Pump sample through filtration unit and into sample container after letting the first 100 mL be wasted as a filter rinse.

 Sect
 2.2

 Page
 3 of
 6

 Revison:
 Zero

 Date:
 1/85

2.0 MONITORING METHODOLOGY (continued)

- Rinse lid of sample container with filtered stream and tighten onto sample container.
- 8. Identify and label sample container; include:
 - A. Site well ID;
 - B. Date;
 - C. Temperature of original sample;
 - D. pH of original sample;
 - E. Conductivity of original sample;
 - F. Preservation Method
- 9. Preserve the sample in the field using the appropriate chemical or physical preservation method.
- 10. If the sample is from the drinking water supply well, preserve the filter by placing it in a plastic petri container and seal the container. Label the container with the site I.D., Date, and volume filtered.

Upon return to the office, the samples are stored in a locked cooler at 4° C until transferred to the Analytical Laboratory.

Field data is transcribed onto computer data worksheets and are held in this form until the analytical laboratory data becomes available. When such data is available, the data is then entered onto the work sheets and typed into the computer record. The worksheets and analytical sheets are filed as reference material.

The following is the analytical data to be requested on the well samples.

Sect	2.2	
Page 4	of	6
Revison:	Zero	
Date:	1/85	

CHEMICAL PARAMETER MONITORING SCHEDULE OPERATIONAL PHASE GROUNDWATER PROGRAM

Quarterly Sampling

Annual Sampling**

Indicator Parameters:

pH (F,L)
Specific Conductance (F,L)
Temperature (F)
Sulfate (L)
Chloride (L)
U-Natural (L)
Thorium-230 (L)
Radium-226 (L)
Pb-210 (L)
Po-210 (L)

Accuracy Assessment Parameters*

Calcium (L)
Magnesium (L)
Potassium (L)
Bicarbonate/Carbonate (F,L)
Sodium (L)
Total Dissolved Solids (L)

pH (F,L) Specific Conductance (F,L) Temperature (F) Total Dissolved Solids (L) Alka, inity (F,L) Bicarbonate/Carbonate (L) Sulfate (L) Chloride (L) Ammonia (L) Phosphate (L) Aluminum (L) Arsenic (L) Cadmium (L) Calcium (L) Chromium (L) Copper (L) Lead (L) Magnesium (L) Manganese (L) Mercury (L) Molybdenum (L) Potassium (L) Selenium (L) Sodium (L) Vanadium (L) Zinc (L) Gross Alpha (L) Gross Beta (L) Uranium-Nat. (L) Radium-226 (L) Thorium-230 (L) Lead-210 (L) Polonium-210 (L)

Note:

F = Parameter measured in field

L = Parameter measured in laboratory

All radionuclides and metals are analyzed for dissolved concentrations only.

* First and Third Quarters

** First Quarter

Heavy metal and radionuclide samples are preserved by filtration, adjustment of pH to less than two with nitric acid, and storage at 40° C. Ammonia samples are preserved by filtration, adjustment of pH to less than two with sulfuric acid, and storage at 40° C. Other samples are preserved at 40° C.

Sect	2.2	
Page 5	of	6
Revison:	Zero	
Date:	1/85	

2.0 MONITORING METHODOLOGY (continued)

Samples are cataloged at White Mesa and sent to the Analytical Laboratory with the appropriate Certificate of Analysis sheets attached. Samples are transmitted by locked and sealed containers by postal contract services. Copies of Certificate of Analysis sheets are returned to White Mesa showing date of receipt by the Laboratory.

Bottles utilized are of linear polyethylene and consist per sample site of:

- 1. Two gallons Radionuclides;
- 2. Two liters metals;
- 3. One liter -- ammonia; and,
- One liter -- T.D.S., CL, SO₄, Ca, CO₃, HCO₃, K, Alkalinity, and Na.

3.0 CALIBRATION

3.1 Phreatic Measurements

Equipment used in phreatic measurements are checked for calibration quarterly.

3.2 Water Quality

Probe and meter equipment including temperature, pH, and conductivity are calibrated at each use. Calibration logs are not maintained.

4.0 RECORD KEEPING

Summarized data is logged onto computer file work sheets. Once all data for a well or quarter is completed, the data from the worksheet is typed into a computer file. Certificates of Analysis and computer work sheets are then maintained as a backup file with the main working file being on the computer system.

Data includes well, I.D., sample date, well phreatic elevations, field analytical data, and all assay data.

Sect_	2.2	
Page 6	of	6
Revison:	Zero	
Date:	1/85	- Management

5.0 MONITORING LOCATION AND FREQUENCY

Monitor wells are monitored quarterly for phreatic elevation, radionuclide and chemical quality. The active monitor wells are identified as: 1, 2, 3, 4, 5, 11, 12, 13, and the culinary water well. Refer to the environmental monitoring topographic map for the well locations.

6.0 ANALYSIS PROCEDURE

The laboratory analytical procedures utilized are as presented in the Analytical Procedure Manual.

Field data analytical procedures are as per Section 2.4 of this manual.

7.0 QUALITY ASSURANCE METHODOLOGY

7.1 Well Contamination

Well contamination, from external surface factors, is controlled by installation of a cap over the surface casing and cementing off the surface section of the drill hole. Wells have surface casing of mild access to the key series locking the wells.

Subsurface well stagnation, for pumped wells, is reduced by pumping the wells until temperature, pH, and conductivity levels of water drawn into the well and sampled.

7.2 Phreatic Elevations

Monitoring of phreatic elevations is controlled by usage of a field log book so that the technician can refer to previous field data in book serves as a check for numerical transposition of calculated

7.3 Water Quality

Quality assurance of water quality in field sample analysis, handling, and preservation is maintained by following procedures as Minerals standards. Observation of technician performance is Blind duplicates of at least one well per quarter are submitted to assurance performance. Deviations exceeding ten percent result in analytical and field procedure review.

Sect	2.3	
Page 1	of	3
Revison:	Zaro	-
Date:	1/85	

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINES

ENVIRONMENTAL MONITORING

CULINARY SUPPLY

1.0 EQUIPMENT

Equipment for monitoring of domestic water quality and usage consists of flow totalizer meter, an Beckman Model 20 pH meter, chlorine comparator, and fecal coliform bottles supplied by the State of Utah.

Zero point four five micron Gelman membrane filters are used for filtration.

2.0 MONITORING METHODOLOGY

2.1 Quantity

Quantity of domestic water usage is maintained by the Environmental Staff. Currently, there is an in-line flow rate meter located at the domestic water supply wellhead. The flowrate meter consists of a digital readout with two rotating needles reading the last two numerical digits. The larger dial reads tens of gallons, the smaller dial reads units of gallons. The last digit on the digital readout is hundreds of gallons.

Readings are taken the last day of each week and recorded in the Domestic Water record notebook. Values are used by the State Engineer's Office as part of an annual survey.

2.2 Quality

Domestic raw water is grab sampled daily by the environmental crew who transmit the sample to the Environmental Department.

Bacteriological quality is checked by submittal of proper sampled fecal coliform sample to the Utah Department of Health Branch Laboratory on a monthly basis or as required.

Chlorine content is checked during weekdays using chlorine comparator. The pH is monitored weekly.

Compliance with Utah's Drinking Water Regulations is monitored as per E.P.A. guidelines and for elements determined for ground water sources.

Sect	2.3
Page 2	of 3
Revison:	Zero
Date:	1/85

3.0 CALIBRATION

Calibration of equipment consists solely of calibrating the Beckman Model 20 probe. This is accomplished by checking probe readout versus buffered solutions of pH one, seven, and ten. The equipment is adjusted to reflect the calibration solution pH as described in the Beckman pH equipment manual and in section 2.4 of this manual.

4.0 RECORD KEEPING

Records are maintained in a Domestic Water Data Notebook covering data summary and is maintained in the Environmental Office at White Mesa.

Recorded data, in summary form, includes:

- 1. Sample Period;
- 2. Sample Type;
- Weekly Consumption;
- 4. Fecal Coliform, Count; and
- 5. pH Range.

5.0 MONITORING LOCATION AND FREQUENCY

Samples for water chemical quality are taken daily. Fecal coliform sampling occurs once per month, as per Utah Public Drinking Water Regulations. Sample taps for the mill are rotated monthly. The daily grab sample is checked each Thursday for pH level.

Water quantity readings are obtained weekly at the wellhead by the Environmental staff.

Analysis of pH values is by direct readout from a Beckman Model 20 pH meter.

The analytical procedures utilized are as presented in Section 2.4. Results are reported in final concentration format to White Mesa.

7.0 QUALITY ASSURANCE METHODOLOGY

7.1 Bacteriological Monitoring

Bacteriological monitoring consists solely of fecal coliform checks through usage of Utah Department of Health Laboratories and sample containers. Sampling is done strictly by standard methods.

Sect		2.3	
Page	3	of	3
Reviso	n:	Zero)
Date:		1/85)

7.0 QUALITY ASSUPANCE METHODOLOGY (continued)

Avoidance of sample jar overtopping, proper flushing of a non-aerated sample tap, labeling of bottles, identification documentation, and transportation processing are actions taken as quality control.

7.2 Quantity Monitoring

Observation of flow rate meter operation is routinely done weekly to ensure proper meter operation. Maintenance or replacement of meters is accomplished with Environmental Staff appraisal.

7 ° Chemical Quality Monitoring

analysis immediately follows sample collection. Residual chlorine oncentrations are determined using chlorine comparator.

Sect	2.4	
Page 1	of	2
Revison:	Zero	
Date:	1/85	

WHITE MESA PROCEDURES MANUAL MONITORING GUIDELINES ENVIRONMENTAL

TEMPERATURE AND CONDUCTIVITY MEASUREMENTS

1.0 EQUIPMENT

Equipment used is:

Yellow Springs Model 33
 S-C-T Meter with ten foot probe system

This model is a portable unit which is operated both by line power and by battery mode. The probe is protected by a plastic enclosure for field usage.

2.0 PROCEDURES FOR USE

The procedures for using the temperature and conductivity meter are:

- 1. Ensure probe is connected to meter.
- Switch mode control to off. Use meter screw to adjust meter needle to 0, if necessary.
- Switch mode to red line. Use red line control to adjust meter needle to red line.
- TEMPERATURE: Switch mode to temperature; read meter when needle is steady.
- CONDUCTIVITY: Read temperature; set ^{OC} control to indicated temperature. Switch mode to appropriate conductivity scale for on-scale meter readings. Read meter and multiply reading by scale.
- Replace batteries when Step 3 cannot be accomplished. Use Eveready E95 (or equivalent) alkaline battery.
- 7. Clean probe tip in distilled water prior to use.
- 8. Allow needle to stabilize prior to reading values.
- When reading conductivity when temperature adjusted as per above, ronductivity reading is mhos/cm at 25°C.

Sect	2.4
Page 2	of 2
Revison:	Zero
Date:	1/85

3.0 QUALITY CONTROL METHODOLOGY

The temperature sensor is periodically checked versus a NBS traceable thermometer. The conductivity meter cell constant is checked monthly versus meter reading values using standard potassium chloride reference solutions.

The solutions are:

Solution	Normality	Method of Preparation	Temp.(°C)	Conductivity	(µmhos)
А	0.1	7.4365 g KCL/1 at 20 °C	0 18 25	7,138 11,167 12,856	
В	0.01	0.7440 g KCL/1 at 20 °C	0 18 25	773 1,220 1,408	
С	0.001	Dilute 100 mL of to 1 liter at 200		147	

Calculate the cell constant as follows:

$$L = \frac{K_1 + K_2}{1,000,000 + K_X}$$

Where:

L = Cell constant

K1 = Conductiviity, in mhos/cm, of KCL solution at the temperature of measurement

K2 = Conductivity, in mhos, at the same temperature, of the distilled water used to prepare the reference solution.

Kx = Measured conductance, in mhos.

Temperature readings should not vary from thermometer values. Conductivity readings should be within two percent. Standard solutions can be cross-checked with the White Mesa Analytical Laboratory. Meter conductivity minimum value determinable is ten mhos/cm.

Distilled water conductivity should be less than 10 micromhos/cm.

Sect	2.4-2					
Page 1	of	2				
Revison:	Zero					
Date:	1/85					

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINES ENVIRONMENTAL

TH METERS

1.0 EQUIPMENT

Equipment used in the White Mesa Environmental Lab and in the field to monitor pH is:

- 1. Beckman Model 20 pH meter;
- 2. Beckman Gel Filled Combination Electrode; Futura II;
- 3. Beckman pH 1.0 buffer solution, chloride buffer;
- 4. Beckman pH 7.0 buffer solution, phosphate buffer;
- 5. B.A.R. pH 10.0 buffer solution, borate buffer:
- 6. pH combination electrode filling solution: 2M KCL, Sat. AgCL;
- 7. Magnetic stir rods and stirrer lab usage;
- 8. 250 mL glass beakers lab usage;
- 9. 250 mL plastic beakers field usage; and,
- 10. Deionized distilled water.

2.0 pH ANALYSIS

Procedures for pH analysis are as follows:

- 1. Field Perform battery check on Model 20 meter;
- Inspect pH probe for cracks.
- Put probe in buffer solution of 7 pH. Buffer solution is placed from supply bottle into beaker. Allow meter to standardize to pH of 7.

Sect_		2.4-2					
Page	2	of	2				
Revison	:	Zero)				
Date:	***************************************	1/85					

2.0 pH ANALYSIS (continued)

od A

Field -- Buffer solution can be swirled using hand motion.
Response may take time. Cold temperature of air
will affect meter electronics. Keep meter warm.
If slope correction falls below 95 percent,
relocate meter to a warmer environment.

8 %

4. Rinse probe with distilled water and dry with a clean tissue.

e wi

 Put probe in another solution containing either buffer solution of one or ten--depending upon estimated sample pH value. Response time varies.

in a mon-

6. Allow meter to standardize to buffer solution.

mer to

7. Rinse probe with distilled water and dry.

noe w.

8. Put probe in sample stream, let meter stabilize, and read pH level, nearest 0.1 pH. Meter compensates for temperature of solution.

in s

- 9. Remove probe, rinse with distilled water and dry between samples.
- 10. Do not put used buffer solution back into supply bottle; discard.

3.0 QUALITY ASSURANCE

The following of the above analysis procedure and usage of standard equipment will give accurate and repeatable results in pH analysis.

Technician performance is periodically reviewed by supervisor.

3.0 TAILING MONITORING

 Sect
 3.1

 Page
 1
 of 10

 Revison:
 Zero

 Date:
 1/85

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINES

ENVIRONMENTAL

TAILING STABILITY INSPECTION PROGRAM

1.0 SUMMARY

The on-site inspection program is a systematic procedure for inspecting and recording observations of the performance of all aspects of the tailings disposal system, including geotechnical, structural, hydraulic, and electrical-mechanical features of the operations. Items of inspection and procedures are divided into groups according to inspection frequency as follows:

- 1. Daily
- 2. Weekly
- 3. Monthly
- 4. Quarterly
- 5. Yearly

Changes in inspection frequency will be made as needed, based on observations made during these scheduled inspections. Inspections will also be made after the occurrence of any unusual or severe natural or man-caused events. Each of the inspection item groups is described below.

2.0 DAILY INSPECTION

On a daily basis, all areas connected with active tailings disposal will be patrolled and observations of the current condition and behavior of the disposal system will be made and recorded. This involves visual inspection of the following:

- Tailings slurry transport system (from the mill to Cell 2 or Cell 3)
- 2. Tailings Cell 2
- 3. Tailings Cell 3
- 4. Evaporation Cell 1-I
- 5. Dike structures including Dike 1-I, 1A-I, 2, and 3
- 6. Cell 2 sump and drain structure and associated drain system
- 7. Cell 3 sump and drain structure and associated drain system.

Sect		3.1	
Page	2	of	10
Reviso	n:	Zero	-
Date:	-	1/85	

2.0 DAILY INSPECTION (continued)

The inspection checklist presented in Table 1A will be used as a guide to what conditions are of potential concern, and also to provide a place to record observations of potential concern. For all inspection items, the inspector is required to record whether that item appears to be performing properly (0.K. column of checklist is checked) or that conditions of potential concern have been observed with that item (observations are recorded and the action required column of checklist is checked). If conditions of potential concern are observed, then some further action is required by the inspector. The specific action required is indicated in Table 1B. Table 1B indicates that one of three levels of action may be required based on three types of observations:

Key No.	Observation Type	Required Action					
1	Emergency Indicator	Notify plant superintendent, environmental coordinator, and engineer					
2	Warning Indicator	Record all data, notify environmental coordinator immediately					
3	Clues to Distress	Record all data, notify environmental coordinator at earliest convenience.					

In addition to the completion of the daily inspection checklist and concurrently with the daily inspection, certain items of operating data will be recorded by inspection personnel. These items will be recorded on a daily or weekly basis as noted below, unless large changes are noted during the daily visual inspection. These items are listed in the data form presented in Table 2, and include:

- Pond elevations in Cell 1-I, Cell 2, and Cell 3 (record weekly)
- Location of slurry discharge within the active cell (record daily)
- Flow and line pressure for the active tailings slurry line (record daily)
- 4. Flow in the active cell sump and drain line (record weekly)
- Liquid level in underdrain risers (record weekly).

These data provide a record of performance against which future observations can be evaluated. Record photographs should be made periodically of all operating facilities for reference when questions about observations and previous conditions arise.

Sect		3.1
Page	3	of 10
Reviso	n:	Zero
Date:		1/85

3.0 MONTHLY INSPECTION

Inspection of additional items in the tailings disposal system will be made on a monthly basis. These include:

- Quantitative evaluation of the active cell tailings slurry pipeline condition.
- Inspection of diversion and retention structures for surface water runoff.

Results of the inspection will be recorded in Table 3.

Slurry Pipeline

The slurry pipeline will be inspected at certain key locations to determine pipe wear. An ultrasonic device will be used to measure pipe thicknesses and determine the need for replacement pipe and pipe fittings. The critical locations which must be checked include bends, slope changes, valves, and junctions which are critical with respect to the stability of the dike. The exact locations to be checked will be established by the environmental coordinator, depending on the location and configuration of the slurry pipeline at the time of inspection.

Surface Water Control Structures

Diversion Ditches 1 and 2 will be inspected along their entire lengths for alteration of the channel cross-section and characteristics, and for removal of debris. The Mill and Facilities Area Sedimentation Pond will be inspected for volume of storage and general condition. The condition of these structures will be recorded in Table 3.

4.0 QUARTERLY INSPECTION

Items requiring quarterly inspection and/or measurement include:

- Inspection of Cells 1-I, 2, and 3 emergency spillways.
- Review of maintenance and operational procedures.
- Inspection for Post-Construction Changes outside of immediate disposal area.

All items inspected on a monthly basis will be included in the quarterly inspection. The results of the quarterly inspection will be recorded in Table 4.

The emergency spillways for Cell 1-I, 2, and 3 will be examined to detect any changes in the structures. The Safety Dike will be inspected in the

Sect	3.1
Page 4	of 10
Revison:	Zero
Date:	1/85

4.0 QUARTERLY INSPECTION (continued)

same manner during the quarterly inspection as the active cell dikes are inspected on a daily basis, using the checklist of Table 1A.

Maintenance and operational procedures will be reviewed for any needed changes, based on observations over the last quarter. General inspection of areas outside the immediate disposal area will be made to determine any changes in site conditions not due to tailings disposal operations.

A summary of observations and recommended actions (if any) for each of the above quarterly inspection items will be prepared for the records by inspection personnel.

5.0 YEARLY INSPECTION

Yearly inspection involves survey measurement of Dikes 1-I, 1A-I, 2, and 3 configuration.

The dike crest and slope alignment and elevations will be surveyed to detect movements which are not observable by visual inspection. Survey measurements will be made at selected sections of Dikes 1-I, 1A-I, 2, and 3. At each section, measurements will be made at the crest, slope midpoint, and toe of the downstream side of the dike (where possible). The location and number of sections to be surveyed will be designated by the environmental coordinator.

Results of the survey work will be submitted to the environmental coordinator for review and placed in the inspection record files.

6.0 TECHNICAL EVALUATION AND INSPECTION REPORT

A technical evaluation of inspection observations will be performed on an annual basis, or at times when it is needed due to significant observations of concern. The detailed scope of the evaluation is difficult to define and will depend on the nature of the observations since the last evaluation. The evaluation will address any changes in the system or items of concern observed during system performance. A report will be prepared which lists these changes and/or significant observations and states the effect on these items on continued operations. The report will also contain a summary of the inspection observations for the time period since the last report. The summary will simply consist of a collection of the data sheets used in the weekly, monthly, and quarterly inspections.

7.0 Freeboard Limits

The freeboard limits are 3.5 feet below crest on Pond One and 5.0 feet below crests on Ponds 2 and 3.

TABLE 1.A

UMETCO MINERALS CORPORATION WHITE MESA

DAILY INSPECTION DATA

Date:	
Inspector	-

	Inspection Items	Condition of Potential Concern	0.K.	Observations of Potential Concern	Action Required
DIKE 5	- Slopes	Sloughs or Sliding, Cracks, Bulge Subsidence, Severe Erosion, Moist Areas, Areas of Seepage Outbreak	es,		
	- Crest	Cracks, Subsidence, Severe Erosio	n		
DIKE 3	- Slopes	Sloughs or Sliding, Cracks, Bulge Subsidence, Severe Erosion, Moist Areas, Areas of Seepage Outbreak	5,		
	- Crest	Cracks, Subsidence, Severe Erosio	n		
CELL 2 DRAIN SYSTEM	- Drain Access	s and Sump Blockage, Damage			
	- Pipeline to	Cell Leaks, Blocks, Damage			

Note: If conditions of potential concern are observed, action is required. See Table entitled "Daily Inspection Checklist."

TABLE 1.A

UMETCO MINERALS CORPORATION WHITE MESA

DAILY INSPECTION DATA (continued)

					Date: Inspector:	
	Inspection Items		Condition of Potential Concern	Observations of Potential Concern	Action Required	
EVAPORATION CELL 1-I	-	Water Level	Greater than Operating Level, Large Change Since Previous Inspection			
	-	Liner and Cover	Erosion of Cover, Exposure of Liner			
DIKE 1-I	-	Slopes	Sloughs or Sliding, Cracks, Bulges, Subsidence, Severe Erosion, Moist Areas, Areas of Seepage Outbreak			
		Crest	Cracks, Subsidence, Severe Erosion			
DIKE JA-I	-	Slopes	Sloughs or Sliding, Cracks, Bulges, Subsidence, Severe Erosion, Moist Areas, Areas of Seepage Outbreak			
	-	Crest	Cracks, Subsidence, Severe Erosion			
Active Cell	Slurry	Pipeline	Flow Rategpm			
Active Cell	Slurry	Pipeline	Pressures: Point 1 psig Point 2 psig Point 3 psig			
Active Cell	Slurry	Pipeline	Discharge Point			

TABLE 1.B UMETCO MINERALS CORPORATION WHITE MESA DAILY INSPECTION CHECKLIST

	OBSERVATION OF POTENTIAL CONCERN									Changes							Sliding		
	INSPECTION ITEM	Pipeline Break		Damage	Sharp Bends	Cn	Loose Connections	Loss of Support	Improver Location	, Large	cks	Severe Erosion	Subsidence	Erosion of Cover	Exposed Liner	Bulging	loughs or		Seepage Breakout
Cell 2 Tailings Slurry Transport System	Pipeline at Dike Pipeline at Other Locations Pipeline Joints Pipeline Supports Valves Point of Discharge	1 2	2 2 2 - 2 -	3 3 3 3 3	2 3 3	1 1 - 1 1	3 3	2	3 - 3 - 2										
Tailings Cell 2	Pond Level Beach Cell Edge Liner and Cover									2	3 2 2	3 3 3	3 2 2	3	- 3				
Dikes 1-I, 1A-I, 2, 3	Upstream Slope Downstream Slope Crest										1 1 1	3 3	2 2 2			2 2 2	1 1 1	2	2
Cell 2 Drain System	Sump Pipeline	2	2		2														
Key No.	Type of Observation																		
1	Emergency Indicator	No	tif ord	y Pi	lan	t S	upe	rin iat	ten ely	den	t a	nd	env	iro	nme	nta	1		
2	Warning Indicator	Red	core	d a	ll e	dat	1, 1	not	ify	en	vir	onm	ent	al	coo	rdi	nati	or	
3	Distress Indicator	Re	cor	d a	11 0	data	a,	not	ify	en	vir	onm	ent	al o	001	rdir	nato	or a	it

TABLE 2.0

UMETCO MINERALS CORPORATION WHITE MESA TAILING SYSTEM

WEEKLY INSPECTION REPORT

	Week of				
Pond Elevations Cell 1					
(0.1 feet elev.) Cell 2					
Ce11 3					
Mean Slurry Flow (spm'					
Mean Return Sump Flo 4pm)					
Mean Drain Flow (gpm)					
Underdrain phreatic Levels (Ft.) Cell 1 Cell 2					
Ce11 3					
REMARKS					

TABLE 3.0

UMETCO MINERALS CORPORATION WHITE MESA

MONTHLY INSPECTION DATA

	Inspector:
	SLURRY PIPELINE
	Equipment Used:
	Equipment Operator:
	Location Inspected:
	General Pipeline Condition:
	Results (thickness, etc.):
	Action Required:
	Location inspected.
	deneral riperine condition:
	Results (thickness, etc.):
	Action Required:
	more than two pipeline areas are inspected, use additional forms).
	SURFACE WATER CONTROL STRUCTURES:
	Diversion Ditch 1 Condition:
-	Diversion Ditch 2 Condition:
-	Diversion Ditch 3 Condition:
-	Mill and Facilities Area Sedimentation Pond Conditions:
N	and racificies area sequimentation pond conditions.
N	
***	Remarks:

TABLE 4.0

UMETCO MINERALS CORPORATION

WHITE MESA

QUARTERLY INSPECTION DATA

		Inspector:	
1.	Emergency Spillways:		
	Cell 1-I Condition:		
	Cell 2 Condition:		-
	Cell 3 Condition:		
	Action Required:		
2.	General Area Inspection:		
	Condition/Observations:		
	Action Required:		-
REMA	ARKS:		

Sect	3.2
Page 1	of 1
Revison:	Zero
Date:	1/85

WHITE MESA PROCEDURES MANUAL

Monitoring Guideline Environmental

LINER INTEGRITY

The onsite tailing monitoring program for liner integrity consists of monitoring underdrain pipeline collection seepage and visual observation of liner protection from solar deterioration.

During operating periods, the sump and drain structure is monitored daily by assigned inspection personnel. On a weekly basis, underdrains are observed to pumped or bailed, to determine volume, and an analysis of the liquid contents is completed. The samples are analyzed for:

- U-Natural, total;
- 2. Vanadium. total;
- Molybdenum, total;
- Sulfates, total;
- 5. Chlorides, total; and,
- 6. pH.

Surface access points to the underdrains will remain capped between checks to minimize precipitation entrapment.

Analytical data is reviewed to determine if seepage is due to direct migration of tailing liquor.

The inspection personnel consists of the Environmental Coordinator, Radiation Safety Officer, or their designees. Tailing stability monitoring and analysis the responsibility of the Environmental Coordinator. Adherence to the referenced document: "Tailing Management System; Monitoring Plan", February 1982, D'Appolonia, Energy Fuels Nuclear, Inc. will be maintained.

4.0 MISCELLANEOUS

 Sect
 4.1-4.3

 Page
 1
 of
 5

 Revison:
 Zero

 Date:
 1/85

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINES

ENVIRONMENTAL

EXTERNAL GAMMA.

SURFACE SOIL, AND VEGETATION

1.0 EQUIPMENT

Monitoring equipment for surface soils and vegetation consists of a shovel, tape measure, trowels, and collection bags.

Monitoring of external gamma levels is by use of Eberline spherical container TLD chips, one set of five chips per container.

2.0 MONITORING METHODOLOGY

2.1 Surface Soils

Surface soils are sampled at the five air monitoring sites. Surface soil samples consist of samples removed by trowel to a depth of one centimeter, from an undisturbed area, within a surface area of 1.25 square feet. Total sample volume is 0.041 cubic feet. The technique utilized is to remove surface organic material covering the site, remove soil to a depth of one centimeter using a trowel for the entire described surface area, and directly placing the excavated soil into the plastic bag. An identification tag, containing sample location, sample type identification, date, and technician initials is then fastened around the bag closure sealing the contents.

Soil samples are then transmitted to the analytical laboratory along with the appropriate Certificate of Analysis sheet for the following analysis on a dry basis:

- 1. Natural Uranium; and,
- 2. Radium-226;

Results are reported as micro Curies per gram.

Sect 4	.1-4.3	
Page 2	of	5
Revison:	Zero	
Date:	1/85	-

2.0 MONITORING METHODOLOGY (continued)

2.2 Vegetation

Forage vegetables are sampled per growing season at three locations, northeast, northwest, and southwest of the mill, where such vegetation may exist.

Vegetation is clipped at edible or ground plane elevations and itemized as to species and location sampled. Samples are enclosed in plastic bags for storage and transportation for analysis. Edible portions are defined as that portion normally consumed by the consumer. Weights of vegetation are obtained prior to shipment to the laboratory. The wet basis weight, location, species, date sampled, and technician initials are included on the bag closure tag.

Vegetation is analyzed for:

- 1. Radium-226; and,
- 2. Lead-210.

Results are reported as micro Curies per kilogram on wet basis.

2.3 External Gamma

External gamma is monitored at the ambient air sampling sites using the spherical container TLD badges of Eberline. The containers, each containing five TLD chips, are mounted one meter above ground plane at each site with two containers per site. The containers loaded with TLD's are received the first of each quarter from Eberline and exchanged with those in the field. A background TLD is stored in a lead-lined container as a transportation control. The TLD's are returned to Eberline for processing with a report returned within three weeks of transmittal.

Values reported are in millirem per week average for the monitor period along with a counting error term.

3.0 CALIBRATION

There are no calibration requirements associated with soil, vegetation or external gamma measurements as required to be done at the site.

4.0 RECORD KEEPING

4.1 Surface Soils

Surface soil record keeping consists of:

Soil type, (clay, sand, silt, gravel);

 Sect
 4.1-4.3

 Page
 3
 of
 5

 Revison:
 Zero

 Date:
 1/85

4.0 RECORD KEEPING (continued)

- 2. Date sampled:
- 3. Location sampled;
- 4. Technician initials; and.
- 5. Radionuclide analysis.

Records are maintained in the 40 CFR 190 data notebook maintained at the Environmental Office.

4.2 Vegetation

Data maintained in record form for vegetation analysis includes:

- 1. Sample date:
- 2. Species identification;
- 3. Sample location;
- 4. Sample weight, wet basis;
- 5. Technician initials; and,
- 6. Radionuclide analysis.

Data is maintained in 40 CFR 190 notebook in the Environmental Office.

4.3 External Gamma

Data maintained as a record summary for external gamma is:

- 1. Sample period;
- 2. Sample location; and,
- 3. External gamma levels for total radiation.

Data is maintained on computer files.

5.0 MONITORING LOCATION AND FREQUENCY

5.1 Surface Soils

Surface soil sampling occurs during March of each year at the ambient air sampling sites (BHV-1 to BHV-5).

Sect	4.1-	4.3		
Page	4	of	5	-
Reviso	on:	Zer	0	-
Date:		1/8	5	MARKANCO .

5.0 MONITORING LOCATION AND FREQUENCY (continued)

5.2 Vegetation

Vegetation samples are obtained during each growing season and are divided between forage and direct human food consumption species. Forage species are collected at or near the following sites:

- BHV-1 near meteorological station;
- 2. BHV-1 west (1/2 mile) of meteorological station; and,
- BHV-4 ambient particulate monitoring station (southwest of mill);

5.3 External Gamma

External gamma measurements are taken over a quarterly interval for the twelve months of the year at all ambient air particulate monitoring sites.

6.0 ANALYSIS PROCEDURE

The laboratory analytical procedures utilized are as presented in the appropriate Laboratory Analytical Procedure Manual except for external gamma which is done by Eberline, Inc.

7.0 QUALITY ASSURANCE METHODOLOGY

7.1 Surface Soils

Surface soil samples are obtained from a known surface area by using a standard template. Maintaining one centimeter depth is by tape measure or other suitable graduated measure. Identification tags are installed in the field labeling each sample with tags secured to the sample container. A field log notebook is also maintained. Samples are stored in locked rooms or containers with access only by environmental personnel. Samples are submitted to the analytical laboratory in sealed, locked containers accompanied by Certificate of Analysis sheets.

7.2 Vegetation

Vegetation samples are stored in plastic bags and weighed upon return to the laboratory. Only edible portions are sampled. Samples are identified and tagged in the field and stored in locked containers prior to transhipment to locked, sealed containers to the analytical laboratory. Certificate of Analysis sheets include wet basis weights and accompany samples to the laboratory. Sample sizes are at least two kilograms each.

Sect	4.1-4.3	
Page 5	of	5
Revison:	Zero	
Date:	1/85	

7.0 QUALITY ASSURANCE METHODOLOGY (continued)

7.3 External Gamma

Quality assurance for external gamma measurements consist of:

- Monitoring the containers once per week to document that TLD's are still there;
- 2. Checking the containers to insure Eberline enclosed chips;
- Changing containers one by one to insure same numbered container is at same site;
- Insuring all containers are present when receiving or shipping to Eberline; and,
- Review of Eberline data for consistency and data transposition.

5.0 ADMINISTRATIVE CONTROL - ALARA

Sect	5.1
Page 1	of 1
Revison:	Zeru
Date:	1/85

WHITE MESA PROCEDURES MANUAL

MONITORING GUIDELINES ENVIRONMENTAL

RADIOLOGICAL AUDIT PROGRAM

1.0 FREQUENCY

An ALARA audit of the environmental monitoring program is conducted on a semi-annual basis. The audit is conducted with the presence of the Plant Superintendent, Environmental Coordinator, corporate environmental personnel and/or corporate health and safety personnel.

2.0 PURPOSE

The purpose of the audit is to administer the environmental monitoring program to maintain conditions as low as reasonably achievable through administrative familiarization and reaction to observed environmental conditions. A detailed audit report is submitted to the Operations Manager-Uranium with a copy forwarded to the Nuclear Regulatory Commission.

3.0 REPORT

The audit committee reviews and documents in a semi-annual report the following items:

- Documented inspection reports,
- Environmental radiological effluent and monitoring data, including Quality Assurance data, and
- Reviews of operating and monitoring procedures completed during this time period.

The audit report specifically addresses:

- Trends in environmental radiological effluent and monitoring data.
- 2. Performance of effluent control equipment
- Administrative controls/policies on ALARA management of retention systems and releases.