



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1646 JACKSON, MISSISSIPPI 39205

83 SEP 15 11:36

September 12, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1

Docket No. 50-416

License No. NFF-13

File 0260/L-835.0

Special Report 83-079/0 - Fire
Doors in Auxiliary Building
Blocked Open to Support
Planned Maintenance
Activities

AECM-83/0570

On August 8, 1983, fire rated doors 1A108 and 1A109 in the Auxiliary Building were blocked open to support planned maintenance activities (to run hose for testing). Fire watches were established in accordance with Technical Specification 3.7.7 until the doors were restored on August 22, 1983.

This is submitted as a Special Report pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation (LCO) was exceeded. The event had no affect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

J H Hobbs

for L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: (See Next Page)

8309190366 830912
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555