

MISSISSIPPI POWER & LIGHT COMPANY Helping Build Mississippi P. D. BOX 1640, JACKSON, MISSISSIPPI 39205 83 SEP 14 AID: 35 September 7, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission Region II 101 Marietta Street, N.W., Suite 2900 Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station Unit 1 Docket No. 50-416 License No. NPF-13 File 0260/L-835.0 Special Report 83-033/1 - Update Report - Fire Rated Penetrations Opened to Implement Design Change Packages AECM-83/0547

This is an update to a previous report submitted on May 7, 1983, for the following event. Beginning on April 11, 1983, the fire rated penetrations listed on the attached page, were opened to implement design change packages. Hourly fire watches were established within one hour and will be maintained for the duration of the planned maintenance activities in accordance with Technical Specification 3.7.7. The purpose of this update is to provide a revised estimated completion date for fire rated penetrations that have not been restored.

The condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The remainder of the work tasks are now expected to be completed by October 15, 1983. This is reported as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

& H Hobbs


L. F. Dale Manager of Nuclear Services

OFFICIAL COPY IE 22 1/1

EBS/SHH:rg

Attachment

cc: See next page



Member Middle South Utilities System

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0547 Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

.

Mr. Richard C. DeYoung, Director (w/a) Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Document Control Desk (w/a) U. S. Nuclear Regulate Commission Washington, D. C. 20555 Beginning on April 11, 1983, the following fire rated penetrations were opened to implement design change packages. A restoration date is listed for the penetrations which have been restored. The remainder are expected to be restored by October 15, 1983.

PENETRATIONS	DATE RESTORED	INCIDENT REPORT #
CE-7E	08/27/83	83-04-35
CE-179D	08/23/83	83-04-33
CE-417B		83-04-32
CE-323C		83-04-32
CE-360G		83-04-38
CE-1G		83-04-38
CE-82E		83-04-38
CE-278D		83-04-38
CE-12C		83-04-38
CE-4C		83-04-71
CE-272D		83-04-71
CE-95D	06/07/83	83-04-72
CE-8E	06/07/83	83-04-72
CE-210C	그 가 잘 챙겨야 했다. ㅋㅋㅋㅋ	83-04-62
CE-438G		83-04-62
AE-87C	08/26/83	83-04-60
AE-132C	08/26/83	83-04-60
FIRE DAMS		
L072/LA35	07/12/83	83-04-44
L064/LA37	07/12/83	83-04-25
L064/LA52	07/12/83	83-04-25
L065/LA54	07/12/83	83-04-25
L067/LA53	07/12/83	83-04-25
L066/LA54	07/12/83	83-04-25
L067/LA57	07/12/83	83-04-25
L094/LA23	07,12/83	83-04-25
L094/LA5	07/12/83	83-04-25
L092/LA5	07/12/83	83-04-25
L091/LA4	07/12/83	83-04-25
L089/LA5	07/12/83	83-04-25
L089/LA1	07/12/83	83-04-25
L090/LA4	07/12/83	83-04-25