



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

September 6, 1983

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 69
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company (the licensees) dated November 23, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 69, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 6, 1983

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 69 TO FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Revise Appendix A as follows:

Remove Pages

3/4 7-32b

3/4 7-32d

3/4 7-33

-

Insert Pages

3/4 7-32b

3/4 7-32d

3/4 7-33

3/4 7-33a

TABLE 3.7-4a (Continued)

SAFETY RELATED HYDRAULIC SNUBBERS*

BEAVER VALLEY - UNIT 1	SNUBBER NO.	SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION				ACCESSIBLE OR INACCESSIBLE	HIGH RADIATION ZONE	ESPECIALLY DIFFICULT TO REMOVE
3/4 7-32b	RC-IHSS-3	RC	RCP	Cub. C	722'	I	Yes	Yes
	RC-IHSS-4	"	"	"	722'	"	"	"
	PS-245-VS-1	"	"	"	725'	"	"	"
	VS-359-1	"	"	"	719'	"	"	"
	SI-IHSS-420	SI	"	"	731'	"	"	"
	SI-IHSS-421	"	"	"	731'	"	"	"
	RC-IHSS-101	RC	RCP	Cub. A.	739'	I	Yes	Yes
	RC-IHSS-102	"	"	"	739'	"	"	"
	SI-IHSS-102A	SI	"	"	745'	"	"	"
	SI-IHSS-102B	"	"	"	745'	"	"	"
	SI-IHSS-414	"	"	"	741'	"	"	"
	RC-IHSS-103	RC	RCP	Cub. B	739'	"	"	"
	RC-IHSS-104	"	"	"	739'	"	"	"
	SI-IHSS-418	SI	"	"	741'	"	"	"
	RC-IHSS-23	RC	REA.	CONT. BLDG.	749'	A	No	No
	RC-IHSS-105	RC	RCP	Cub. C	739'	I	Yes	Yes
	RC-IHSS-106	RC	"	"	739'	"	"	"
	RC-IHSS-130	"	"	"	739'	I	"	"
	RC-IHSS-131	"	"	"	739'	"	"	"
	SI-IHSS-114A	SI	"	"	745'	"	"	"
	SI-IHSS-114B	"	"	"	745'	"	"	"
	SI-IHSS-422	"	"	"	741'	"	"	"
	SI-IHSS-423	"	"	"	739'	"	"	"
	RC-IHSS-41A	"	"	"	784'	"	"	"

* Snubbers may be added to safety related systems without prior License Amendment to Table 3.7-4 provided that safety evaluations, documentation and reporting are provided in accordance with 10 CFR 50.59 and that a revision to Table 3.7-4 is included with a subsequent License Amendment request.

TABLE 3.7-4a (Continued)

SAFETY RELATED HYDRAULIC SNUBBERS*

SNUBBER NO.	SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION			ACCESSIBLE OR INACCESSIBLE	HIGH RADIATION ZONE	ESPECIALLY DIFFICULT TO REMOVE
WFPD-IHSS-207	FW	REA. CONT. BLDG.	772'	A	No	No
WFPD-IHSS-208	"	"	772'	"	"	"
WFPD-IHSS-208A	"	"	771'	"	"	"
SIIP-IHSS-207	MS	"	796'	I	"	Yes
SIIP-IHSS-208	"	"	796'	"	"	"
WFPD-IHSS-221	FW	"	772'	A	"	No
WFPD-IHSS-212	"	"	772'	"	"	"
WFPD-IHSS-212A	"	"	771'	"	"	"
SIIP-IHSS-213	MS	"	798'	I	"	Yes
SIIP-IHSS-214	"	"	798'	"	"	"
SIIP-IHSS-209	"	"	798'	"	"	"
SIIP-IHSS-210	"	"	798'	"	"	"
SIIP-IHSS-211	"	"	798'	"	"	"
SIIP-IHSS-212	"	"	798'	"	"	"
SIIP-IHSS-214A	"	"	805'	"	"	"
WFPD-IHSS-209	FW	"	780'	A	"	No
WFPD-IHSS-210	"	"	780'	"	"	"
RC-IHSS-119	"	"	734'	"	"	"
SI-PSSP-337	SI	"	728'	"	No	"
SI-IHSS-409	"	"	729'	"	"	"
SI-IHSS-410	"	"	731'	"	"	"
SI-IHSS-411	"	"	731'	"	"	"
RS-IHSS-201	RS	"	731'	"	Yes	"

* Snubbers may be added to safety related systems without prior License Amendment to Table 3.7-4 provided that safety evaluations, documentation and reporting are provided in accordance with 10 CFR 50.59 and that a revision to Table 3.7-4 is included with a subsequent License Amendment request.

TABLE 3.7-4b

SAFETY RELATED MECHANICAL SNUBBERS*

<u>SNUBBER NO.</u>	<u>SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION</u>			<u>ACCESSIBLE OR INACCESSIBLE</u>	<u>HIGH RADIATION ZONE**</u>	<u>ESPECIALLY DIFFICULT TO REMOVE</u>
RC-PSSP-115	RC	Pressurizer Cub.	768'	A	Yes	No
RC-PSSP-116	"	"	768'	"	"	"
RC-PSSP-24A	"	"	770'	"	"	Yes
RC-PSSP-24B	"	"	769'	"	"	"
RC-PSSP-25A	"	"	779'	"	"	"
RC-PSSP-25B	"	"	778'	"	"	"
RC-HSS-042A-A	"	"	784'	"	"	"
RC-HSS-042A-B	"	"	784'	"	"	"
RC-PSSP-122A	"	"	784'	"	"	"
RC-PSSP-122B	"	"	784'	"	"	"
RC-PSSP-301	"	"	784'	I	"	"
CC-PSSP-300A	CC	P.A. Bldg.	726'	A	No	No
CC-PSSP-300B	"	"	726'	"	"	"
CC-HSS-406A	CC	Pipe Annulus	710'	I	Yes	Yes
CC-HSS-406B	"	"	710'	"	"	"
WR-HSS-307	RW	P.A. Bldg.	732'	A	No	No
WCCB-PSSP-101	SGBD	Rea. Cont. Bldg.	727'	"	Yes	"
WCCB-H-47A	"	"	731'	"	"	"
RC-PSSP-128	RC	PRT Cub.	735'	"	"	"
RC-PSSP-129	"	"	733'	"	"	"
WCCB-PSSP-46E	SGBD	RCP Cub. A	740'	"	"	"
WCCB-PSSP-46F	"	"	740'	"	"	"
WCCB-PSSP-46G	"	"	740'	"	"	"
WCCB-PSSP-46H	"	"	740'	"	"	"

* Snubbers may be added to safety related systems without prior License Amendment to Table 3.7-4b provided that a revision to Table 3.7-4b is included with the next License Amendment request.

**Modifications to this column due to changes in high radiation areas may be made without prior License Amendment provided that a revision to Table 3.7-4b is included with the next License Amendment request.

TABLE 3.7-4b, Continued

SAFETY RELATED MECHANICAL SNUBBERS*

<u>SNUBBER NO.</u>	<u>SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION</u>		<u>ACCESSIBLE OR INACCESSIBLE</u>	<u>HIGH RADIATION ZONE**</u>	<u>ESPECIALLY DIFFICULT TO REMOVE</u>	
CC-HS-021B	CC	RCP Cub. A	744'	A	Yes	No
CC-HS-021A	"	"	745'	"	"	"
CC-HS-001A	CC	RCP Cub. B	740'	"	"	"
CC-HS-001B	"	"	739'	"	"	"
WGCB-PSSP-200A	SGBD	"	740'	"	"	"
WGCB-PSSP-200B	"	"	740'	"	"	"
WGCB-PSSP-200C	"	"	740'	"	"	"
WGCB-PSSP-200D	"	"	740'	"	"	"
WGCB-PSSP-55G	SGBD	RCP Cub. C	722'	"	"	"
WGCB-PSSP-55H	"	"	722'	"	"	"
WGCB-PSSP-55E	"	"	728'	"	"	"
WGCB-PSSP-55F	"	"	728'	"	"	"
RC-PSSP-20	RC	PRT Cub.	734'	"	"	"

* Snubbers may be added to safety related systems without prior License Amendment to Table 3.7-4b provided that a revision to Table 3.7-4b is included with the next License Amendment request.

**Modifications to this column due to changes in high radiation areas may be made without prior License Amendment provided that a revision to Table 3.7-4b is included with the next License Amendment request.