

DISTRIBUTION: JAN 24 1984 Bocket File NRC PDR L PDR ORB#3 Rdg DEisenhut OELD EJordan JTaylor Vice President - Nuclear Operations ACRS-10 Virginia Electric and Power Company Grav File PMKreutzer

LEngle

Docket Nos. 50-338 and 50-339

Dear Mr. Stewart:

Post Office Box 26666

Richmond, Virginia 23261

Mr. W. L. Stewart

SUBJECT: POTENTIAL FOR VOIDING IN REACTOR COOLANT SYSTEM ANTICIPATED TRANSIENTS, NUREG-0737 ITEM II.K.2.17/NORTH ANNA POWER STATION, UNITS 1 AND 2 (NA-1&2)

We have completed our review of the subject as noted above for Westinghouse plants. Our generic safety evaluation is provided in the enclosure to this letter.

Based on our review, we have determined that the issue of steam formation in the reactor coolant system of Westinghouse plants has been adequately addressed. We further conclude that a steam void will not result in unacceptable consequences during anticipated transients.

Therefore, Item II.K.2.17 of NUREG-0737 is hereby resolved for NA-1&2.

Sincerely,

Original Signed by J. R. Miller

James R. Miller, Chief **Operating Reactors Branch #3** Division of Licensing

Enclosure: Safety Evaluation

cc: See next page

8402130375 840124 PDR ADOCK 05000338 PDR

	IFruile	AI
OFFICE	CRB#3:DL	ORB#3: DL
	LEngle/pn	GRMi <sup>4</sup> ler
DATE	1/24/84	1/2/184

NRC	FORM	318	110	801	NRCM	0240

OFFICIAL RECORD COPY

A U.S. GPO 1983-400-247

..................

## Virginia Electric and Power Company

cc: Richard M. Foster, Esq. Musick, Williamson, Schwartz, Leavenworth & Cope, P.C. P. 0. Bex 4579 Boulder, Colorado 80306

Michael W. Maupin, Esq. Hunton, Williams, Gay and Gibson P. O. Box 1535 Richmond, Virginia 23212

Mr. Paul W. Purdom Environmental Studies Institute Drexel University 32nd and Chestnut Streets Philadelphia, Pennsylvania 19104

Atomic Safety and Licensing Appeal Board Panel U.S. Nuclear Regulatory Commission Washington, D. C. 20555

Ellyn R. Weiss, Esq. Sheldon, Harman, Roisman and Weiss 1725 I Street, N.W. Suite 506 Washington, D. C. 20006

Mr. E. W. Harrell P. O. Box 402 Mineral, Virginia 23117

Mr. Anthony Gambardella Office of the Attorney General 11 South 12th Street - Room 308 Richmond, Virginia 23219

Resident Inspector/North Anna c/o U.S.N.R.C. Senior Resident Inspector Route 2, Box 78 Mineral, Virginia 23117

Mr. J. H. Ferguson Executive Vice President - Power Virginia Electric and Power Company Post Office Box 26666 Richmond, Virginia 23261 Mrs. Margaret Dietrich Route 2, Box 568 Gordonsville, Virginia 22042

111

Mr. W. T. Lough Virginia Corporation Commission Division of Energy Regulation P. O. Box 1197 Richmond, Virginia 23209

Mrs. June Allen North Anna Environmental Coalition 8720 Lockmoor Circle Wichita, Kansas 67207

U.S. Environmental Protection Agency Region III Office ATTN: Regional Radiation Representative Curtis Building 6th and Walnut Streets Philadelphia, Pennsylvania 19106

Regional Administrator Nuclear Regulatory Commission, Region II Office of Executive Director for Operations 101 Marietta Street, Suite 3100 Atlanta, Georgia 30303

Old Dominion Electric Cooperative c/o Executive Vice President 5601 Chamberlayne Road Richmond, Virginia 23227



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

124

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION NUREG-0737, ITEM II.K.2.17

> VOIDING IN THE REACTOR COOLANT SYSTEM DURING ANTICIPATED TRANSIENTS IN WESTINGHOUSE PLANTS NORTH ANNA POWER STATION, UNIT NOS. 1 & 2

## I. INTRODUCTION

On April 14, 1979, just after the TMI-2 incident, the NRC issued IE Bulletin No. 79-06A (ref. 1) which, among other things, required all Westinghouse plant licensees to review the actions required by operating procedures for coping with transients and accidents with particular attention to:

- a. Recognition of the possibility of forming voids in the primary coolant system large enough to compromise the core cooling capability, especially natural circulation capability,
- Decator action required to prevent the formation of such voids, and
- c. Operator action required to enhance core cooling in the event such voids are formed (e.g., remote venting).

On June 11, 1980, a steam bubble formed in the upper head region of a Combustion Engineering plant during a natural circulation cooldown (ref. 2). The issue of steam formation in the reactor coolant system (RCS) of Westinghouse plants was thereafter made part of TMI Action Plan Requirement II.K.2.17 (ref. 3).

The June 11, 1980 event also resulted in the issuance of an NRC Generic Letter (ref. 4) which asked all PWR licensees to review their capabilities for performing natural circulation cooldown and to assess the potential for upper vessel voiding during the process. The natural circulation issue, which is now called Multi Plant Action No. B-66, is being evaluated separately.

#### II. DISCUSSION

Subsequent to Reference 4 the Westinghouse Owners Group undertook a study (ref. 5) to ascertain the potential for void formation in Westinghouse reactors during anticipated transients. For this study Westinghouse used the WFLASH computer program, which models the RCS with nodalized volumes connected by flow paths. This has two phase flow capability, and tracks voids when they occur.

The potential for voids during transients depends on, among other things, the initial temperature of the fluid in the upper head region and the degress with which it mixes with colder fluid in other parts of the primary system. In Westinghouse plants the initial upper head temperature depends on how much cold leg fluid

2

is diverted to this region. For the newer Westinghouse plants there is enough cold leg fluid diverted to make the temperature in the upper head region essentially equal to the temperature of the cold leg fluid. However, most currently

operating Westinghouse plants have an amount of flow into the upper head region which results in an upper fluid temperature that is between the cold leg temperature and the core outlet temperature. Since there will be more voiding in the plants with the hotter upper head regions, these are considered to be the limiting case. For these plants Westinghouse conservatively assumed that the initial temperature of the fluid in the upper reactor vessel was equal to the core outlet temperature. Thus, in their analyses of loss of coolant transients with a loss of offsite power, voids form in the upper head region whenever the RCS pressure drops to the saturation pressure corresponding to the initial core outlet temperature.

For Westinghouse plants with the reactor coolant pumps running, the flow into the upper head region is from the upper downcomer through the spray holes. The flow out of the upper head region is downward through the guide tubes into the upper plenum region. If the reactor coolant pumps are stopped, this flow into the upper head slows, stops, and then reverses direction. This is because the water in the core is heated by the decay heat, so it has a lower density than the cold leg water in the downcomer. Thus

3

without the reactor coolant pumps operating, the hot, low-density water in the core is buoyed up through the guide tibes into the upper head region. This hotter water increases the potential for creating voids. Thus a loss of offsite power with the consequential loss of the reactor coolant pumps will increase the amount of void created in the upper head region.

To make the results of these analyses valid for all Westinghouse-designed 2, 3, and 4 loop plants, Westinghouse evaluated the variations in (1) thermal inertia of the upper head region (2) the power level to upper plenum volume ratio, and (3) the guide tube/spray nozzle flow path resistance. The analyses showed that the thermal inertia of the upper head region is largest for the highest power (3411MWth) 4 loop plant with an inverted top hot upper support plate, so this was modeled in the WFLASH program. It was also determined that the power level to upper plenum volume ratio was essentially the same for all 2, 3, and 4 loop plants and that the guide tube/spray nozzle flow path resistance is less in the 2 and 3 loop plants. From these evaluations Westinghouse concluded that the results of the transient analyses for steam voiding on a 4 loop 3411 MWth plant with an inverted top hat upper support plate bound those for all Westinghouse plants.

Steam voids can be created in the upper reactor vessel by either decreasing the pressure below the saturation pressure at the

4

prevailing fluid temperature (i.e., a depressurization event) or increasing the temperature of the water above the saturation temperature. For all of the anticipated transients, including those where the

temperature of the water is increased, Reference 5 states:

"Previous analyses performed for preparation of --- safety analyses reported in plant licensing documentation explicitly account for void formation in the upper head region if it is calculated to occur. The results of the previous analyses indicate no safety concerns are associated with this possibility since voids generated in the upper head would be collapsed when they are brought in contact with the subcooled region of the system."

## III. EVALUATION

Westinghouse has had the capability for calculating the effects of steam voids in reactor coolant systems since the FLASH program (Reference 6) was first developed in 1966. However, this program was too time consuming for large scale problems such as the calculation of voids in upper reactor vessels during transients. By 1969 Westinghouse had developed FLASH-4 (Reference 7) which, with the more rapid calculating ability provided by an implicit formulation, did allow the calculation of voids in reactor vessels. The ability to calculate voids was carried into LOFTRAN programs by greatly reducing the velocity of a fixed fraction of the flow, i.e., by creating a "dead volume".

6

Based on this knowledge and the availability of these computer programs we agree that the analyses performed for the anticipated transients reported in the licensing documentation of these Westinghouse plants account for the effects of void formation in the reactor coolant systems.

### IV. CONCLUSION

The staff concludes that the voids generated in the reactor coolant systems of these Westinghouse plants during anticipated transients are accounted for in present analysis models. Furthermore, based on transient analyses performed by Westinghouse using these models, the staff further concludes that this steam void will not result in unacceptable consequences during anticipated transients in any of these Westinghouse plants.

# REFERENCES

- U.S. NRC, IE Bulletin Nc. 79-06A, "Review of Operational Errors and System Misalignments Identified During the Three Mile Island Incident", April 14, 1979.
- Check, P. S. "Void Formation in Vessel Head During St. Lucie Natural Circulation Cooldown Event of June 11, 1980, dated August 12, 1980.
- U.S. NRC, "Clarification of TMI Action Plan Requirements"; NUREG-0737; page II.K.2.17-1, dated November, 1980.
- U.S. NRC, "Natural Circulation Cooldown (Generic Letter No. 81-21)", dated May 5, 1981.
- Jurgensen, R. W.; "St. Lucie Cooldown Event Report"; WOG-57; April 20, 1981.
- Margolis, S. G. and Redfield, J. A.; "FLASH: A Program for Digital Simulation of the Loss-of-Coolant Accident"; WAPD-TM-534; May 1966.
- Porsching, T. A. et.al.; "FLASH-4: A Fully Implicit Fortran IV Program for the Digital Simulation of Transients in a Reactor Plant"; WAPD-TM-840; March 1969.