

January 27, 1995

Mr. M. S. Tuckman
Senior Vice President
Nuclear Generation
Duke Power Company
P. O. Box 1006
Charlotte, NC 28201

SUBJECT: RESPONSE TO NRC BULLETIN 90-01, SUPPLEMENT 1, "LOSS OF FILL-OIL IN TRANSMITTERS MANUFACTURED BY ROSEMOUNT" - CATAWBA NUCLEAR STATION, UNITS 1 AND 2 (TAC NOS. M85371 AND M85372)

Dear Mr. Tuckman:

By letters dated February 22 and May 24, 1993, and November 30, 1994, you provided responses to NRC Bulletin 90-01, Supplement 1, "Loss of Fill-Oil in Transmitters Manufactured by Rosemount." for the Catawba Nuclear Station, Units 1 and 2. The responses reported having 34 Rosemount transmitters at Catawba that are subject to the Requested Actions of the Supplement 1.

The staff has reviewed your responses and finds they conform with the Requested Actions and reporting requirements of NRC Bulletin 90-01, Supplement 1, for the Catawba Nuclear Station, Units 1 and 2. The staff's evaluation and conclusions are contained in the enclosed Safety Evaluation. This completes our activities associated with TAC Nos. M85371 and M85372. Further NRC review, if any, will be performed by inspection or audit.

Sincerely,

/s/

Robert E. Martin, Senior Project Manager
Project Directorate II-3
Directorate for Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION

Docket Files
PUBLIC
PDII-3 Reading
J. Zwolinski
S. Vargz
OGC
ACRS (4)

E. Merschoff, RII
R. Crlenjak, RII
N. Le
D. Spaulding

FILE NAME: G:\CATAWBA\CAT85371.LTR

OFFICE	LA: PD23:DRPE	PM: PD21:DRPE	PM: PD23:DRPE	D: PD23:DRPE
NAME	L. HERRY	N. Le	R. MARTIN	H. BERKOW
DATE	1/27/95	1/25/95	1/26/95	1/27/95

9502080002 950127
PDR ADDOCK 05003413
PDR

OFFICIAL RECORD COPY

070000

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

January 27, 1995

Mr. M. S. Tuckman
Senior Vice President
Nuclear Generation
Duke Power Company
P. O. Box 1006
Charlotte, NC 28201

SUBJECT: RESPONSE TO NRC BULLETIN 90-01, SUPPLEMENT 1, "LOSS OF FILL-OIL IN TRANSMITTERS MANUFACTURED BY ROSEMOUNT" - CATAWBA NUCLEAR STATION, UNITS 1 AND 2 (TAC NOS. M85371 AND M85372)

Dear Mr. Tuckman:

By letters dated February 22 and May 24, 1993, and November 30, 1994, you provided responses to NRC Bulletin 90-01, Supplement 1, "Loss of Fill-Oil in Transmitters Manufactured by Rosemount." for the Catawba Nuclear Station, Units 1 and 2. The responses reported having 34 Rosemount transmitters at Catawba that are subject to the Requested Actions of Supplement 1.

The staff has reviewed your responses and finds they conform with the Requested Actions and reporting requirements of NRC Bulletin 90-01, Supplement 1, for the Catawba Nuclear Station, Units 1 and 2. The staff's evaluation and conclusions are contained in the enclosed Safety Evaluation. This completes our activities associated with TAC Nos. M85371 and M85372. Further NRC review, if any, will be performed by inspection or audit.

Sincerely,

A handwritten signature in cursive script that reads "Robert E. Martin".

Robert E. Martin, Senior Project Manager
Project Directorate II-3
Directorate for Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosure:
Safety Evaluation

cc w/encl: See next page

Mr. David L. Rehn
Duke Power Company

cc:

Mr. Z. L. Taylor
Regulatory Compliance Manager
Duke Power Company
4800 Concord Road
York, South Carolina 29745

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

North Carolina Municipal Power
Agency Number 1
1427 Meadowood Boulevard
P. O. Box 29513
Raleigh, North Carolina 27626-0513

Mr. T. Richard Puryear
Nuclear Technical Services Manager
Westinghouse Electric Corporation
Carolinas District
2709 Water Ridge Parkway, Suite 430
Charlotte, North Carolina 28217

County Manager of York County
York County Courthouse
York, South Carolina 29745

Richard P. Wilson, Esquire
Assistant Attorney General
South Carolina Attorney General's
Office
P. O. Box 11549
Columbia, South Carolina 29211

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Dayne H. Brown, Director
Division of Radiation Protection
N.C. Department of Environment,
Health and Natural Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Catawba Nuclear Station

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

Senior Resident Inspector
4830 Concord Road
York, South Carolina 29745

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of
Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-0001

Saluda River Electric
P. O. Box 929
Laurens, South Carolina 29360

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335