

Docketfile



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 2, 1995

LICENSEE: GPU Nuclear Corporation
FACILITY: Three Mile Island Nuclear Station, Unit 1 (TMI-1)
SUBJECT: SUMMARY OF JANUARY 25, 1995, MEETING WITH GPU NUCLEAR CORPORATION REGARDING ACTIVE LICENSING ISSUES AT THREE MILE ISLAND NUCLEAR STATION, UNIT 1 (TMI-1)

On Tuesday, January 25, 1995, a public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and GPU Nuclear Corporation (GPUN) at the TMI-1 site. The purpose of the meeting was to discuss active TMI-1 licensing issues. Attachment 1 is the list of participants at the meeting. Attachment 2 is a copy of the handouts used during the meeting.

Changes since the previous meeting (on 11/15/94) include (see Attachment 2):

Completed staff action since last meeting:

- TSCR 246 - Revision to Long-Range Plan - Closed out. Amendment 192 issued on 11/23/94.
- TMI-1 Conditions of Operation - Closed out. The staff issued a letter on 12/29/94 that deleted the conditions of operation imposed in 1985 at the time of TMI-1 restart. The conditions were no longer applicable and were deleted in response to a GPUN request dated 6/4/94.
- NRC Bulletin 88-11 - Pressurizer Surge Line Thermal Stratification - Closed out. GPUN provided reconfirmation that all actions have been completed for TMI-1 in a letter dated December 13, 1994.
- GL 91-11 - Resolution of Generic Issues 48 and 49 - Closed out. Completion of the staff's review was documented in a letter dated 3/5/92.
- NRC Bulletin 93-02 - Debris plugging of ECCS suction strainers. Closed out. Completion of the staff's review was documented in a letter dated 12/12/94.
- Remote Shutdown System Technical Specifications (TS) - Closed out. The staff completed its review and concluded that TS are required. GPUN was informed by letter dated 12/27/94 that a TS Change Request should be submitted. GPUN agreed to a 3/31/95 submittal date.

Other changes:

- Implementation of USI A-46 resolution (SQUG) (TAC No. M69486) - GPUN stated that the USI A-46 seismic evaluation report will be submitted in 5/95.

9502080160 950202
PDR ADOCK 05000289
P PDR

NRC FILE CENTER COPY

JFO

- ◆ Motor-operated valves - Generic Letter (GL) 89-10. Inspection report 94-12 was issued on August 30, 1994 and requested a management meeting with GPUN. The meeting was held on 10/20/94 to further discuss outstanding MOV issues. GPUN supplied its response to GL 89-10, Supplement 6 on 11/3/94 and will request NRC concurrence for a schedule extension to the 11R refueling outage (Fall 1995).
- ◆ Review of B&W Topical Report BAW-2228 - UT examination of RV nozzles. Conditional relief to use ID UT was given in the staff's SE dated 10/8/92, conditioned on qualification of the technique proposed by B&W. BWOG responded to an RAI on 10/20/94 and the staff approved the topical report on 12/2/94. The next step is for GPUN to make a plant-specific submittal referencing the approved topical report.
- ◆ ASME Code Case N-498-1 - steam generator hydro - the staff will consider a plant-specific relief by 2/95 in response to GPUN's request dated 6/24/94.
- ◆ ASME Code Case N-416-1 - steam system alternate NDE - the staff is reviewing the 9/1/94 GPUN request and should complete its review in 2/95.
- ◆ IST Interval extension request - teleconference held with GPUN in 11/94. Staff will not grant plant-specific request pending generic rulemaking. Companion NUREG to be issued in 2/95. Rule will require all licensees to upgrade to 1989 version of Code as necessary.
- ◆ GL 92-01 - Reactor vessel integrity - the completion date for the staff review was changed to 3/95.
- ◆ TSCR 221 (TAC No. M86713) - Undervoltage relays. The scheduled date for issuance of a license amendment was changed to 2/95.
- ◆ TSCR 237 (TAC No. M89457) - QA audit frequency changes - GPUN to resubmit TSCR with changes requested by the staff by 2/95.
- ◆ TSCR 245 is scheduled to be submitted to the NRC in the near future to change the expiration date of the TMI-1 license to recover the NRC-ordered shutdown time between the TMI-2 accident and lifting of the shutdown order in 1985. GPUN met with the staff on 1/26/95 to discuss this request.
- ◆ Thermolag concerns were briefly discussed. The response to GL 92-08 followup RAI was submitted on 12/5/94. The staff issued an additional followup letter on 12/29/94.

GPUN discussed their intention to perform a service water self-assessment inspection. This project was also discussed with Region I management on January 24 during a site tour.

GPUN was asked to add a section to the licensing issue listing that denotes issues that were resolved since the last meeting. They agreed to do so.

Original signed by:

Ronald W. Hernan, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-289

- Attachments: 1. List of Attendees
- 2. GPUN meeting handout

cc w/atts: See next page

Distribution w/attachments 1 & 2:
 Docket File
 PUBLIC
 PDI-4 Memo
 RHernan
 JRogge, RI
 OGC
 SNorris
 EJordan, D/AEOD

w/attachment 1:
 WRussell/FMiraglia
 RZimmerman
 SVarga
 JZwolinski
 PMcKee
 ACRS (4)
 WDean


Document Name: G:\HERNAN\1-25-95.SUM

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4		
NAME	SNorris	RHernan:bf	PMcKee		
DATE	2/1/95	2/2/95	2/19/95	1/1	1/1

February 2, 1995

GPUN discussed their intention to perform a service water self-assessment inspection. This project was also discussed with Region I management on January 24 during a site tour.

GPUN was asked to add a section to the licensing issue listing that denotes issues that were resolved since the last meeting. They agreed to do so.



Ronald W. Hernan, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-289

Attachments: 1. List of Attendees
2. GPUN meeting handout

cc w/atts: See next page

Three Mile Island Nuclear Station, Unit No. 1

cc:

Michael Ross
O&M Director, TMI-1
GPU Nuclear Corporation
Post Office Box 480
Middletown, Pennsylvania 17057

John C. Fornicola
Planning and Regulatory Affairs
Director
GPU Nuclear Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054

Jack S. Wetmore
Manager, TMI Licensing
GPU Nuclear Corporation
Post Office Box 480
Middletown, Pennsylvania 17057

Ernest L. Blake, Jr., Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037

Chairman
Board of County Commissioners
of Dauphin County
Dauphin County Courthouse
Harrisburg, Pennsylvania 17120

Chairman
Board of Supervisors
of Londonderry Township
R.D. #1, Geyers Church Road
Middletown, Pennsylvania 17057

Michele G. Evans
Senior Resident Inspector (TMI-1)
U.S. Nuclear Regulatory Commission
Post Office Box 311
Middletown, Pennsylvania 17057

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Robert B. Borsum
B&W Nuclear Technologies
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852

William Dornsife, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
Post Office Box 2063
Harrisburg, Pennsylvania 17120

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Mr. T. Gary Broughton, Vice President
and Director - TMI-1
GPU Nuclear Corporation
Post Office Box 480
Middletown, PA 17057

CATEGORY	ITEM	ENGR	LAI	GPLM ACTION / STATUS	NRC ACTION / STATUS	Next Action by	TAC No.	PRIOR
GENERIC MULTI-PLANT 10CFR73	SECURITY VENTILE BARRIER UPGRADE	DVN GMC		GPLM TO SUBMIT DESIGN SPECS TO NRC 180 DAYS FOLLOWING EFFECTIVE DATE OF RULE CHANGE TO 10CFR73(a)(1)(iii), <u>DUE 2/28/95.</u>	NRC TO APPROVE BY <u>TBD</u> .	GPLM		B3
GENERIC MULTI-PLANT GL 86-10	REMOTE SHUTDOWN TECH SPECS	DVN DJD	89-9662	GPLM SUBMITTED LETTER (C311-94-2027), DATED 3/21/94 REQUESTING NRC CONCURRENCE THAT THE REMOTE SHUTDOWN SYSTEM DOES NOT NEED TO BE INCLUDED IN THE TECH SPECS. GPLM TO SUBMIT REMOTE SHUTDOWN TECH SPECS BY <u>3/31/95.</u>	NRC DENIED GPLM REQUEST IN A LETTER (C311-94-3385), DATED 12/30/94 AND REQUESTED THAT GPLM SUBMIT REMOTE SHUTDOWN TECH SPECS.	GPLM		C
GENERIC MULTI-PLANT GL 87-02	SQUA (USI A-46)	YH	88-9249 92-9114 92-9170	GPLM RESPONDED TO NRC SER (C311-88-3186, DATED 7/29/88), 311-88-2134, DATED 10/6/88 & C311-89-3079, DATED 3/7/89) QUESTIONS - INTEGRATED SCHEDULE IN A LETTER (C311-90-2009), DATED 1/26/90. GPLM LETTER (C311-92-2119), DATED 9/21/92 COMMITTED TO COMPLETION OF A-46 AND SUBMITTAL OF THE REVIEW RESULTS BY 5/22/95. SAFE SHUTDOWN LIST DEVELOPED 5/93. GPLM SUBMITTED PROC & CRITERIA USED TO DEVELOP FLOOR RESPONSE SPECTRA BY LETTER (C311-93-2103), DATED 8/15/93. 10R WALKDOWNS WERE COMPLETED AS SCHEDULED. USI A-46 SEISMIC EVALUATION REPORT TO BE SUBMITTED <u>IN 5/95.</u>	NRC ISSUED SUPPLEMENT TO THEIR SER TO RESOLVE THE PREVIOUS OPEN ITEMS ON 5/22/92. NRC IS AGREEABLE TO A SINGLE WALKDOWN. NRC EVALUATION OF SUPP 1 RESPONSE DATED 11/18/92 (C311-92-3215). NRC APPROVED GPLM METHODOLOGY FOR DEVELOPMENT OF FLOOR RESPONSE SPECTRA FOR RESOLUTION OF USI A-46 IN A LETTER DATED 9/26/94 (C311-94-3247) FILE#94218.	GPLM	H69486	C LRP CAT B
GENERIC MULTI-PLANT GL 88-20	Individual Plant Evaluations (IPE)	DJD	89-9250	GPLM SUBMITTED THE IPE ON 5/20/93 PER TMI-1 INTEGRATED SCHEDULE (C311-93-2048).	NRC TO REVIEW IPE BY 12/95. ✓	NRC	H74480	B3
GENERIC MULTI-PLANT GL 88-20 Supp 4	IPEEE	DJD	91-9238 91-9239	IPEEE PROGRAM DESCRIPTION SUBMITTED 12/24/91 (C311-91-2150). FINAL IPEEE RESULTS TO BE SUBMITTED 12/20/94. GPLM SUBMITTED SCHEDULE REASSESSMENT LETTER 9/2/92 (C311-92-2107). GPLM SUBMITTED FINAL IPEEE RESULTS IN A LETTER (C311-94-2332), DATED 12/29/94.	NRC TO REVIEW PLAN AND SCHEDULE BY 3/31/92. NRC IS AGREEABLE TO A SINGLE WALKDOWN. ALL PLANTS WILL BE ASKED TO RESPOND BEFORE 6/94. METHODOLOGY IS ACCEPTABLE, 6/95 IS LATEST DATE ACCEPTABLE. LETTER TO GPLM 6/29/92 CONFIRMED THIS. NRC LETTER (C311-93-3266), DATED 11/18/93 APPROVED THE SCHEDULE. NRC TO REVIEW GPLM SUBMITTAL OF IPEEE RESULTS BY <u>TBD</u> .	NRC	H83685	B3

CATEGORY	ITEM	ENGR	LAI	GPUN ACTION / STATUS	NRC ACTION / STATUS	Next Action by	TAC No.	P2/OR
GENERIC MULTI-PLANT GL 89-10	Motor Operated Valves (MOV's)	DVN	89-9148	GPUN INITIAL RESPONSE SUBMITTED 12/28/89 INDICATING 11R COMPLETION. NRC LETTER DATED 07/90 CONCURRED. NRC IR 92-80 CONTAINED 1 VIOLATION & IDENTIFIED SEVERAL ISSUES & ALSO STATED TMI WAS WORKING TO A 07/01/94 COMPLETION DATE. TMI DID NOT ADDRESS THE SCHEDULE ISSUE IN THE VIOL RESPONSE. IR 94-12 IN JULY 1994 RESULTED IN A MANAGEMENT MTG AT REGION I IN OCT 1994. GPUN LETTER 11/3/94 (C311-94-2151) PROVIDED ADDITIONAL STATUS OF MOV PROGRAM. THE MAIN ISSUE NOW IS THE SCHEDULE COMPLETION. TMI WILL SEND A LETTER TO REGION I TO CLARIFY THE SCHEDULE CONFUSION AND REQUEST CONCURRENCE FOR A SCHEDULE EXTENSION TO 11R.	NRC REGION I INSPECTION WEEK OF 6/8/92. IR ISSUED 7/24/92 (C311-92-3147). NRC PHASE II INSPECTION WEEK OF 7/11/94. IR 94-12 (), ISSUED ON 8/30/94, REQUESTED A MANAGEMENT MEETING WITH GPUN. THE MEETING WAS 10/20/94 TO DISCUSS MOV ISSUE. A FINAL INSPECTION IS PLANNED FOR SPRING OF 1995.	GPUN/NRC	N75728	C
GENERIC MULTI-PLANT GL 92-01	RV Integrity	YN	92-9055	GPUN SUBMITTED RESPONSE ON 7/2/92 (C311-92-2086). BMOG REPORT SUBMITTED FEB 1992 FOR WELDS BELOW 50 FT-LBS UPPER SHELF ENERGY. GPUN RESPONDED RAI BY LETTER (C311-93-2163) DATED 12/13/93. GPUN LETTER DATED 5/13/94 (C311-94-2075) COMMITTED TO A RESPONSE 30 DAYS FROM THE DATE THE LAST BMOG PLANT RECEIVES THE RAI. BMOG GENERIC RESPONSE (BAW-2222) WAS PROVIDED IN JUNE, 1994). GPUN RESPONSE (5000-94-0030/C311-94-2097), DATED 6/24/94 ENDORSED THE BMOG REPORT (BAE-2222) AND CONFIRMED APPLICABILITY OF BAW-2178P AND BAW-2192P TO TMI-1 FOR EQUIVALENT MARGIN ANALYSIS OF ITS LOW UPPER SHELF WELD METALS.	NRC RAI DATED 7/19/93 (C311-93-3159). NRC APPROVED THE APPLICABILITY OF BAW-2178P AND BAW-2192P IN A LETTER TO BMOG DATED 3/29/94. NRC REQUESTED ADDITIONAL INFORMATION IN GL 92-01, REVISION 1 (C311-94-3077), DATED 4/11/94. NRC MET WITH BMOG ON 5/19/94 TO DISCUSS GENERIC BMOG RESPONSE. NRC IS REVIEWING BAW-2222. NRC TO APPROVE GPUN RESPONSE BY 12/94.	NRC	N83741	C

NEW
INFO

3/95

CATEGORY	PLANT	ENGR	LAI	GPUN ACTION / STATUS	MRC ACTION / STATUS	Next Action by	TAC No.	PRIOR
GENERIC MULTI-PLANT GL 92-08	Thermo-Lag 330-1 Fire Barriers	MGH	94-9181	GPUN RESPONDED TO GL ON 4/12/93 (C311-93-2015). GPUN RESPONDED TO 12/21/93 RAI ON 2/10/94 (C311-94-2012). GPUN TO RESPOND TO 50.54(F) REQUEST BY 12/19/94. GPUN DISCUSSED THE PLANNED ACTIONS WITH THE PROJECT MANAGER ON 11/15/94 (C311-94-3342, DATED 11/30/94) AND REQUESTED A MEETING IN JANUARY 1995 TO DISCUSS THE EXEMPTION REQUEST PLANNED. GPUN TO RESPOND BY 3/29/95 TO HRC MRC FOLLOWUP TO THE RAI.	HRC REQUESTED ADDITIONAL INFORMATION IN A LETTER DATED 12/21/93 (C311-93-3292). BY LETTER DATED 9/19/94 (C311-94-3237) HRC ACKNOWLEDGED GPUN 2/10/94 RESPONSE TO RAI AND REQUESTED GPUN RESPOND IN 90 DAYS TO SECTIONS OF THE 2/10/94 GPUN RESPONSE THAT HAD BEEN DEFERRED OR WERE INCOMPLETE. BY LETTER DATED 12/29/94, HRC REQUESTED ADDITIONAL INFORMATION WITHIN 90 IN A FOLLOWUP TO THE PREVIOUS RAI.	GPUN	M85615	C
GENERIC MULTI-PLANT IEB 88-11	PZR Surge Line Stress	MRC GMC	89-9030 89-9028 94231.0 1	GPUN SUBMITTED REAP 1/1/90, C311-89-2141. GPUN WILL UPDATE ATIQUE ANALYSIS & SUBMIT RESULTS BY 1/91. GPUN TO SUBMIT UPDATED BWDG FATIGUE ANALYSIS BY 1/4/91. BWDG SUBMITTED TOPICAL RPT ON THIS ISSUE TO NRC ON 12/31/90 (OG-813). GPUN REQUESTED TO EXTEND THE DUE DATE FOR PLT SPECIFIC ANALYSIS BY 60 DAYS PER LTR DTG 12/21/90, C311-90-2151. GPUN RESP SUBMITTED 3/20/91 (C311-91-2015). GPUN RESPONDED TO HRC REQUEST IN A LETTER (C311-94-2345), DATED 12/13/94.	HRC TO REVIEW GPUN SUBMITTAL BY 8/91. HRC SER AND OPEN ISSUES (TAC NO. 72174) ON BAWOG BOUNDING ANALYSIS DATED 8/9/90 (C311-90-3178). SER ON BAW-2127, HRC TO TAYLOR DATED 7/24/91 REQUESTS ADDITIONAL INFORMATION FROM BAWOG. HRC CLOSED IN THE TAC IN C311-91-3172 DATED 9/18/91. TAC WAS REOPENED BY HRC LETTER DATED 10/12/94, (C311-94-3274) WHICH REQUESTED A 60 DAY RESPONSE (12/16/94) CONFIRMING THAT ALL ACTIONS REQUIRED BY 88-11 INCLUDING UPDATING OF THE PLANT SPECIFIC STRESS AND FATIGUE ANALYSIS REQUESTED BY ACTION 1.d ARE COMPLETE. HRC TO REVIEW GPUN RESPONSE BY TBB	HRC	72174	C
GENERIC MULTI-PLANT IEB 92-01	Failure of Thermo-Lag 330 Fire Barrier	MGH	92-9118	GPUN RESPONDED TO IEB 7/28/92 (C311-92-2102). GPUN SUBMITTED A SUPPLEMENTAL RESPONSE ON 8/18/92 (C311-92-2111). TELECOM HELD W/MRR ON 9/23/92. GPUN RESPONDED TO SUPP 1 OF IEB & TELECOM ON 9/25/92 (C311-92-2125).	HRC TO REVIEW RESPONSE BY 12/94. HRC MAY CLOSE OUT BULLETIN 92-01 AND TRACK THE THERMO-LAG 330 ISSUE UNDER GENERIC LETTER 92-08.	HRC	M83940	B2

CLOSE OUT

CATEGORY	ITEM	ENGR	LAI	GPUN ACTION / STATUS	NRC ACTION / STATUS	Next		
						Action by	TAC No.	PRIOR
PLANT SPECIFIC ISI - 10yr	Ten Year ISI Program Description and Relief Requests	NRK		GPUN SUBMITTED PROGRAM DESCRIPTION W/RELIEF REQUESTS 4/19/91 (C311-91-2010). GPUN SUBMITTED ADD'L INFORMATION/CLARIFICATION 12/18/91 (C311-91-2129). GPUN SUBMITTED REQUEST TO DEFER OTSG SECONDARY SIDE HYDRO TO 11R ON 10/9/92 (C311-92-2132). GPUN SUBMITTED 3 RELIEF REQUESTS ON 2/16/93 (C311-93-2004). GPUN SUBMITTED ANOTHER RELIEF REQUEST ON 4/16/93 (C311-93-2031). AS REQUESTED BY THE NRC IN A MTG ON 5/27/94, BMOG WILL RESPOND TO RAI IN 4-6 WEEKS TO SATISFY CONDITIONS FOR GRANTING RELIEF REQUEST NO. 1 AS PROVIDED IN THE NRC'S SER DATED 10/8/92. BMOG LETTER OG-1386, DATED 6/8/94 COMMITTED TO ADDITIONAL GENERIC BOUNDING FRACTURE MECHANICS ANALYSIS. BMOG RESPONDED TO RAI 8/24/94 (OG-1416). BMOG RESPONDED TO RAI ON BAW-2228 ON 10/20/94 (OG-1432) REQUESTING NRC RESPONSE BY 11/94. TMI-1 NEEDS APPROVAL BY 4/19/2001; OTHER B&W PLANTS NEED RESOLUTION SOONER. GPUN/BMOG TO RESPOND TO NRC'S 12/2/94 LETTER.	NRC APPROVED FIRST INTERVAL RELIEF ON 9/11/91 (C311-91-3176). NRC REQUESTED ADDITIONAL INFORMATION ON 9/19/91 (C311-91-3173) REGARDING 2ND INTERVAL PROGRAM. NRC TRANSMITTED SER 10/8/92 (C311-92-3192). NRC APPROVED OTSG HYDRO DEFERRAL 1/5/93 (C311-93-3005). NRC TRANSMITTED SER ON 9/1/93 (C311-93-3204). THE SER DATED 10/2/92 REQUIRED THAT THE ALTERNATIVE EXAMINATION TECHNIQUE MEET CERTAIN CONDITIONS. IN A MTG ON 5/27/94, BMOG WAS REQUESTED TO PROVIDE ADDITIONAL FRACTURE ANALYSIS FOR NRC TO CONCLUDE THE CONDITIONS HAVE BEEN MET. SUBJECT TO BMOG RESPONSE, THE NRC WILL PROVIDE A GENERIC APPROVAL ON THE BMOG DOCKET FOR REFERENCE BY PROJECT MANAGERS FOR EACH OF THE PLANT DOCKETS. NRC REQUESTED ADDITIONAL INFORMATION ON BAW-2223 BY LETTER DATED 10/12/94. NRC APPROVED BAW-2228 IN A LETTER TO BMOG DATED 12/2/94, WHICH REQUESTED LICENSEES TO REFERENCE AND CONFIRM APPLICABILITY TO EAW-2228A.	GPUN	NR0197 NR4761 NR5877	C
PLANT SPECIFIC IST - 10 YR	24 MONTH EXTENSION OF THE TEN YEAR IST INTERVAL	NRK	N/A	GPUN LETTER (C311-94-2098) DATED 6/29/94 REQUESTED EXTENSION OF THE 10-YR IST INTERVAL BY 24 MONTHS BASED ON A RULEMAKING THAT WILL DELETE THE UPDATE REQUIREMENT BUT NOT IN TIME FOR TMI-1 BENEFIT WITHOUT RELIEF. GPUN SUBMITTED AN APPEAL LETTER (C311-94-2156), DATED 11/29/94.	NRC DENIED GPUN REQUEST BY LETTER DATED 9/22/94 (C311-94-3244). NRC TO RESPOND TO GPUN APPEAL LETTER BY TBD.	NRC/GPUN	NR0018	B1
PLANT SPECIFIC IST APPROVAL	APPROVAL TO USE ASME CODE CASE N-498-1	NRK	N/A	GPUN LETTER (C311-94-2073), DATED 6/24/94 REQUESTED APPROVAL TO USE ASME CODE CASE N-498-1.	NRC TO PROVIDE GENERIC ENDORSEMENT OF CODE CASE N-498-1 BY REG GUIDE IN MID '95. NRC TO RE-EVALUATE NEED FOR PLANT SPECIFIC APPROVAL IN 1/95 BASED ON THE STATUS OF GENERIC APPROVAL.	NRC		B2

RULEMAKING IN PROGRESS

NRC WILL CONSIDER
PLANT-SPECIFIC RELIEF BY 2/95

CATEGORY	ITEM	ENGR	LAI	GPUN ACTION / STATUS	NRC ACTION / STATUS	Next Action by	T&C No.	PRIOR
PLANT SPECIFIC 1ST APPROVAL	APPROVAL TO USE ASME CODE CASE N-416-1 & NDE CRITERIA RELIEF	MRK		GPUN REQUESTED: 1) NRC APPROVAL TO USE ASME CODE CASE N-416-1 DUE TO HARDSHIP RELATED TO HYDROSTATIC TESTS AND 2) SPECIFIC RELIEF FROM THE CODE CASE TO USE ORIG CONSTRUCTION CODE NDE ACCEPTANCE CRITERIA VS 1992 CODE SECTION III CRITERIA RATHER THAN REPEAT THE NDE (C311-94-2076, DATED 9/1/94). HYDROS AFFECTED TO DATE ARE OTSG SECONDARY SIDE (INCLUDING MS, FW, AND EPW) AND NSRW. APPROVAL/RELIEF WAS REQUESTED BY 1/95. THERE WILL BE ONE ADDITIONAL HYDRO, NECESSITATED BY RCP SEALS WORK, FOR WHICH THE CODE CASE WILL APPLY. RELIEF IS ONLY NEEDED FOR THE WELDED REPAIRS PERFORMED PRIOR TO ASME ISSUANCE OF THE CODE CASE, WHERE THE NEW ISI CRITERIA WAS NOT USED.	MRC TO APPROVE BY TBB 2/95	NRC	N90392	B1
TSCR 214	Primary / Secondary Leakrate	PFC MRK		GPUN SUBMITTED A TSCR TO REVISE CURRENT 0.1 GPM LEAKRATE TO 0.2 GPM (PREVIOUSLY APPROVED ON A TEMPORARY BASIS) 5/13/92 (C311-92-2036). GPUN MET WITH NRC ON 7/1/93 TO DISCUSS APPROVAL OF A PERMANENT CHANGE TO 0.2 GPM. TSCR TO REMAIN IN PLACE FOR POTENTIAL CYCLE 10 TEMP CHANGE. GPUN SUPPLEMENT TO TSCR-214 (C311-93-2174), DATED 1/10/94 PROVIDED ADDITIONAL INFORMATION FROM 10R TO SUPPLEMENT GPUN REQUEST FOR A PERMANENT CHANGE.	F.R. NOTICE 10/14/92. COULD BE ISSUED AFTER COMMENT PERIOD IF NEEDED. SINCE THE 7/1/93 MEETING, THE NRC QUESTIONED THE NEED FOR A PERMANENT CHANGE AND DEFERRED THE DECISION ON A PERMANENT CHANGE UNTIL AFTER 10R. NRC WILL NOT APPROVE ON A PERMANENT BASIS.	GPUN	N84597	C
TSCR 221	Undervoltage Relays	MGH		GPUN SUBMITTED TSCR-221 ON 5/17/93 (C311-93-2064) REQUESTING RELAXATION OF REQUIREMENTS FOR INOPERABLE UNDERVOLTAGE RELAYS AND PROVIDING GUIDANCE FOR ACTIONS. GPUN SUBMITTED REVISED PAGE ON 12/23/94 (C311-94-2376).	NRC TO APPROVE BY TBB 3/95. NOTE: AMENDMENT 189 CHANGED PAGE 3-32A. THEREFORE, THE CORRESPONDING PAGE IN TSCR-221 IS NO LONGER CURRENT. IN A 8/25/94 MEETING WITH NRC REVIEWER AND PM, GPUN AGREED TO MINOR CHANGES.	NRC	N86713	C

CATEGORY	ITEM	ENGR	LAI	GPUN ACTION / STATUS	MRC ACTION / STATUS	Next Action by	TAC No.	PRIOR
TSCR 223	RADIATION MONITORING SYSTEM	AMN		GPUN TO SUBMIT TSCR BY 3/95 WHICH WILL REVISE TS AS FOLLOWS: 1. TRANSFER REMAINING RETS FROM TS TO ODCM, 2. DELETE FROM TS SURVEILLANCE ALL 2AD MONITORS THAT DON'T HAVE AN ASSOCIATED LCO, AND 3. EXTEND CALIBRATION FREQUENCY OF SOME OF THE REMAINING RAD MONITORS FROM QUARTERLY TO UP TO 18 MONTHS.	MRC TO APPROVE BY <u>TBD</u> .	GPUN		C
TSCR 227	Improvements from Std Tech Specs	NRK		GPUN SUBMITTED TSCR 227 (C311-94-2154) ON 01/16/95 TO ADOPT CERTAIN IMPROVEMENTS AND DELETIONS AS PERMITTED BY STS AND REGULATIONS AS FOLLOWS: 1. PERSONNEL ACCESS HATCH CONTAINMENT REQUIREMENTS - ADOPT STS, 2. RB ANNUAL INSPECTION - DELETE INSPECTION NOT REQUIRED BY APPENDIX J, 3. RCS PRESSURE TESTS - DELETE TESTS NOT REQUIRED BY STS OR ASME CODE, 4. HYDROGEN RECOMBINER SURVEILLANCE - REFUELING VS 6-MO PER GL93-05, 5. REVIEW OF TSCR - ADOPT STS VS 50.59 REVIEW, 6. BS NOZZLE INSPECTION - ADOPT 10-YR STS FREQ VS 5-YR FREQ, 7. NSSV'S - ADOPT STS FREQUENCY, 8. PCSV'S - ADOPT STS FREQUENCY AND INCORPORATE BASIS CHANGE, 9. CR AIR TREATMENT SYSTEM - ADOPT TEST DURATION FOR SYSTEMS W/O NTRS.	MRC TO APPROVE BY <u>TBD</u> .	MRC		C
TSCR 237	QA AUDIT FREQUENCY	DPK		GPUN SUBMITTED TSCR 237 (C311-94-2031), DATED 4/19/94 TO DELETE AUDIT FREQUENCIES FROM TS 6.5.3 AND REVISE OQA PLAN. GPUN TO RESUBMIT BY 2/95.	MRC LETTER (C311-94-3142), DATED 6/10/94 PROJECTED THE REVIEW WILL TAKE MORE THAN 60 DAYS. MRC DISCUSSED CONCERNS IN A 10/94 CONFERENCE CALL REGARDING INTERVALS > 24 MO. REVIEW IS COMPLETE.	GPUN	MB9457	B1

CATEGORY	ITEM	ENGR	LAI	GPUN ACTION / STATUS	NRC ACTION / STATUS	Next Action by	TAC No.	PRIOR
TSCR 243	24 MONTH SURVEILLANCE	DGJ		GPUN TO SUBMIT A TSCR BY 2/26/95 TO EXTEND TEN (10) SURVEILLANCES (WITH FREQUENCY NOTATION "F") TO ACCOMMODATE THE 24 MONTH FUEL CYCLE. THESE REFUELING INTERVAL SURVEILLANCES WERE NOT COVERED BY AMENDMENT 175 (TSCR 206).	NRC TO APPROVE BY <u>TBD</u> .	GPUN		B1
TSCR 244	CYCLE 10 CONTROL ROD DROP TIME TESTING	DJD WGH		GPUN SUBMITTED A TSCR ON 5/20/94 (C311-94-2069) REQUESTING EXIGENT REVIEW TO REVISE THE MAXIMUM ALLOWABLE CONTROL ROD INSERTION TIME ACCEPTANCE CRITERION (2.11 SEC) FOR THE REMAINDER OF CYCLE 10 FOR 12 CONTROL RODS PREVIOUSLY EXPERIENCING SLOW DROP TIMES DURING TESTING. THE AMENDMENT MAY BE REQUIRED TO SUPPORT STARTUP FOLLOWING FUTURE ROD TESTING.	NRC TRANSMITTED FR NOTICE (C311-94-3129), DATED 6/7/94. NRC TO REVIEW AND APPROVE BY <u>TBD</u> .	NRC	NB9496	A
TSCR 245	License Change To Recover Extended Shutdown	GRG		GPUN TO SUBMIT LICENSE CHANGE REQUEST BY 2/10/95 TO RECOVER THE EXTENDED SHUTDOWN PERIOD (6YRS AMC 3MO) FOR THE OPERATING LICENSE. GPUN HAS SCHEDULED A MEETING WITH THE NRC ON 1/26/95.	NRC TO APPROVE BY <u>TBD</u> .	GPUN		A
TSCR XX1	In-House Reload Methodology	DJD		GPUN TO SUBMIT A TSCR AND REQUEST FOR TOPICAL REPORT REVIEW AND APPROVAL TO PERFORM RELOAD ANALYSES USING IN-HOUSE METHODOLOGY AND CRITERIA BEGINNING WITH CYCLE 12. TOPICAL REPORTS TO BE SUBMITTED 1/95 (1), 2/95 (2) AND 4/95 (1). NRC APPROVAL REQUESTED BY 4/96.	NRC TO APPROVE BY <u>TBD</u> .	GPUN		C
TSCR XX2	Purge Valve Testing	NRK		GPUN TO SUBMIT TSCR BY <u>TBD</u> TO ADOPT A PERFORMANCE BASED SPECIFICATION FOR PURGE VALVE TESTING.	NRC TO APPROVE BY <u>TBD</u> .	GPUN		B3
TSCR XX3	FUEL MOVEMENT WITH PERSONNEL AIR LOCK OPEN	NRK		GPUN TO SUBMIT TSCR BY 3/1/95 TO ALLOW MOVEMENT OF FUEL OR POSITIVE REACTIVITY CHANGES WITH PERSONNEL AIR LOCK OPEN.	NRC TO APPROVE BY <u>TBD</u> .	GPUN		B2