



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

February 10, 1995

TVA-SQN-TS-94-07

10 CFR 50.90

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of	)	Docket Nos. 50-327
Tennessee Valley Authority	)	50-328

SEQUOYAH NUCLEAR PLANT (SQN) - SUPPLEMENTAL INFORMATION TO  
TECHNICAL SPECIFICATION (TS) CHANGE 94-07 (TAC NOS. M91219 AND  
M91220)

Reference: TVA letter to NRC dated December 16, 1994, "Sequoyah Nuclear  
Plant (SQN) - Technical Specification (TS) Change 94-07,  
'Reduction of Maximum Applicable Power Level for Operation  
With One or More Main Steam Safety Valves (MSSVs)  
Inoperable'"

In accordance with 10 CFR 50.90, we are enclosing an amendment to  
Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The  
proposed change supplements the above referenced submittal by clarifying the  
limits of Mode 3 applicability.

The supplemental changes to the proposed TS change are identified in  
Enclosure 1 (affected pages only). The justification for the proposed TS  
change is provided in Enclosure 2. Enclosure 3 provides a revised significant  
hazard consideration, which contains the original and supplemental  
information.

140113

9502140342 950210  
PDR ADDCK 05000327  
PDR

DO30

U.S. Nuclear Regulatory Commission

Page 2

February 10, 1995

The need for this supplemental response was a result of an oversight when TVA decided to leave the Nuclear Instrumentation System high-neutron flux trip setpoint in the affected TS Section 3.7.1.1.

TVA requests a 45-day implementation period for this TS change following issuance.

Please direct questions concerning this issue to Steve Gilley at 843-7427.

Sincerely,

*R. H. Shell*

R. H. Shell  
Manager  
SQN Site Licensing

Sworn to and subscribed before me  
this 10<sup>th</sup> day of February 1995

*Gregg M. Bellisople*  
Notary Public  
My Commission Expires Oct 21, 1998

Enclosures

cc: See page 3

U.S. Nuclear Regulatory Commission  
Page 3  
February 10, 1995

(Enclosures):

Mr. D. E. LaBarge, Project Manager  
Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

Mr. Michael H. Mobley, Director (w/o Enclosures)  
Division of Radiological Health  
3rd Floor  
L & C Annex  
401 Church Street  
Nashville, Tennessee 37243-1532

NRC Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323-2711