



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

83 SEP 19 49:55

NUCLEAR PRODUCTION DEPARTMENT

September 16, 1983

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-045/1 - Update
Report - Fire Doors Blocked Open
to Allow Performance of a
Planned Maintenance Activity
AECM-83/0512

This is an update to a previous report submitted on June 17, 1983. The condition for which the report was submitted occurred on May 15, 1983, when fire doors OC501 and OC503 on the east side of the Control Room were blocked open to allow the routing of hoses into the Control Room for the sealing of fire rated penetrations. A fire watch was established at the start of the planned maintenance activity and was maintained for the duration in accordance with Technical Specification 3.7.7.

The doors were not closed by the seven day time limit of the action statement, therefore, the previous report was submitted as a Special Report pursuant to Technical Specification 6.9.2. The condition had no effect on the health and safety of the public and did not constitute a threat to plant safety. The planned maintenance activity is complete and the doors were restored to operability on July 30, 1983. This is a final report.

Yours truly,

L. F. Dale
for L. F. Dale
Manager of Nuclear Services

EBS/SHH:rg

cc: See next page

8309210233 830916
PDR ADOCK 05000416
S PDR

CONFIDENTIAL COPY
1022
110

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555