



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

September 16, 1983

83 SEP 19 9:53

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-055/1 -
Update Report - Fire Rated
Penetrations Opened to
Implement Design Change
Packages
AECM-83/0589

This is an update to a previous report submitted July 13, 1983, for the event described below. The purpose of this update is to provide a revised estimated completion date.

On June 7, 1983, two fire rated penetrations (CE-365F and CE-274D) in the Control Building were opened for the implementation of design change packages. Also on June 9, 1983, two new penetrations (AP3G and AP2G) were cut in the Auxiliary Building stairway wall to implement a design change and were restored on August 26, 1983. Fire watches were established within one hour and were maintained for the duration of the planned activities in accordance with Technical Specification 3.7.7.

The condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. Penetrations CE-365F and CE-274D are now expected to be resealed by November 1, 1983. This is submitted as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

L. F. Dale

L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: (See Next Page)

8309210236 830916
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY
TE 22
1/0

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0589

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555