

MISSISSIPPI POWER & LIGHT COMPANY AISSISSIPPT POWER Mississippi Helping Build Mississippi . O. BOX 1640, JACKSON, MISSISSIBPSEF19 A9:55

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission Region II 101 Marietta St., N.W., Suite 2900 Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station Unit 1 Docket No. 50-416 License No. NPF-13 File 0260/L-835.0 Special Report 83-053/1 -Update Report - Fire Rated Penetrations Opened to Implement Design Change Packages AECM-83/0586

This is an update to a previous report submitted July 8, 1983, for the event described below. The purpose of this update is to provide a revised estimated completion date.

Beginning on June 1, 1983, the fire rated penetrations listed on the attached page were opened to implement design change packages and restored on the dates listed. Hourly fire watches were established within one (1) hour and will be maintained for the duration of the planned maintenance activities in accordance with Technical Specification 6.9.2.

This condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The remaining work tasks are now expected to be complete by November 1, 1983.

Yours truly,

SAHobba

for L. F. Dale Manager of Nuclear Services

EBS/SHH:sap Attachment

cc: (See Next Page)

8309210290 830915 PDR ADOCK 05000416

TEZZ 10

Member Middle South Utilities System

## MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0586 Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

.

Mr. Richard C. DeYoung, Director (w/a) Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Document Control Desk (w/a) U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Attachment to AECM-83/0586 Page 1 of 1

Beginning on June 1, 1983, the following fire rated penetrations were opened to implement design change packages and restored on the dates listed. The remaining work tasks are expected to be completed by November 1, 1983.

PENETRATIONS	INCIDENT REPORT #	RESTORATION DATE
CE-36G CE-20E CE-87E CE-74E CE-200D	83-06-05 83-05-04 83-06-04 83-06-04 83-06-04	08-25-83 08-25-83 08-25-83
CABLE TRAY COVER DTGE 43-45	83-06-02	08-23-83
FIRE DAMS		
LA59-L09 in U720 LA18-L04 in U739 LA59-L01 in U739	83-06-04 83-06-04 83-06-04	08-25-83 08-25-83
LA10-L059 in U720 LA13-L03 in U739 LA12-L03 in U739	83-06-04 83-06-04 83-06-04	08-25-83 08-25-83 08-25-83