# JAN 27 1984

Alabama Power Company ATTN: Mr. R. P. McDonald Vice President-Nuclear Generation P. O. Box 2641 Birmingham, AL 35291

Gentlemen:

SUBJECT: MEETING SUMMARY - DOCKET NOS. 50-348 AND 50-364

This letter refers to the meeting conducted at your request in the NRC Region II office on January 12, 1984. The meeting related to the application of 10 CFR 50.48 and 10 CFR 50 Appendix R, Fire Protection, at the Farley facility.

It is our opinion that this meeting was beneficial. It provided for a better understanding of the NRC's fire protection requirements.

In accordance with Section 2.790 of NRC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosure will be placed in NRC's Public Document Room.

Should you have any questions concerning this matter, we will be pleased to discuss them.

Sincerely,

Richard C. Lewis, Director Division of Project and Resident Programs

Enclosure: Meeting Summary

cc w/encl:

W. O. Whitt, Executive Vice President

F. L. Clayton, Jr., Senior Vice President

H. O. Thrash, Manager, Nuclear Operations and Administration

O. D. Kingsley, Jr., Manager, Nuclear Engineering and Technical Services

J. W. McGowan, Manager-Safety Audit

and Engineering Review
W. G. Ware, Supervisor-Safety Audit

and Engineering Review

W. G. Hairston, III, Plant Manager

bcc: See page 2

8402140307 840127 PDR ADOCK 05000348 PDR bcc w/encl: NRC Resident Inspector Document Control Desk State of Alabama

WHMiller:sa 01/24/84 RII 484
TEConlon
01/24/84

ARHERD JAOISHINSKI 01/36/84

o PRII i Overrelli 01/14/84

haclewis 01/12/84

#### Enciosure

#### MEETING SUMMARY

Licensee: Alabama Power Company

Facility: Farley

Docket Nos.: 50-348 and 50-364

License Nos.: NPF-2 and NPF-8

Subject: Fire Protection Requirements

A management meeting was held in the NRC Region II office on January 12, 1984, to discuss the application of 10 CFR 50.48 and 10 CFR 50 Appendix R (Fire Protection) at the Farley Site. The following items were discussed in detail: protection requirements for equipment and components needed for cold shutdown; separation and/or fire barrier requirements for both major and minor components needed for safe shutdown; protection of steel supports for fire barriers and cable trays; protection requirements for areas involving "intervening combustibles" between safe shutdown components; detection and suppression requirements for fire areas involving safe shutdown equipment i.e., partial protection or total area protection requirements; and, repair requirements to equipment and components which would be damaged by an actual or a postulated fire. Based on the detail discussion, the licensee indicated that certain portions of the Farley Appendix R submittal would be reviewed to verify that the above items were adequately addressed and where applicable, sufficient exemptions would be submitted to the NRC.

Attachment: Attendance List

#### ATTACHMENT

#### ATTENDANCE LIST

Attendance at the APCO - NRC meeting on January 12, 1984, at the NRC Region II office.

### Alabama Power Company

R. L. George, Superintendent, Licensing and Design

C. L. Buck, Design Supervisor

## Southern Company Services, Inc.

D. R. McComb, Design Engineer

J. C. Yance, Fire Protection

J. Wilson, Fire Protection

#### Bechte1

J. E. Love, Engineering Supervisor

R. Puhl, Engineering

# NRC - Region II

T. E. Conlon, Chief, Plant Systems Section

F. S. Cantrell, Chief, Project Section 1B W. H. Bradford, Senior Resident Inspector, Farley

W. H. Miller, Jr., Fire Protection Engineer