

POWER & LIGHT / PO BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 368-2345

February 3, 1984

W3K84-0242 Q-3-A35.07

Mr. John T. Collins Regional Administrator, Region IV U. S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76012

REFERENCE: Telecon C. Hooper (LP&L) and J. Boardman (NRC Region IV) on

December 22, 1983

Telecon C. Hooper (LP&L) and W. Crossman (NRC Region IV) on

January 20, 1984

Telecon C. Hooper (LP&L) and J. Tapia (NRC Region IV) on

January 30, 1984

Dear Mr. Collins:

SUBJECT: Waterford SES Unit No. 3

Docket No. 50-382

Potentially Reportable Deficiency No. 141

"Deficient 4160V (GE) Switchgear Terminations"

Final Report

On December 22, 1983, a problem with deficient (GE) switchgear terminations was reported as Potentially Reportable Deficiency No. 141. Further evaluation of the previously described condition indicates this condition is not considered reportable pursuant to the requirements of 10CFR50.55(e).

## EVALUATION

Control wiring in the GE switchgear does generally employ pre-insulated ring tongue connectors. However, because of the terminals on the Knox fuse block, GE modified the pre-insulated lugs to accommodate the terminals and also used spade type lugs.

General Electric stated that various combinations of lugs used on the Knox fuse blocks were used in the prototype test program for seismic qualification. Hence, the seismic qualification is valid.

Based on the above evaluation, this PRD is considered not reportable.

Very truly yours,

Durch

T. F. Gerrets

Corporate Quality Assurance Manager

TFG: CNH: SSTG

Mr. John T. Collins February 3, 1984 W3K84-0242 Page 2

cc: Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555
(15 copies)

Director
Office of Management
Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. E. L. Blake Shaw, Pittman, Potts, & Trowbridge 1800 M Street, N.W. Washington, D.C. 20036

Mr. W. M. Stevenson Monroe & Lemann 1424 Whitney Building New Orleans, Louisiana 70130