



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429
January 16, 1984

FILE: B09-13510A
SERIAL: BSEP/84-0058

Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 & 2
DOCKET NO. 50-325 and 50-324
LICENSE NO. DPR-71 AND DPR-62
SUPPLEMENTAL RESPONSE TO IE BULLETIN 83-03

Dear Mr. O'Reilly:

A review of Carolina Power & Light Company's responses to IE Bulletin 83-03 dated June 8, 1983 (Serial No. BSEP/83-1627), and December 13, 1983 (Serial No. BSEP/83-3890), revealed a potential conflict in the periodicity of the committed valve inspection program. To avoid confusion in the future, CP&L commits to inspecting the valve internals to verify operability on a two-valve-per-year periodicity (one diesel). This inspection has already been incorporated in plant procedure MI-10-521I.

Very truly yours,

P. W. Howe, Vice President
Brunswick Nuclear Project

RMP/pms/LETPS1

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8402140467 840116
PDR ADDCK 05000324
PDR
Q

JEH 1/6