

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-8526

Mailing Address:
Post Office Box 4545
Atlanta, Georgia 30302

L. T. Gucwa
Manager Nuclear Engineering
and Chief Nuclear Engineer



NED-84-046

February 6, 1984

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC DOCKETS 50-321, 50-366
OPERATING LICENSES DPR-57, NPF-5
EDWIN I. HATCH NUCLEAR PLANT UNITS 1, 2
WITHDRAWAL OF REQUEST FOR TECHNICAL SPECIFICATION CHANGE
ALLOWING PLANT OPERATION WITHOUT FORCED RECIRCULATION FLOW

Gentlemen:

By letter dated November 28, 1983, Georgia Power Company proposed an amendment to the Plant Hatch Units 1 and 2 Technical Specifications (Appendix A to the Operating Licenses). This amendment would have changed requirements to allow plant operations for up to 30 continuous minutes without forced recirculation flow. This proposal is hereby withdrawn from further consideration by the NRC at this time.

Very truly yours:

William S. Burr / for

L. T. Gucwa
Chief Nuclear Engineer

CBS

xc: H. C. Nix, Jr.
Senior Resident Inspector
J. P. O'Reilly, (NRC-Region II)

A001
1/0

8402150197 840206
PDR ADOCK 05000321
P PDR