

Appendix A

Notice of Violation

Vermont Yankee Nuclear Power Corporation
Vermont Yankee Nuclear Power Station

Docket No. 50-271
License No. DPR-28

As a result of the inspection conducted on December 6-9, 1983, and in accordance with the NRC Enforcement Policy, (10CFR2, Appendix C), published in the Federal Register on March 9, 1982, (47FR9987), the following violation was identified:

Technical Specification 6.5B requires, in part, that radiation control procedures be prepared, approved and maintained and made available to all station personnel. These procedures shall be consistent with 10 CFR Part 20, and reviewed and approved by the Plant Manager, or his designee, and the Manager of Operations.

Contrary to the above radiation control procedures, necessary to comply with 10 CFR Part 20, for the van-mounted personnel whole body counting system were not reviewed and approved by the Plant Manager, or his designee, and the Manager of Operations. The system was used without the required procedures from September 7, 1983 through December 9, 1983.

This is a Severity Level V violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, Vermont Yankee Nuclear Power Corporation is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for this violation: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

8402150242 840131
PDR ADOCK 05000271
Q PDR