

February 24, 1995

Mr. Jerry W. Yelverton  
Vice President, Operations AND  
Entergy Operations, Inc.  
Route 3 Box 137G  
Russellville, Arkansas 72801

SUBJECT: BULLETIN 90-1, SUPPLEMENT 1 - RESPONSE FROM ARKANSAS NUCLEAR ONE,  
UNITS 1 AND 2 (TAC NOS. M85352 AND M85353)

Dear Mr. Yelverton:

We have completed our review of your responses to NRC Bulletin 90-01, Supplement 1. The bulletin was related to oil leakage from Rosemount pressure transmitters. Your responses dated March 5, 1993, and April 15 and June 22, 1994, were reviewed by the Idaho National Engineering Laboratory (INEL) under a contract issued by NRC. The NRC safety evaluation (Enclosure 1) endorsing the INEL evaluation (Enclosure 2) is enclosed. The evaluation concludes that the responses from Arkansas Nuclear One, Units 1 and 2 are complete.

Sincerely,

ORIGINAL SIGNED BY:

George Kalman, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-313 and 50-368

Enclosures: 1. NRC Safety Evaluation  
2. INEL Evaluation

cc w/encls: See next page

DISTRIBUTION:

Docket File	PUBLIC	PDIV-1 R/F
JRoe	WBeckner	PNoonan
GKalman	OGC	ACRS (4)
ABeach, RIV		

G:\VWPKN\AR85353.LTR

OFFICE	PDIV-1/LA	PDIV-1/PM
NAME	PNoonan	GKalman:mk
DATE	2/24/95	2/14/95
COPY	YES/NO	YES/NO

OFFICIAL RECORD COPY

200056

9503010090 950224  
PDR ADOCK 05000313  
Q PDR

NRC FILE CENTER COPY

DFD1



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

February 24, 1995

Mr. Jerry W. Yelverton  
Vice President, Operations AND  
Entergy Operations, Inc.  
Route 3 Box 137G  
Russellville, Arkansas 72801

SUBJECT: BULLETIN 90-1, SUPPLEMENT 1 - RESPONSE FROM ARKANSAS NUCLEAR ONE,  
UNITS 1 AND 2 (TAC NOS. M85352 AND M85353)

Dear Mr. Yelverton:

We have completed our review of your responses to NRC Bulletin 90-01, Supplement 1. The bulletin was related to oil leakage from Rosemount pressure transmitters. Your responses dated March 5, 1993, and April 15 and June 22, 1994, were reviewed by the Idaho National Engineering Laboratory (INEL) under a contract issued by NRC. The NRC safety evaluation (Enclosure 1) endorsing the INEL evaluation (Enclosure 2) is enclosed. The evaluation concludes that the responses from Arkansas Nuclear One, Units 1 and 2 are complete.

Sincerely,

A handwritten signature in black ink, reading "George Kalman", is positioned above the typed name and title.

George Kalman, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-313 and 50-368

Enclosures: 1. NRC Safety Evaluation  
2. INEL Evaluation

cc w/encls: See next page

Mr. Jerry W. Yelverton  
Entergy Operations, Inc.

Arkansas Nuclear One, Units 1 & 2

cc w/encl:

Mr. Harry W. Keiser, Executive Vice  
President & Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286

Mr. Jerrold G. Dewease  
Vice President, Operations Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286

Ms. Greta Dicus, Director  
Division of Radiation Control  
and Emergency Management  
Arkansas Department of Health  
4815 West Markham Street  
Little Rock, Arkansas 72205-3867

Mr. Robert B. McGehee  
Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, Mississippi 39205

Mr. Nicholas S. Reynolds  
Winston & Strawn  
1400 L Street, N.W.  
Washington, D.C. 20005-3502

Admiral Kinnaird R. McKee, USN (Ret)  
214 South Morris Street  
Oxford, Maryland 21654

Mr. Robert B. Borsum  
Licensing Representative  
B&W Nuclear Technologies  
1700 Rockville Pike, Suite 525  
Rockville, Maryland 20852

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 310  
London, Arkansas 72847

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Honorable C. Doug Lunningham  
County Judge of Pope County  
Pope County Courthouse  
Russellville, Arkansas 72801