

Nuclear Division
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 456-6000

September 22, 1983

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-6G
Revision 1 to Change Request No. 86 to Operating License

Gentlemen:

Enclosed are three (3) originals and thirty-seven (37) copies of Revision 1 to our Application No. 86 for Amendment to Operating License DPR-6G. Revision 1 involves clarification of the coincidence levels for the P-7, P-8, P-9 and P-10 permissives previously submitted by Technical Specification Change Request No. 86, dated July 14, 1983.

The P-7, power range neutron flux coincidence has been revised from 2/4 to 3/4 and the turbine impulse chamber pressure coincidence has been revised from 1/2 to 2/2. The P-8, power range neutron flux coincidence has been revised from 2/4 to 3/4. The P-9, power range neutron flux coincidence has been revised from 2/4 to 3/4. The P-10, power range neutron flux coincidence has been revised from 3/4 to 2/4.

The P-7, P-8 and P-9 permissives are defined by the coincidence levels required to automatically block reactor trips when below the setpoint. The P-10 permissive is defined by the coincidence level that allows the manual block of reactor trip when above the setpoint.

These changes are consistent with the system logics and the Updated Final Safety Analysis Report (UFSAR) and more clearly define the coincidence required for the applicable permissive. No physical change is being made to any plant equipment as a result of the above changes. The changes are being made to conform to the UFSAR format.

We have determined that these changes provide clarification of an existing submittal, therefore, no change to the previous safety evaluation is required and no fee is required.

Pool


8309290152 830922
PDR ADOCK 05000334
P PDR

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Revision 1 to Change Request No. 86 to Operating License
Page 2

The OSC and ORC have reviewed and approved this revision to Technical Specification Change Request No. 86.

Therefore, page 3/4 3-7 should be removed from our initial application and the enclosed page should be inserted.

Very truly yours,


J. J. Carey
Vice President, Nuclear

Enclosure

cc: Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

Mr. W. M. Troskoski, Resident Inspector
U. S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555