**Commonwealth Edison** One First National Plaza, Chicago, Illinois Address Reply to: Post Office Box 767 Chicago, Illinois 60690

January 31, 1984

	Name of the Owner	
PRIN	CIPAL STAFF	1
A	DPRP	pug+1
D/RA	DE L'he	1'
A/RA	DRMSP	1
RC	DRMA	
PAO	SCS	1
SGA	ML	1
NF	File	3
	the second se	

S.

Mr. James G. Keppler Regional Administrator U.S. Nuclear Regulatory Commission Region III 799 Roosevelt Road Glen Ellyn, IL 60137

> Subject: LaSalle County Station Units 1 and 2 Response to Confirmatory Action Letter dated November 28, 1983 Item E, Qualification Plan NRC Docket Nos. 50-373 and 50-374

Reference (a): J. G. Keppler letter to Cordell Reed dated November 28, 1983.

Dear Mr. Keppler:

As required by the referenced confirmatory action letter, this letter provides our response to Item E, Plan and schedule to obtain a rully qualified soft seat for the inboard feedwater check valves, B21-F010 A&B.

A material supplier and literature search was conducted for alternate materials to replace the presently used EPR. Two alternative materials are being considered for testing: Kalrez, from Dupont, and Aflas from Parker Scal.

These materials, and the presently used EPR compound, will be subjected to the following conditions:

1.	Temperature	420° Continuous, all water environment. 450°, for 4 hours, all water environment	
2.	Pressure	1000 PSIG	
3.	Radiation	2.6×10 <sup>7</sup> Rads Gamma	
4.	Time	Sufficient Duration to measurably effect physical properties.	
5.	Compression	0,10,20, 30% of original material thicknes	

Upon completion of testing, the physical condition of the samples will be evaluated by measuring the change in the following physical parameters. These evaluations will be based on various ASTM standards. A degradation of physical properties that results in a failure of a seal to pass an equivalent leak rate test, will be FEB 3 1984 considered a failure of the material.

8402220416 840217 PDR ADDCK 05000373 PDR G

## January 31, 1984

## J. G. Keppler

- 2 -

Compression set	ASTM	D3985
Hardness	ASTM	D224
Tensile Strength	ASTM	D412
Modulus of Elasticity	ASTM	D797
Tear Strenght	ASTM	D624
Padiation Damage	NA	

Testing is expected to take approximately 10 months.

When a physically acceptable material has been selected, the seal design will be reviewed to determine if any changes would be necessary to the original design due to a material change. This should be completed in two weeks. A design change would result in a new mold being fabricated. This is estimated to take six weeks.

Production and delivery of new seals is estimated to take six weeks. Installation could then be done during a planned outage of appropriate duration, but no later than startup following the first refueling outage for each respective unit.

A detailed test plan and procedures will be developed in conjunction with a testing consultant. To date we have discussed the above plan with Anchor/Darling and Farwell & Hendricks, Inc.

To the best of my knowledge and belief the statements contained herein and in the attachment are true and correct. In some respects these statements are not based on my personal knowledge but upon information furnished by other Commonwealth Edison and contractor employees. Such information has been reviewed in accordance with Company practice and I believe it to be reliable.

If there are any further questions regarding this matter, please contact this office.

Very truly yours,

CW Schorde 1/31/84

C. W. Schroeder Nuclear Licensing Administrator

lm

cc: NRC Resident Inspector - LSCS