PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-III-83 -91 Date October 3, 1983 This preliminary notification constitutes EARLY notice of events of POSSIBLE national security or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date. Facility: Wisconsin Electric Power Licensee Emergency Classification: Point Beach Nuclear Station Unit 1 Notification of an Unusual Event Alert Two Rivers, WI 54241 Docket No. 50-266 Site Area Emergency General Emergency xx Not Applicable Subject: SIX MONTH OUTAGE TO REPLACE STEAM GENERATORS Beginning Saturday, October 1, 1983, the licensee commenced a six-month outage for refueling, routine maintenance and replacement of the unit's two steam generators. The licensee received authorization to replace the steam generators from the Office of Nuclear Reactor Regulation on September 30, 1983. Approximately 14 per cent of the 6500 tubes in the two generators have either been plugged or removed from service because of corrosion. As a result, the unit has been operating at only 75 per cent of its 495,000 kilowatt capacity. Unit 2, which is operating at 100 per cent power, recently completed a tube sleeving program. It has not been determined at this time whether Unit 2 also will need steam generator replacement. The licensee notified the news media by telephone of the outage and steam generator replacement on September 30, 1983. A formal news release is being prepared by the licensee and is expected to be issued October 3, 1983. Region III (Chicago) will respond to : inquiries. The State of Wisconsin will be notified. The Resident Inspector was notified of this event on September 30, 1983. This information is current as of 12:30 p.m. October 3, 1983. CONTACT: DISTRIBUTION: H. St. 2:48 MNBB Phillips o Willste c Chairman Palladino NMSS EDO Comm. Gilinsky OIA RES PA Comm. Roberts AEOD MPA Comm. Asselstine ELD MAIL: INPO 3:13 Comm. Bernthal ADM: DMB WSAC 3' SECY DOT: Trans Only ACRS Applicable Resident Site 3:35 CA Regions I 2:50, II 2:57, IV 2:51 V 3:03 Licensee (Corporate Office) 3:50 J PDR 8310060264 831003

PNO-III-83-091 PDR