

DUKE POWER COMPANY
PROCEDURE PREPARATION
PROCESS RECORD

(1) ID No: CP/O/B/8800/05
Change(s) 0 to
2 Incorporated

- (2) STATION: Catawba
- (3) PROCEDURE TITLE: Chemistry Procedure for the Recording and Management
of Data
- (4) PREPARED BY: R L Renter DATE: 11/1/83
- (5) REVIEWED BY: LA Evans DATE: 11-1-83
Cross-Disciplinary Review By: N/B. TOS
- (6) TEMPORARY APPROVAL (IF NECESSARY):
By: _____ (SRO) Date: _____
By: _____ Date: _____
- (7) APPROVED BY: M.S. Tuckman Date: 11/7/83
- (8) MISCELLANEOUS:
Reviewed/Approved By: _____ Date: _____
Reviewed/Approved By: _____ Date: _____

MASTER FILE

DUKE POWER COMPANY
NUCLEAR SAFETY EVALUATION CHECK LIST

(1) STATION: Catawba UNIT: 1 2 3
OTHER: Shared
(2) CHECK LIST APPLICABLE TO: CP/O/B/8800/05

(3) SAFETY EVALUATION - PART A

The item to which this evaluation is applicable represents:

Yes No ✓ A change to the station or procedures as described in the FSAR
or a test or experiment not described in the FSAR?

If the answer to the above is "Yes", attach a detailed description of the item
being evaluated and an identification of the affected section(s) of the FSAR.

(4) SAFETY EVALUATION - PART B

Yes No ✓ Will this item require a change to the station Technical
Specifications?

If the answer to the above is "Yes," identify the specification(s) affected
and/or attach the applicable pages(s) with the change(s) indicated.

(5) SAFETY EVALUATION - PART C

As a result of the item to which this evaluation is applicable:

Yes No ✓ Will the probability of an accident previously evaluated
in the FSAR be increased?
Yes No ✓ Will the consequences of an accident previously evaluated
in the FSAR be increased?
Yes No ✓ May the possibility of an accident which is different
than any already evaluated in the FSAR be created?
Yes No ✓ Will the probability of a malfunction of equipment
important to safety previously evaluated in the FSAR
be increased?
Yes No ✓ Will the consequences of a malfunction of equipment
important to safety previously evaluated in the FSAR
be increased?
Yes No ✓ May the possibility of malfunction of equipment
important to safety different than any already evaluated
in the FSAR be created?
Yes No ✓ Will the margin of safety as defined in the bases to any
Technical Specification be reduced?

If the answer to any of the preceding is "Yes", an unreviewed safety
question is involved. Justify the conclusion that an unreviewed safety
question is or is not involved. Attach additional pages as necessary.

(6) PREPARED BY: R. L. Painter DATE: 11/1/83

(7) REVIEWED BY: FD Evans DATE: 11-1-83

(8) Page 1 of 1

DUKE POWER COMPANY

ALARA EVALUATION CHECKLIST

(1) Station Catawba Unit: 1 2 3

Other: Shared

(2) Checklist Applicable to: CP/O/B/8800/05

(3) ALARA Evaluation

Check those items below which were considered applicable during the preparation and review of this document.

Flushing and draining were used to minimize source - strength and contamination levels prior to performing an operation.

_____ Permanent and/or movable shielding was specified for reduction of levels.

Use of permanent or temporary local exhaust ventilation systems was used for control of airborne contamination.

Operation was designed to be completed with the least practicable time spent in the radiation field.

_____ Appropriate tools and equipment were specified for the operation to be performed.

_____ The operation was designed considering the minimum number of people necessary for safe job completion.

Remote handling equipment and other special tools were specified to reduce external dose.

Contamination - control techniques were specified.

_____ The operation was designed to be conducted in areas of as low an exposure as practicable.

Additional ALARA considerations were:

✓ ALARA Principles were not considered since the procedure did not involve work in a radiation area.

(5) Prepared by: A. L. Kinton Date 11/1/93

(6) Reviewed by: W. Evans Date 11-1-83

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
CHEMISTRY PROCEDURE FOR THE
RECORDING AND MANAGEMENT OF DATA

1.0 DISCUSSION

The purpose of this procedure is to outline steps taken by the Chemistry section in sampling, recording of analytical results, and transmittance of data to various members of the Catawba Nuclear Station organization during normal operation.

2.0 APPARATUS

Not applicable

3.0 REAGENTS

Not applicable

4.0 PROCEDURE

4.1 Routine Sampling Schedule

The Power Chemistry and Radwaste Chemistry units of the Chemistry section will collect, analyze, and record samples according to their jurisdictional responsibilities. Enclosures 6.1 through 6.9 describe the sampling schedules for Power Chemistry and Radwaste Chemistry. Frequency of sampling is determined by system operation, as well as State, Federal, and Company requirements.

4.2 Normal Operating Sampling Specifications

Enclosures 6.10 through 6.18 give the normal operating specifications for Power Chemistry and Radwaste Chemistry. Samples are to be analyzed using the appropriate chemistry analytical procedure.

4.3 Interlaboratory Sample Processing

Requests for sample analysis may be made to the Chemistry section whenever needed by filling out a Sample Requisition Form (Enclosure 6.19), and submitting it to the appropriate lab. Sample requests originating from within the Chemistry section for analysis to be performed by another unit of the Chemistry section must be accompanied by a Sample Requisition Form. Requests for radiochemical counting are made by submitting a Sample Requisition Form to the Health Physics Count Room. The form is filled out by the requesting lab and submitted to the appropriate lab along with the sample.

The lab performing the analysis will record the data in the appropriate space on the form and return the original copy to the requesting lab. The requesting lab will record the analysis in their Sample Data Legal Log Book. This is depicted schematically in Enclosure 6.20.

4.4 Sample Documentation

The Sample Data Legal Log Book will be the basic document for recording all samples taken and the results of the analysis performed. Each lab will maintain its own Legal Log Book for samples collected by that particular group. Each sample is given a number which consists of the last digit of the present year, the page number, and the line number that the sample is recorded on, in that respective order. An example would be sample number 2608, where 2 is the last digit in 1982, 6 is the log book page the sample is recorded on, and 08 is the line number the sample is recorded on. The results of analysis, date, and time of sample collection are recorded in the appropriate columns along with the technicians initials who performed the analysis. All entries will be made in black ink; the use of "liquid paper" to white out incorrect entries is not permitted. Instead, a single line will be drawn through the incorrect entry and initialed. The correct entry is then written above the incorrect entry. Enclosures 6.21 through 6.26 are copies of a page from each Legal Log Book.

4.5 Document Control

The Station Chemist shall have the responsibility of administratively maintaining the legal ledger and submitting it to the Master File. Copies of chemical and radiochemical records are kept on Master File for a minimum of six (6) years. Copies of records of radioactive releases and waste disposal are kept on Master File for the life of the station.

5.0 REFERENCES

- 5.1 Oconee Nuclear Station Chemistry Procedures
- 5.2 McGuire Nuclear Station Chemistry Procedures
- 5.3 System Power Chemistry Manual
- 5.4 Catawba Nuclear Station Directives Manual, Volume I
- 5.5 Westinghouse Chemistry Criteria and Specifications
- 5.6 NPDES Permit #SC0004278

6.0 ENCLOSURES

- 6.1 Primary Sampling and Analysis Schedule
- 6.2 Oil Sampling and Analysis Schedule
- 6.3 Secondary Sampling and Analysis Schedule - Hot Standby

- 6.4 Water Treatment Room Sampling and Analysis Schedule
- 6.5 HVAC Sampling and Analysis Schedule
- 6.6 Steam Generator Wet-Layup Sampling Schedule
- 6.7 Environmental Sampling and Analysis Schedule
- 6.8 Hypochlorite Generator Sampling and Analysis Schedule
- 6.9 Radwaste Sampling and Analysis Schedule
- 6.10 Primary Chemistry Operating Specifications
- 6.11 Oil Analysis Operating Specifications
- 6.12 Secondary Chemistry Operating Specifications - Hot Standby
- 6.13 Water Treatment Room Operating Specifications
- 6.14 HVAC Operating Specifications
- 6.15 Steam Generator Wet-Layup Specifications
- 6.16 Environmental Chemistry Operating Specifications
- 6.17 Hypochlorite Generator Operating Specifications
- 6.18 Radwaste Chemistry Operating Specifications
- 6.19 Sample Requisition Form
- 6.20 Interlaboratory Sample Processing
- 6.21 Primary Chemistry Legal Log Book
- 6.22 Oil Analysis Legal Log Book
- 6.23 Secondary Chemistry Legal Log Book
- 6.24 HVAC Legal Log Book
- 6.25 Environmental Chemistry Legal Log Book
- 6.26 Radwaste Chemistry Legal Log Book

PRIMARY SAMPLING AND ANALYSIS SCHEDULE
CT/O/B/BA00/05
ENCLOSURE 6.1

Page 2 of 2

SYSTEM	SAMPLE	CL ⁻ ppb	Fe ²⁺ ppb	O ₂ ppm	Boron ppb	pH @ 25°C	Cond. umho/cm @ 25°C	Susp. Sol. ppb	Turbidity NTU	Nitrogen cc/kg	Hydrogen cc/kg	Fluoride ucl/ml	Gross B ucl/ml	D.F. 131 ucl/ml	Y Isotopic Liq	Y Isotopic Crud	H ₂ ucl/ml	Gross Activity	Glycol %	SiO ₂ ppb	Mg/ppb	Ca ppb	Al ppb	Inhibitor ppm	BZT ppm	Bacteria col/ml	Chromates ppm	Phosphates ppm	OTHERS
BR	Desmineralizer Outlet	M	M		D	D																							
FW	FWST	M	M		2/H (T)	M		M																					
KF	Spent Fuel Pool	M	M		3/M	M																							
KF	SFP IX Outlet	M	M																										
NF	Glycol Mix Tank					2/H		2/H												2/H									
NF	Glycol Pump Disch					2/H		2/H												2/H									
NF	Ice Making Solution Mix Tank				N/S	N/S																							
NF	Ice Condenser				Q (T)	Q (T)																							
KC	Component Cooling	M	M			M		M																					
NR	Chiller Hx Shell	M	M			M		M																					
FD	D/C Eng. Cool. Water					2/H																							
WZ	Groundwater Dring. Sump																												

(T)-Denotes Tech. Spec. Item; frequency given may be more conservative than actual spec.
 *Also, within 6 hrs. after a solution volume increase of ≥ 12 Tank Volume
 **Also, within 6 hrs. after vol. increase of 2130.3 gal.
 ***-Total Dissolved Gas - 1/yr.
 ****-Tech. Spec. Item during refueling
 *****-Increase frequency if there has been a large change in inhibitor concentration.
 N/S-Not scheduled.
 # -when in service

OIL SAMPLING AND ANALYSIS SCHEDULE
CP/0/B/R800/05
ENCLOSURE 6.2

Table 1 - Analysis at Station

System	Sample	Viscosity	Heat. #	% Water	Water and Sediment	Specific Gravity	Particle Count				
LT	Main Turbine Lube Oil	M	M		M						
LF	FMT (A&B) Lube Oil	M	M		M		M	M	M	M	M
NC	NC Pump Motor Oil (A,B,C,D)	SD	SD		SD		M	M	M	M	M
NC	NC Pump Motor Oil (Spare)		2/y		2/y						
FD	Fuel Oil Tank Truck	FTA (T)			PTA (T)	PTA (T)	See Table 2 also; no analysis necessary if fuel is for AD diesel only.				
	Fuel Oil Storage Tanks (A1,A2,B1,B2)						See Table 2				
	Lube Oil Tank Truck	FTA ***	Each Load ***	Each Load ***							
LD	Clean Lube Oil Storage Tank	M	M	M							
ID	Lube Oil Sump Tank	M	M	M							
AD	Fuel Oil Storage Tank	Q			Q						
AD	Oil Fan	Q	Q	Q							

Table 2 - Analysis by Consultant

System	Sample	Viscosity	Distillation Temp	Water and Sediment	Carbon Residue on 10% Residue	Copper Strip Corrosion	Flash Point	Cloud Point	Pour Point	Ash	Sulfur	Cetane Number	Insoluble	Specific Gravity
FD	Fuel Oil Tank Truck		* (T)		* (T)	* (T)	* (T)	* (T)	* (T)	* (T)	* (T)	* (T)	* (T)	
	Fuel Oil Storage Tanks (A1,A2,B1,B2)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)	BM * (T)

BM - Bi-monthly Y - Yearly PTA - Prior to Addition * - Must be verified within 2 weeks of sampling
 M - Monthly SD - Shutdown T - Tech Spec ** - Must be verified within 1 week of sampling
 Q - Quarterly *** - Viscosity must be within specification prior to addition to the tank; other analysis may be done later

SECONDARY CHEMISTRY SAMPLING AND ANALYSIS SCHEDULE -
HOT STANDBY
CY/O/B/800/05
ENCLOSURE 6.3

	pH	Cond umane	Cond. Cat.	O ₂ ppb	Na ppb	N ₂ H ₄ ppb	Cl ppb	Su ₂ S. ppb	SiO ₂ ppb	Tox. Fe ppb	Cu ppb	Pb ppb	NH ₃ ppb	
Steam Generator Blowdown A-D	S		C	S	C		S	S	S	3/M	3/C		3/C	
Main Steam A-D	S	S			D*				P					
Hotwell Pump Discharge	S	C	C	C	C		D	S	S	3/M	3/M			
Pollisher (Main) Influent	D	D	C					S						
Pollisher (Main) Effluent	S		C		C			S	S	3/2	3/M			
Pollisher Cell Effluent A-E			C											
Main Feedwater	S	S	C	C	S	C	D	S	S	3/M	3/M		3/M	
Upper Surge Tank	D	D						D						
Condensate Storage Tank	D	D							D					

S = 1/Shift
D = 1/day

C = Continuous
3/M = 3/week

*To be run on AA

WATER TREATMENT ROOM SAMPLING AND ANALYSIS SCHEDULE
 CP/O/R/8800/05
 ENCLOSURE 6.4

Page 1 of 2

Sample	Turb.	Cond.	Mill Susp. Solids	SiO ₂	Cl ⁻	F ⁻	Free Cl ₂	TSS	Color	pH	TOC	Total Coliform	O ₂
Raw Water	D	D		W				D	D	D		D*	
YF "A" Eff.	D	D		W			D	D		D			
YF "B" EFF.	D	D		W			D	D		D			
Finished YD	D						D		D	D		D*	
YM Carbon Filters Inf.											W*		
YM Carbon Filter "A" Eff.							W				W*		
YM Carbon Filter "B" Eff.							W				W*		
YM Demin. "A" Eff.		D	D	S	D	D				D			
YM Demin. "B" Eff.		D	D	S	D	D				D			
YD Carbon Filter Inf.											W*		
YD Carbon Filter "A" Eff.							W				W*		
YD Carbon Filter "B" Eff.							W				W*		

Page 2 of 2

(a) - Dissolved Oxygen monitored as operation requires

[illegible]

ENCLOSURE 6.5
CP/O/B/8800/C5
HVAC SAMPLING AND ANALYSIS SCHEDULE

SAMPLE	pH	CONDUCTIVITY	TURBIDITY	INHIBITOR	BACTERIA	BZT	
YB, YC, YH (Admin. Bldg.) YJ, YK, YR, YV, YW, YN	1/W	1/W	1/W	1/W	1/M		
KR	1/W	1/W	1/W	1/W	1/M	1/M	

SAMPLE	CONDUCTIVITY	GLYCOL	SUSPENDED SOLIDS				
YH (Service Turbine, and Auxiliary Bldg. Loops)		2/M	2/M				

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
CHEMISTRY PROCEDURE FOR THE
RECORDING AND MANAGEMENT OF DATA
CP/O/B/8800/05
ENCLOSURE 6.6

Steam Generator Wet Lay-Up Sampling Schedule

1. Generators are to be sampled and all analysis run three (3) times per week until stable, then once (1) a week.

ENVIRONMENTAL SAMPLING AND ANALYSIS SCHEDULE
CP/O/R/8800/05
ENCLOSURE 6.7

PL	Abiotic Temp. °C	Flow MGD	pH at 25°C	Spec Cond. µmhos/cm	Turb NTU	Total Cl ₂ mg/L	Free Cl ₂ mg/L	DO ppm	BOD ppm	TSS ppm	Volatiles Solids c/o	Alk ppm CaCO ₃	Acidity ppm CaCO ₃	Soluble Silica ppm	Oil and Grease ppm	Focal Coliforms/100 ml	Boron ppm	Hydrazine ppm	Sediment Solids mg/L	Ca & Mg ppm
Intake (Lake Wythe)																				
Discharge																				
MC																				
Initial Holdup Pond																				
Settling Basin A																				
Settling Basin B																				
Final Holdup Pond																				
UMP in 5's Out Pit																				
System Discharge																				
MF																				
Influent																				
Cell A																				
Cell B																				
Cell C																				
Cell D																				
Effluent Polishing Basin																				
System Discharge																				
MC																				
Unit 1 Cooling Towers																				

*Off-site Analysis

ENCLOSURE 6.8
CP/O/B/8800/05

To Be Added Later

ENCLOSURE 6.9
CP/O/B/8800/05

To Be Added Later

PRIMARY CHEMISTRY OPERATING SPECIFICATIONS

CP/O/B/1800/05

ENCLOSURE 6.10

Page 1 of 3

SYSTEM	SAMPLE	CL ⁻ ppb	Fe ³⁺ ppb	O ₂ ppb	Boron ppm	pH @ 25°C	Cond. umho/cm @ 25°C	Susp. Sol. ppb	Turbidity NTU	Nitrogen cc/kg	Hydrogen cc/kg	Piston Gases ucl/ml	Gross B ucl/ml	D. E. I. 131 ucl/ml	γ Isotopic Liq.	γ Isotopic Crud	H ₂ ucl/ml	Gross Activity	St ⁹⁰	SiO ₂ ppb	Hg ppb	Ca ppb	Al ppb	Fe ppb	Li ppm	OTHERS
NC	Loop "A"									N/S	25-50															
NC	Pze - Liquid	≤150	≤150	F	A	4.2-10.5	N/S						N/S												See Page 3	
NC	Pze - Gas											N/S														
NC	PRT - Liquid			≤100																						
NC	PRT - Gas			<4.52						N/S	N/S	N/S														
NC	HCPT - Gas			<4.52																						
NV	Letdown Rx Outlet	≤150 (T)	≤150 (T)	F	0-2000 (T)	4.2-10.5	N/S	≤100					N/S	≤1.0 (T)	N/S		N/S		N/S		≤200	G	≤30		See Page 3	
NV	Mixed Bed Outlet	B	B										B		B											
NV	VCT - Gas			C						N/S	N/S	N/S														
NV	Boric Acid Tanks	≤150	≤150		7000-7700 (T)	N/S	N/S	≤200					N/S								≤600	≤5	≤10	≤50	≤150	
NV	Boric Acid Batch Tanks				7000-7700																					
NI	Cold Leg Accumulators	≤150	≤150		1900-2100 (T)																					
NI	UHI Accumulator	≤150	≤150		1900-2100 (T)					D (T)																
ND	Decay Heat Removal	(T) ≤150	(T) ≤150	F	N/S	4.2-10.5	N/S	≤200					N/S								≤200	≤10	≤20	≤60	See Page 3	
NB	RMIST	≤50	≤50	≤100		6.0-8.0	≤2.0	≤5					≤0.005				≤1.0			≤50	≤2	≤2	≤15			

N/S-No Spec.

(T)-denotes Tech. Spec. Item; value given may be lower than actual spec.

A -within 50 ppm of HV Letdown Rx Outlet boron concentration

B - ≤ 1X Inlet

C - < minimum detectable amount

D - < 80 Std. Cu. Ft. Total dissolved gas/1800 cu. ft. H₂O

E - Tech. Spec. Item during refueling; ≥ 2000

F - H₂ Spec. @ < 180°F; ≤ 100 between 180°F and 250°F

G - Ca ≤ 50 and Mg ≤ 5 @ ≤ 85% power

Ca and Mg combined ≤ 5 @ > 85% power

PRIMARY CHEMISTRY OPERATING SPECIFICATIONS
CP/O/B/8809/05
ENCLOSURE 6.10


Page 2 of 3

SYSTEM	SAMPLE	CL ₂ ppb	CO ₂ ppb	Boron ppb	pH @ 25°C	Cond. umho/cm @ 25°C	Snap. Sol. ppb	Turbidity NTU	Nitrogen cc/kg	Hydrogen cc/kg	Fission Gases uCi/ml	Gross B uCi/ml	D.E. I ₁₃₁ uCi/ml	γ Isotopic Liq	γ Isotopic Crud	H ₂ uCi/ml	Gross Activity	Glycol %	SL ₂ ppb	Hg/ppb	Ca ppb	Al ppb	Inhibitor ppm	BZT ppm	Bacteria col/ml	Chromates ppm	Phosphates ppm	OTHERS
NR	Desintegrator Outlet	<150	<150	N/S	N/S							N/S																
FW	FWST	<150	<150	2000-2100 (T)	4.0-4.7		<200					N/S		NS					<200	<10	<20	<60						
KF	Spent Fuel Pool	<150	<150	>2000	4.0-4.7			<10				N/S		B						<50	<100	<300						
KF	SFP IX Outlet	B	B									N/S																
NF	Glycol Mix Tank						N/S																					
NF	Glycol Pump Disch						N/S																					
NF	Ice Making Solution Mix Tank			1950-2250 (T)	9.0-9.5																							
NF	Ice Condenser			>1800 (T)	9.0-9.5 (T)																							
KC	Component Cooling	<1000	<1000		8.2-10	<5000		<30				N/S												2000-3000	20-80	20-80		
NR	Chiller Hx Shell	<1000	<1000		8.2-10	<5000		<30				N/S												2000-3000	20-80	20-80		
ED	D/G Eng. Cool. Water				8.2-9.7																					700-1700	100-300	
MZ	Groundwater Drng. Sump											C																

N/S - No Spec.
(T) - denotes Tech. Spec. Item; value given may be lower than actual spec.
A - within 50 ppm of NV letdown Hx Outlet boron concentration
B - < IX inlet
C - < minimum detectable amount
D - < 80 Std. Cu. Ft. Total dissolved gas/1800 cu. ft. H₂O
E - Tech. Spec. Item during refueling; ≥ 2000
F - No Spec. @ <180°F; ≤100 between 180°F and 250°F
G - Ca ≤ 5.10 and Mg ≤ 5 @ 58% power
Ca and Mg combined ≤ 5 @ >85% power

RECOMMENDED LI CONCENTRATION RANGE AS A FUNCTION OF BORON CONCENTRATION

FIGURE 1



OIL ANALYSIS OPERATING SPECIFICATIONS
CP/O/N/8800/05
ENCLOSURE 6.11

Table 1 - Analysis at Station

System	Sample	Viscosity Sus @ 100 F	Neut. # mg KOH/gm	Water v/v%	Water and Sediment v/v%	Specific Gravity	Particle Count				
							6-11 μ	12-20 μ	21-60 μ	61-105 μ	>250 μ
LT	Main Turbine Lube Oil	140-170	<0.2		<0.2		210,000	6500	2370	112	18
LF	PWPT (A & B) Lube Oil	140-170	<0.2		<0.2		210,000	6500	2370	112	18
NC	RC Pump Motor Oil (A, B, C, D)	143-175	<0.4*		nil						
NC	RC Pump Motor Oil (Spare)		<0.4*		nil						
	Fuel Oil Tank Truck	(T) 32.6-40.1			(T) ≤0.05	(T) 0.83-0.89					
FD	Fuel Oil Storage Tanks (A1, A2, B1, B2)					See Table 2 also.					
	Lube Oil Tank Truck	649-812	later	≤0.1							
LD	Clean Lube Oil Storage Tank	649-812	later	≤0.1							
LD	Lube Oil Soap Tank	649-812	later	≤0.1							
AD	Fuel Oil Storage Tank	30-45			50.1						
AD	Oil Pan	459-702			≤0.1						

Table 2 - Analysis by Consultant

System	Sample	Viscosity Sus @ 100 F		Distillation Temp. (°C) 90% Point		Water and Sediment v/v%	Carbon Residue on 102 Residue %	Copper Strip Corrosion	Flash Point °C (°F)	Cloud Point °C (°F)	Pour Point °C (°F)	Ash w/w%	Sulfur w/w%	Cetane Number	Insolubles mg/100ml	Specific Gravity	
		Min	Max	Min	Max											Min	Max
	Fuel Oil Tank Truck			(T) 283.5(40)	(T) 308.6(40)		(T) ≤0.35	(T) ≤3	(T) ≤52(125)	(T) ≤24	(T) ≤13	(T) ≤0.01	(T) ≤0.50	(T) ≥40	(T) ≤2	(T) 0.83	(T) 0.89
FD	Fuel Oil Storage Tanks (A1, A2, B1, B2)	(T) 32.6	(T) 40.1	(T) 283.5(40)	(T) 308.6(40)	(T) ≤0.05	(T) ≤0.35	(T) ≤3	(T) ≤52(125)	(T) ≤24	(T) ≤13	(T) ≤0.01	(T) ≤0.50	(T) ≥40	(T) ≤2	(T) 0.83	(T) 0.89

T - Tech Spec

* - Difference from new oil

SECONDARY CHEMISTRY OPERATING SPECIFICATIONS -
 HOT STANDBY
 CP/O/R/BROO/05
 ENCLOSURE 6.12

	pH	Cond. umho	Cat. Cond.	O ₂ ppb	Na ppb	N ₂ H ₄ ppb	Cl ppb	Sua. Sol. ppb	SiO ₂ ppb	Toc. Fe	Cu ppb	Pb ppb	NH ₃ ppb	
Steam Generator Blowdown A-D	8.5- 9.3		<2.0	<5	<100		<100	<1000	<1000	<1000	<100		<750	
Main Steam A-D	8.8- 9.3	2-7			<3				<20					
Hotwell Pump Discharge	8.8- 9.3	2-7	<0.8	<100	<20			<100	<300	<100	<5			
Polisher (Main) Influent	8.8- 9.3	2-7	<0.8					<100						
Polisher (Main) Effluent	8.8- 9.3		<0.8		<20			<100	<300	<100	<5			
Polisher Cell Effluent A-E			<0.8											
Main Feedwater	8.8- 9.3	2-7	<0.8	<100	<20	>3 x 100 or >50	<25	<100	<300	<100	<5		100- 750	
Upper Surge Tank	8.8- 9.3	2-7						<100						
Condensate Storage Tank	6.0- 9.3	1-7							<300					

WATER TREATMENT ROOM OPERATING SPECIFICATIONS
CP/O/B/8800/05
ENCLOSURE 6.13

Page 1 of 2

Sample	NTU Turb.	umhos Cond.	ppb Mill Susp. Solids	ppb SiO ₂	ppb Cl ⁻	ppb F ⁻	ppm Free Cl ₂	ppm TSS	C.U. COLOR	pH	TOC	Total Coliform	ppb O ₂
Raw Water	N/S	N/S		N/S				N/S	N/S	N/S		N/S	
YF Filter Eff. "A"	<1.0	N/S		N/S			0.5- 2.0	N/S		N/S			
YF Filter Eff. "B"	<1.0	N/S		N/S			0.5- 2.0	N/S		N/S			
Finished YD	5/Two Day avg. 1/mo. avg.						<2.0		<15	6.5- 8.5		0	
YM Carbon Filters Inf.											N/S		
YM Carbon Filter "A" Eff.							<0.1				N/S		
YM Carbon Filter "B" Eff.							<0.1				N/S		
YM Demin "A" Eff.		<0.2	<100	<20	<100	<100				5.8- 8.0			
YM Demin "B" Eff.		<0.2	<100	<20	<100	<100				5.8- 8.0			
YD Carbon Filter Inf.											N/S		
YD Carbon Filter "A" Eff.							<0.1				N/S		
YD Carbon Filter "B" Eff.							<0.1				N/S		

Page 2 of 2

[illegible]

ENCLOSURE 6.14
CP/O/B/8800/05

HVAC SAMPLING AND ANALYSIS SPECIFICATIONS

SAMPLE	pH @ 25°C	CONDUCTIVITY µmhos/cm	TURBIDITY NTU	INHIBITOR ppm	BACTERIA Colonies/ml	BZT ppm
YB, YC, YH (Admin. Bldg.) YJ, YK, YR, YV, YW, YN	8.2 - 10	<5000	<30	2000 - 3000	<250,000	
KR	8.2 - 10	<5000	<30	2000 - 3000	<250,000	>20

SAMPLE	CONDUCTIVITY µmhos/cm	GLYCOL wt. %	SUSPENDED SOLIDS •
YH (Service, Turbine, and Aux. Bldg. Loops)		35-60	<2000

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
CHEMISTRY PROCEDURE FOR THE
RECORDING AND MANAGEMENT OF DATA
CP/O/B/8800/05
ENCLOSURE 6.15

Steam Generator Wet Lay-Up Specifications

	pH	Na ppb	Cat. Con. umhos	Cl ⁻ ppb	N ₂ H ₄ ppm	D.O. ppb	Sus. Solids ppb	NH ₃ ppb	REMARKS
Steam Generators A-D	9.8- 10.5	<1000	<10	<500	75- 200	<100	<100	5-30	

ENVIRONMENTAL CHEMISTRY OPERATING SPECIFICATIONS
CP/O/B/8800/05
ENCLOSURE 6.16

Unit	Ambient Temp. °C	Flow MGD	pH at 25°C	Spec Cond umhos/cm	Turb NTU	Total Cl ₂ mg/l	Free Cl ₂ ppm	DO ppm	BOD ppm	TSS ppm	Volatiles o/s	Alk ppm CaCO ₃	Acidity ppm CaCO ₃	Soluble Solids ppm	Oil and Grease ppm	Focal Coliforms/100 ml	Boron ppm	Hydrazine ppm	Sediment ml/l	Calc Mg ppm
RL																				
Intake (Lake Wylie)	NS		NS	NS	NS	NS														
Discharge	NS		6-9																	
VC																				
Initial Holdup Pond			NS																	
Settling Basin A			6-9																	
Settling Basin B			6-9																	
Final Holdup Pond			6-9																	
PIP In Sys Out Pit			6-9		NS	<.02				<.30										
System Discharge		NS	6-9							<.30					<.15		<.10			<.43
VT																				
Influent			NS						NS											
Cell A			NS				1-3			NS			NS						NS	
Cell B			NS				2-4			NS			NS						NS	
Cell C			NS				3-5			NS			NS						NS	
Cell D			NS				4-5			NS			NS						NS	
Effluent Polishing Basin	NS		6-9				5-7		<.30	<.90			NS							
System Discharge		NS	6-9			NS	.5		<.30	<.90						200				
RC																				
Unit 1 Cooling Towers	NS		7.5-7.8	12XRL	NS	NS	2.5 hr			<.150										<.50
Cooling Tower Blowdown			6-9			0 (1)	0 (2)													

(1) 2 hr/24 hr exception
(2) 2 hr/24 hr exception of 0.2 average

ENCLOSURE 6.17
CP/O/B/8800/05

To Be Added Later

ENCLOSURE 6.18
CP/O/B/8800/05

To Be Added Later

ENCLOSURE 6.19
CP/O/B/8800/05
CATAWBA NUCLEAR STATION
SAMPLE REQUISITION

HEALTH PHYSICS' SAMPLE NUMBER _____
CHEMISTRY'S SAMPLE NUMBER _____
DATE/TIME SAMPLE TAKEN _____
DATE/TIME RESULTS RECEIVED _____
DWR # _____ LWR # _____ RWP # _____

REQUISITION SUBMITTED BY:

PERSON _____
RADWASTE CHEM _____
ENVIRON CHEM _____
SECONDARY CHEM _____
PRIMARY CHEM _____
CONTROL ROOM _____
HEALTH PHYSICS _____
OTHER GROUP _____

PHONE EXT. _____

SUBMIT REQUISITION TO:

HOT LAB _____ ()
COLD LAB _____ ()
AA LAB _____ ()
CT LAB _____ ()
RADWASTE BENCH _____ ()
WATER TRY. LAB _____ ()
HP LAB REQUEST
(SAMPLE TO BE TAKEN) _____ ()
HP COUNT ROOM
(ANALYSIS ONLY) _____ ()

PRIORITY:

- (1) Personnel Safety, Reactor Safety, Secondary Operations Requirement
(2) High Radwaste Subsystem Inventory
(3) Results in 4 Hours
(4) Results in 8 Hours
(5) Results in 24 Hours
(6) Information - Specify Results in _____ Hours

SAMPLE TYPE/ORIGIN _____

SAMPLE PREPARED BY _____

FOR AA SAMPLES, SPECIFY FLAME ☐ OR FURNACE ☐

DETERMINE CONFORMANCE TO SPECIFICATIONS FOR _____

DISCHARGE DOCUMENTATION REQUESTED YES ☐ NO ☐

SERVICES REQUESTED

CHECK BOX ABOVE APPROPRIATE ITEM. THE LABORATORY WILL ENTER RESULTS IN THE BOX BELOW THE ITEM OR ATTACH RESULTS AS REQUIRED.

ANALYSIS PERFORMED BY CHEMISTRY

TAKE SAMPLE	O ₂ PPH/5	Cl PPH	F PPH	S PPH	pH	Cu PPH	Fe PPH	Nb PPH	Al PPH	Pb PPH	SiO ₂ PPH	Ca PPH	Mg PPH

OXID ORG PPH	APPROX UCI/ml	FILTR Y UCI/ml	ADS N Y UCI/ml	IX N Y UCI/ml	CAUS ADD (ppb)

ANALYSIS PERFORMED BY HEALTH PHYSICS

TAKE SAMPLE AND ROUTE TO HP LAB	Cell SPECTRUM (Attach Results)	GROSS B _____	SAMPLE VOLUME _____ FOR AIR ANALYSIS VOLUME = TIME X FLOW _____ X _____	RELEASE RATE (gpm or cfm) _____
	JOB STREAM INITIATED _____	GROSS Y _____		
	PERSON ANALYZING SAMPLE _____	GROSS Z _____		
	COUNTING TIME _____	TRITIUM _____		
	TIME SAMPLE BEGAN COUNTING _____	OTHER (Attach Results)		

REMARKS/ADDITIONAL SAMPLE REQUEST:

PERFORMED BY: _____


DATE _____

TIME COMPLETED _____

REVIEWED BY LAB SUPERVISOR(S) _____

CONTROL ROOM NOTIFIED YES ☐ NO ☐

INTERLABORATORY SAMPLE PROCESSING



- 1) Requesting Lab draws sample and assigns sample number.
- 2) Sample Requisition Form is filled out.
- 3) Sample and Form routed to appropriate lab.
- 4) The lab receives form and sample and performs requested analysis.
- 5) Results are recorded in appropriate space on Sample Requisition Form.
- 6) If additional interlaboratory analyses required, sample and form are routed to next requested lab, where additional analysis performed.
- 7) Once all analyses completed, original copy of Requisition Form with all required data entered is returned to Requesting Lab.
- 8) Requesting Lab transfers data into their Lab Log Book; appropriate actions as indicated by results are initiated.

Form 18728

CATAWBA NUCLEAR STATION - PRIMARY CHEMISTRY

[illegible]

[illegible]

ENCLOSURE 6.22
CP/O/B/8800/05

Page 1 of 2

Form 34721 (10-81)

[illegible]

PARTICULATE COUNT MICRONS

Page No. _____

[illegible]

Page 1 of 2

CATAWBA NUCLEAR STATION SECONDARY CHEMISTRY

[illegible]

Page 2 of 2

Page No.

[illegible]

CATAWBA NUCLEAR STATION - CLOSED COOLING SYSTEMS

[illegible]

DATAWBA NUCLEAR STATION WASTEWATER CHEMISTRY

[illegible]

Page 2 of 2

PAGE 8

[illegible]

ENCLOSURE 6.26
CP/O/B/8800/05

To Be Added Later