

APPENDIX A

NOTICE OF VIOLATION

Pennsylvania Power and Light Company  
Susquehanna Steam Electric Station, Unit 1

Docket No. 50-387  
License No. NPF-14

As a result of the inspection conducted on November 28-December 2, 1983, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register on March 9, 1982 (47 FR 9987), the following violation was identified:

- A. Section 6.8.1 of the Technical Specifications requires written procedure shall be established, implemented and maintained covering the various activities.

Contrary to the above, the procedures (SC-69-006 and CH-IC-011) used for the liquid radwaste monitor calibration were not implemented as required.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Pennsylvania Power and Light Company is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8402240023 840208  
PDR ADDCK 05000387  
Q PDR