

APPENDIX A

NOTICE OF VIOLATION

GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station

Docket No. 50-219
License No. DPR-16

As a result of the inspection conducted on October 12, 17-21, and 27, 1983 and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C), the following violations was identified:

- A. 10 CFR Part 50, Appendix B Criterion III states in part, "Measures shall be established to assure that applicable design basis ... are correctly translated into specifications, drawings, procedures and instructions." and Criterion XVII states in part, "Sufficient records shall be maintained to furnish evidence of activities affecting quality."

Contrary to the above, as of October 27, 1983, sufficient records of design process activities affecting quality were not maintained to furnish evidence to show that the following NUREG 0737 design basis items had been correctly translated into specifications, drawings, procedures and instructions:

- 1) "The accuracy and response time specification of the containment pressure monitor(s) shall be provided and justified to be adequate for their intended function."
- 2) "The accuracy requirements of the containment water level monitors shall be provided and justified to be adequate for their intended function."
- 3) "The accuracy and placement of the containment hydrogen monitors shall be provided and justified to be adequate for their intended function."

This is a Severity Level V violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, General Public Utility is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including; (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8402240047 840209
PDR ADOCK 05000219
G PDR