

APPENDIX A

NOTICE OF VIOLATION

Rochester Gas and Electric Corporation
R. E. Ginna Nuclear Power Plant

Docket No. 50-244
License No. DPR-18

As a result of the inspection conducted on November 1, 1983 through January 15, 1984, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register on March 9, 1982 (47 FR 9987) the following violation was identified:

Technical Specification 4.5.2.3.1.c requires, in part, that at least once every 18 months the iodine removal efficiency of the post accident charcoal system be measured under test conditions of at least 286°F.

Contrary to the above, the surveillance test performed on December 4, 1983 to determine the iodine removal efficiency of the post accident charcoal system was measured under test conditions of 266°F, rather than 286°F as required. Further, the test report documenting the incorrect test temperature was reviewed and accepted by supervisory personnel from two responsible departments.

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Rochester Gas and Electric Corporation is hereby required to submit to this office within 30 days of the date of the letter transmitting this notice, a written statement or explanation in reply, including for the above violation: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.