

March 6, 1995

Mr. D. L. Rehn  
Vice President, Catawba Site  
Duke Power Company  
4800 Concord Road  
York, SC 29745

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2, - REQUEST FOR USAGE OF ASME  
CODE CASE N-416-1, RELIEF REQUEST NO. 95-GO-001 (TAC NO. M91604)

Dear Mr. Rehn:

By letter dated February 22, 1995, the Duke Power Company (licensee) requested relief from the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI that would allow use of ASME Code Case N-416-1 in lieu of performing the Code-required hydrostatic pressure test for welded repairs or installation of replacement items by welding. Use of Code Case N-416-1 is authorized pursuant to 10 CFR 50.55a(a)(3)(ii) provided that additional surface examinations are performed on the root (pass) layer of butt and socket welds on the pressure retaining boundary of Class 3 components when the surface examination method is used in accordance with Section III. Use of Code Case N-416-1 is authorized until such time as this Code case is published in a future revision of Regulatory Guide 1.147. At that time if you intend to continue to implement this Code case, you must follow all provisions in Code Case N-416-1, with limitations issued in Regulatory Guide 1.147, if any. Our evaluation and conclusions are contained in the enclosed Safety Evaluation.

The NRC staff has concluded that compliance with the specified requirements of Section XI would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. Pursuant to 10 CFR 50.55a(a)(3)(ii), the alternative contained in Request for Relief No. 95-GO-001 is authorized with the conditions identified above.

Sincerely,

Original signed by:

Herbert N. Berkow, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

9503090113 950306  
PDR ADOCK 05000413  
P PDR

Docket Nos. 50-413 and 50-414

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION	W. Russell/F. Miraglia		
Docket File	G. Hill (4)	E. Jordan	T. McLellan, DE/EMCB
PUBLIC	OPA	J. Zwolinski	OGC
PD23 Reading	S. Varga	R. Crlenjak, RII	
R. Zimmerman	R. Spessard	ACRS (4)	
	J. Lieberman	E. Merschoff, RII	

\*SEE PREVIOUS CONCURRENCE

OFFICE	DRPE/PD23/LA	DRPE/PD23/PM	DRPE/PD23/D	OGC*	EMCB*
NAME	L. BERRY	R. MARTIN	H. BERKOW	M. YOUNG	J. STROSNIDER
DATE	3/6/95	3/6/95	3/6/95	3/2/95	3/28/95

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\CATAWBA\CAT91604.RR

000011

DFD11

NRC FILE CENTER COPY

March 6, 1995

Mr. D. L. Rehn  
Vice President, Catawba Site  
Duke Power Company  
4800 Concord Road  
York, SC 29745

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2, - REQUEST FOR USAGE OF ASME  
CODE CASE N-416-1, RELIEF REQUEST NO. 95-GO-001 (TAC NO. M91604)

Dear Mr. Rehn:

By letter dated February 22, 1995, the Duke Power Company (licensee) requested relief from the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI that would allow use of ASME Code Case N-416-1 in lieu of performing the Code-required hydrostatic pressure test for welded repairs or installation of replacement items by welding. Use of Code Case N-416-1 is authorized pursuant to 10 CFR 50.55a(a)(3)(ii) provided that additional surface examinations are performed on the root (pass) layer of butt and socket welds on the pressure retaining boundary of Class 3 components when the surface examination method is used in accordance with Section III. Use of Code Case N-416-1 is authorized until such time as this Code case is published in a future revision of Regulatory Guide 1.147. At that time if you intend to continue to implement this Code case, you must follow all provisions in Code Case N-416-1, with limitations issued in Regulatory Guide 1.147, if any. Our evaluation and conclusions are contained in the enclosed Safety Evaluation.

The NRC staff has concluded that compliance with the specified requirements of Section XI would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. Pursuant to 10 CFR 50.55a(a)(3)(ii), the alternative contained in Request for Relief No. 95-GO-001 is authorized with the conditions identified above.

Sincerely,

Original signed by:

Herbert N. Berkow, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosure: Safety Evaluation

cc w/encl: See next page

	W. Russell/F. Miraglia		
DISTRIBUTION	G. Hill (4)	E. Jordan	T. McLellan, DE/EMCB
Docket File	OPA	J. Zwolinski	OGC
PUBLIC	S. Varga ←	R. Crlenjak, RII	
PD23 Reading	R. Spessard	ACRS (4)	
R. Zimmerman	J. Lieberman	E. Merschhoff, RII	

\*SEE PREVIOUS CONCURRENCE

OFFICE	DRPE/PD23/LA	DRPE/PD23/PM	DRPE/PD23/D	OGC*	EMCB*
NAME	L. BERRY	R. MARTIN	H. BERKOW	N. YOUNG	J. STROSNIDER
DATE	3/6/95	3/6/95	3/6/95	3/2/95	3/28/95

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\CATAMBA\CAT91604.RR



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

March 6, 1995

Mr. D. L. Rehn  
Vice President, Catawba Site  
Duke Power Company  
4800 Concord Road  
York, SC 29745

SUBJECT: CATAMBA NUCLEAR STATION, UNITS 1 AND 2, - REQUEST FOR USAGE OF ASME  
CODE CASE N-416-1, RELIEF REQUEST NO. 95-GO-001 (TAC NO. M91604)

Dear Mr. Rehn:

By letter dated February 22, 1995, the Duke Power Company (licensee) requested relief from the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI that would allow use of ASME Code Case N-416-1 in lieu of performing the Code-required hydrostatic pressure test for welded repairs or installation of replacement items by welding. Use of Code Case N-416-1 is authorized pursuant to 10 CFR 50.55a(a)(3)(ii) provided that additional surface examinations are performed on the root (pass) layer of butt and socket welds on the pressure retaining boundary of Class 3 components when the surface examination method is used in accordance with Section III. Use of Code Case N-416-1 is authorized until such time as this Code case is published in a future revision of Regulatory Guide 1.147. At that time if you intend to continue to implement this Code case, you must follow all provisions in Code Case N-416-1, with limitations issued in Regulatory Guide 1.147, if any. Our evaluation and conclusions are contained in the enclosed Safety Evaluation.

The NRC staff has concluded that compliance with the specified requirements of Section XI would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. Pursuant to 10 CFR 50.55a(a)(3)(ii), the alternative contained in Request for Relief No. 95-GO-001 is authorized with the conditions identified above.

Sincerely,

A handwritten signature in dark ink, reading "Herbert N. Berkow", is written over the typed name.

Herbert N. Berkow, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosure: Safety Evaluation

cc w/encl: See next page



Mr. David L. Rehn  
Duke Power Company

cc:

Mr. Z. L. Taylor  
Regulatory Compliance Manager  
Duke Power Company  
4800 Concord Road  
York, South Carolina 29745

A. V. Carr, Esquire  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire  
Winston and Strawn  
1400 L Street, NW  
Washington, DC 20005

North Carolina Municipal Power  
Agency Number 1  
1427 Meadowwood Boulevard  
P. O. Box 29513  
Raleigh, North Carolina 27626-0513

Mr. T. Richard Puryear  
Nuclear Technical Services Manager  
Westinghouse Electric Corporation  
Carolinas District  
2709 Water Ridge Parkway, Suite 430  
Charlotte, North Carolina 28217

County Manager of York County  
York County Courthouse  
York, South Carolina 29745

Richard P. Wilson, Esquire  
Assistant Attorney General  
South Carolina Attorney General's  
Office  
P. O. Box 11549  
Columbia, South Carolina 29211

Piedmont Municipal Power Agency  
121 Village Drive  
Greer, South Carolina 29651

Dayne H. Brown, Director  
Division of Radiation Protection  
N.C. Department of Environment,  
Health and Natural Resources  
P. O. Box 27687  
Raleigh, North Carolina 27611-7687

Catawba Nuclear Station

North Carolina Electric Membership  
Corporation  
P. O. Box 27306  
Raleigh, North Carolina 27611

Senior Resident Inspector  
4830 Concord Road  
York, South Carolina 29745

Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Max Batavia, Chief  
Bureau of Radiological Health  
South Carolina Department of  
Health and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Mr. G. A. Copp  
Licensing - EC050  
Duke Power Company  
526 South Church Street  
Charlotte, North Carolina 28242-0001

Saluda River Electric  
P. O. Box 929  
Laurens, South Carolina 29360

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Elaine Wathen, Lead REP Planner  
Division of Emergency Management  
116 West Jones Street  
Raleigh, North Carolina 27603-1335