



PECO ENERGY

Robert W. Boyce  
Plant Manager  
Limerick Generating Station

PECO Energy Company  
Limerick Generating Station  
PO Box 2300  
Sanatoga, PA 19464-0820  
215 327 1200 Ext. 2000

10CFR50.73

February 27, 1995

Docket No. 50-353

License No. NPF-85

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

SUBJECT: Licensee Event Report  
Limerick Generating Station - Unit 2

This LER reports automatic closure of four Unit 2 Drywell Chilled Water System inboard containment isolation valves due to an inadvertent loss of power to an interposing relay in the closure circuit for the valves.

Reference:	Docket No. 50-353
Report Number:	2-95-003
Revision Number:	00
Event Date:	January 27, 1995
Discovery Date:	January 27, 1995
Report Date:	February 27, 1995
Facility:	Limerick Generating Station P.O. Box 2300, Sanatoga, PA 19464-2300

This LER is being submitted pursuant to the requirements of 10 CFR 50.73(a)(2)(iv).

Very truly yours,

cc: T. T. Martin, Administrator Region I, USNRC  
N. S. Perry, USNRC Senior Resident Inspector, LGS

9503090119 950227  
PDR ADOCK 05000353  
S PDR

Handwritten initials "JL22" and a vertical line.