

DCS No: 50247-831004
Date: October 12, 1983

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-83-103A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility: Consolidated Edison Company
New York, Inc.
Indian Point Unit 2
Buchanan, New York
(DN 50-247)

Licensee Emergency Classification:
____ Notification of Unusual Event
____ Alert
____ Site Area Emergency
____ General Emergency
X Not Applicable

Subject: INDIAN POINT 2 UNSCHEDULED OUTAGE UPDATE

On October 4, 1983, the licensee commenced an unscheduled outage to repair moisture separator reheater tube leaks. On October 11, the licensee notified the NRC that a reactor coolant leak of approximately 0.1 gpm was noted on No. 22 steam generator hot leg manway. The licensee had previously reported and is monitoring an approximately 0.3 gpm leak on the No. 22 steam generator cold leg manway. The licensee has decided to bring the plant to cold shut-down to repair these manway leaks and the outage will be extended until approximately October 20, 1983.

The licensee will issue a press release. NRC will respond to media inquiries. The State of New York has been notified.

This PN is issued for information only.

CONTACT: T. Foley R. Jacobs L. Norrholm
8-914-739-9360 8-488-1222 8-488-1114

DISTRIBUTION:

H. St.	MNBB	Phillips <u>12:20</u>	E/W	Willste	Mail: ADM:DMB
Chairman Palladino	EDO	NRR	IE	NMSS	DOT:Trans only
Comm. Gilinsky	PA		OIA	RES	
Comm. Bernthal	MPA		AEOD		
Comm. Roberts	ELD				
Comm. Asselstine					
ACRS		Air Rights	INPO----		
SECY		SP	NSAC----		
CA					
PDR	Regional Offices			TMI Resident Section <u>12:27</u>	
				RI Resident Office <u>12:26</u>	

Licensee: _____
(Reactor Licensees)

Region I Form 83
(Rev. January, 1983)

8310170310 831012
PDR I&E
PNO-I-83-103A PDR

TE34
d1