

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

2 88 24  
February 10, 1984

Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30303


Re: RII:RCD  
McGuire Nuclear Station  
Docket Nos. 50-369, 50-370  
IE Bulletin 83-08

Dear Mr. O'Reilly:

This letter is in response to IE Bulletin 83-08 which concerned electrical circuit breakers with an undervoltage trip feature in use in safety-related applications other than the reactor trip system. A review of plant records has shown that no Westinghouse type DB, Westinghouse type DS or General Electric type AK-2 circuit breakers are used in any safety-related applications at McGuire Nuclear Station.

I declare under penalty of perjury that the statements set forth herein are true and correct to the best of my knowledge.

Very truly yours,



Hal B. Tucker

WHM/plp

cc: Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. W. T. Orders  
NRC Senior Resident Inspector  
McGuire Nuclear Station

8402280177 840210  
PDR ADUCK 05000369  
PDR  
Q

484  
1/0