

GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

February 23, 1984
5211-84-2041

Office of Nuclear Reactor Regulation
Attn: H. Denton, Director
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555


Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Master Restart Schedule

The attached master restart schedule has been revised to include work on reactor coolant pump 1B prior to precritical non-nuclear hot functional testing. Vibration problems necessitate inspection of the pump shaft. This work will not impact our scheduled capability of June 1, 1984 criticality. We reiterate our pending request for approval to perform the hot testing program.

In order to take best advantage of this "precritical" period, we have scheduled the completion of the other major work items and surveillances, including containment integrated leak rate testing. Modifications for which milestone delays are perceived will be rescheduled beyond restart. None of the above modifications or plant activities will preclude our ability to complete precritical non-nuclear hot functional testing prior to June 1, 1984.

Sincerely,


H. D. Hukill
Director, TMI-1

HDH:RAS:vjf
Attachment
cc: J. F. Stolz
H. Silver
J. Van Vliet
R. Conte

8402280381 840223
PDR ADOCK 05000289
P PDR

APPROVED BY:
H. D. Hukill

R. J. Toole

H. D. Hukill
V.P. & Director TMI-1
R. J. Toole 2-21-84
O&N Director TMI-1

GPU NUCLEAR CORPORATION
TMI-1
MASTER RESTART SCHEDULE
MAJOR EVOLUTIONS SUMMARY
(ASSUMES 06/01/84 RESTART)

Baseline Revision 2

Revision No. _____

Update No. _____

Date: 02/21/84

Date: _____

Date: _____

