

JAN 5 1984

Tennessee Valley Authority  
ATTN: Mr. H. G. Farris  
Manager of Power  
500A Chestnut Street Tower II  
Chattanooga, TN 37401

Gentlemen:

SUBJECT: MEETING SUMMARY - REPORT NOS. 50-259/83-58, 50-260/83-58 AND  
50-296/83-58

This letter refers to the Enforcement Conference held at our request in the NRC Region II office on December 16, 1983. This meeting concerned activities authorized by NRC Operating License Nos. DPR-33, DPR-52, and DPR-68 of the Browns Ferry facilities. The meeting related to an apparent security violation, operation with underrated diesel generator heat exchangers, and modifications to the scram discharge instrument volume that resulted in exceeding a limiting condition for operations.

The subjects discussed are detailed in the enclosed inspection report.

It is our opinion that this meeting was beneficial and has provided for a better understanding of inspection findings and enforcement issues. In accordance with Section 2.790 of NRC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosure will be placed in NRC's Public Document Room. If you wish to withhold information contained in the inspection report, please notify this office by telephone and submit a written application to withhold information consistent with the requirements of 2.790(b)(1).

Should you have any questions concerning this matter, we will be pleased to discuss them.

Sincerely,

James P. O'Reilly  
Regional Administrator

Enclosure:  
Inspection Report Nos. 50-259/83-58  
50-260/83-58 and 50-296/83-58

cc w/encl:  
J. A. Coffey, Director of Nuclear Power  
G. T. Jones, Plant Superintendent  
H. N. Culver, Chief, Nuclear Safety  
Review Staff  
D. L. Williams, Jr., Superintendent Licensing  
Section  
R. E. Rogers, Project Engineer  
J. W. Anderson, Manager Office of Quality  
Assurance

8402280411 840105  
PDR ADDCK 05000259  
Q PDR

DEF 01  
11

JAN 5 1984

bcc w/encl:  
NRC Resident Inspector  
Document Control Desk  
State of Alabama

RII

*in*  
FCantrell:jw  
1/3/84

RII

*DMcGuire*  
DMcGuire  
1/3/84

RII

*DMVerrelli*  
DMVerrelli  
1/3/84

RII

*RCLewis*  
RCLewis  
1/4/84

RII

*RDMartin*  
RDMartin  
1/ /84