

UNIT SHUTDOWN AND POWER REDUCTIONS
REPORT MONTH AUGUST 1983

311

Doc # No. 50-272
Unit Name Salem No.2
Date Sept. 10, 1983
Telephone 609-935-6000
Extension 4455

Completed by L.K. Miller

No.	Date	Type 1	Duration Hours	Reason 2	Method of Shutting Down Reactor	License Event Report	System Code 4	Component Code 5	Cause and Corrective Action to Prevent Recurrence
83-074	8/08	F	197.6	B	1	---	HF	PUMPXX	Circulating Water Pump Motors
83-076	8/10	"	2.4	"	"	"	"	FILTER	Traveling Screens/ Trash Racks
83-078	8/11	"	133.0	"	"	"	IE	INSTU	Canal Screens Nuclear Excore Nuclear Instrumenta.
83-080	8/17	"	4.1	"	"	"	HF	FILTER	Traveling Screens/ Trash Racks
83-082	8/17	"	12.5	"	"	"	"	"	Canal Screens
83-084	8/18	"	2.7	"	"	"	"	"	"
83-086	8/18	"	2.9	"	"	"	"	"	"
83-088	8/19	"	306.8	"	"	"	HA	GENERA	Generator Stator Trouble

1
F: Forced
S: Scheduled

2 Reason
A-Equipment Failure-explain
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & Licensing Exam
F-Administrative
G-Operational Error-explain
H-Other-explain

3 Method
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Continuation of
Previous Outage
5-Load Reduction
9-Other

4 Exhibit G
Instructions
for Preparation
of Data
Entry Sheets
for Licensee
Event Report
(LER) File
(NUREG 0161)

5 Exhibit 1
Salem as
Source

IE 24

8310180114 831010
PDR ADDCK 05000311
PDR



Public Service Electric and Gas Company P.O. Box E Hancocks Bridge, New Jersey 08038

Salem Generating Station

September 20, 1983

Director, Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

MONTHLY OPERATING REPORT
SALEM NO. 2
DOCKET NO. 50-311

The attached is a revision to the monthly operating report for Salem Unit No. 2 for the month of August 1983. The revision consists of the addition of a second page to the Unit Shutdowns and Power Reduction section of the report. This page was inadvertently omitted from the August report when it was issued.

Sincerely yours,

J. M. Zupko, Jr.
General Manager -
Salem Operations

LKM:kl1

CC: Dr. Thomas E. Murley
Regional Administrator USNRC
Region I
631 Park Avenue
King of Prussia, PA 19405

Director, Office of Management
Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Enclosures
Page 4a
8-1-7.R4

IE 24

1/1