Iowa Electric Light and Power Company February 17, 1984 NG-84-0478

Mr. James G. Keppler Regional Administrator Region III U. S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137

> Subject: Duane Arnold Energy Center Docket No: 50-331 Op. License No: DPR-49 IEB 80-03, Check Valves Followup Report Reference: Letter, R. McGaughy to J. Keppler N6-83-1964 dated June 8, 1983

Dear Mr. Keppler:

In the above reference we committed to inspect two Emergency Service Water System valves that fell within the scope of the subject NRC Bulletin. Specifically, in response to item 3 of the Bulletin, we committed to complete valve inspection prior to startup from our next refueling outage (currently scheduled for the Fall of 1984) or earlier if a sufficient duration outage were to occur. During October, 1983 an outage occurred which allowed inspection of the valves. During the inspection, it was confirmed that the valves had not undergone either partial or complete disassembly of valve internals. Further, the inspection did not identify any problems that would affect valve operability. The completed inspection procedure is available for review at DAEC.

As noted in the reference letter, these valves have been added to our ASME Section XI Inservice Test Program. Future valve performance will be monitored thru this program. This concludes our response to IEB 83-03.

IOWA ELECTRIC LIGHT AND POWER COMPANY

Richard W. McGaughy

Manager, Nuclear Division

8402290265 840217 PDR ADOCK 05000331 PDR

RWM/WJM/pv*

cc: W. Miller

- L. Liu S. Tuthill
 - M. Thadani (NRC) T. Houvenagle (ICC) NRC Resident Office

Document Control Desk USNRC Washington, D.C.

Subscribed and sworn to before me on this 1790 day of Jubruary 1984. Athleen M. Jurman

FEB 2 4 1984

IE11 10

Duane Arnold Energy Center • P.O. Box 351 • Cedar Rapids, Iowa 52406 • 319/851-7611