

**GPU Nuclear**

P.O. Box 480  
Middletown, Pennsylvania 17057  
717-944-7621  
Writer's Direct Dial Number:

September 19, 1983  
5211-83-266

File: Licensee Event  
Reports

Dr. Thomas E. Murley  
Region I, Regional Administrator  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
LER 83-25

This is to confirm the telephone notification to Mr. F. Young, NRC Resident Inspector by Mr. M. A. Nelson at 1810 hrs. on September 16, 1983.

A containment isolation valve (CIV) was found open while containment integrity was required. The CIV (FS-V-405) is a 3/4" vent/cest connection for the fire service supply to the Reactor Building. This event is considered reportable under section 6.9.2.a.2 of the Unit I Technical Specifications.

Although reportable, there was no threat to the health and safety of the public since the second boundary, FS-V-401 remained closed.

Investigation of the cause for this incident and the corrective actions to prevent recurrence will be described in the 14 day followup report.

Sincerely,

R. J. Toole  
Operations and Maintenance  
Director, TMI-1

RJT:HBS:jrg

cc: R. Conte  
CARIRS

8310200008 830919  
PDR ADOCK 05000289  
S PDR

IE29  
1/0