



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 76
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company (the licensees) dated July 14, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:


8403070389 840227
PDR ADDCK 05000334
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 76, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 27, 1984

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Revise Appendix A as follows:

Remove Page
3/4 7-321

Insert Page
3/4 7-321

TABLE 3.7-4a (Continued)

SAFETY RELATED HYDRAULIC SNUBBERS*

BEAVER VALLEY - UNIT 1 3/4 7-324	<u>SNUBBER NO.</u>	<u>SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION</u>			<u>ACCESSIBLE OR INACCESSIBLE</u>	<u>HIGH RADIATION ZONE</u>	<u>ESPECIALLY DIFFICULT TO REMOVE</u>
	FC-HSS-201	FC	FUEL BUILDING	747'	A	No	No
	FC-HSS-5A	"	"	747'	"	"	"
	FC-HSS-202	"	"	745'	"	"	"
	FC-HSS-203	"	"	745'	"	"	"
	FC-HSS-204	"	"	742'	"	"	"
	FC-HSS-205	"	"	742'	"	"	"
	FC-HSS-206	"	"	742'	"	"	"
	WFPD-HSS-228	FW	CABLE VAULT	761'	A	No	Yes
	WFPD-HSS-229	"	"	761'	"	"	"
	WFPD-HSS-230	"	"	761'	"	"	"
	WFPD-HSS-231	"	"	767'	"	"	"
	WFPD-HSS-232	"	"	767'	"	"	"
	WFPD-HSS-233	"	"	767'	"	"	"

* Snubbers may be added to safety related systems without prior License Amendment to Table 3.7-4 provided that safety evaluations, documentation and reporting are provided in accordance with 10 CFR 50.59 and that a revision to Table 3.7-4 is included with a subsequent License Amendment request.