

DCS MS-016

Docket No. 50-285

OCT 17 1983

Mr. W. C. Jones
Division Manager, Production
Operations
Omaha Public Power District
1623 Harney Street
Omaha, Nebraska 68102

Dear Mr. Jones:

SUBJECT: NUREG-0737 ITEM II.K.2.17 - VOIDING IN THE REACTOR COOLANT
SYSTEM DURING ANTICIPATED TRANSIENTS

The NRC staff has completed its review of the above subject NUREG-0737 item. The staff concludes that the voids generated in the reactor coolant system of Combustion Engineering (CE) plants during any anticipated event are accounted for in present analysis models even though these models and analysis are not described in the FSARs of the older plants. The staff further concludes that a steam void will not result in unacceptable consequences in any CE plant reviewed.

A copy of the related safety evaluation is enclosed.

Sincerely,

~~Original~~ signed by:

James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
As stated

cc: See next page

DISTRIBUTION:

✓ Docket File	PMKreutzer
NRC PDR	ETourigny
L PDR	Gray File
NSIC	OELD
ORB#3 Rdg	EJordan
DEisenhut	JTaylor
ACRS-10	JZwolinski
CPatel	

ORB#3:DL
PMKreutzer
10/12/83

ORB#3:DL
ETourigny/pn
10/17/83

CP
ORAB
CPatel
10/17/83

get
ORB#3:DL
JRMiller
10/17/83

Omaha Public Power District

cc:

Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N.W.
Washington, D. C. 20036

Mr. Jack Jensen
Chairman, Washington County
Board of Supervisors
Blair, Nebraska 68023

U.S. Environmental Protection Agency
Region VII
ATTN: Regional Radiation
Representative
324 East 11th Street
Kansas City, Missouri 64106

Metropolitan Planning Agency
ATTN: Dagnia Prieditis
7000 West Center Road
Omaha, Nebraska 68107

Mr. Larry Yandell
U.S.N.R.C. Resident Inspector
P. O. Box 309
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman
Manager - Washington Nuclear
Operations
C-E Power Systems
Combustion Engineering, Inc.
7910 Woodmont Avenue
Bethesda, Maryland 20814

Regional Administrator
Nuclear Regulatory Commission, Region IV
Office of Executive Director for Operations
611 Ryan Plaza Drive Suite 1000
Arlington, Texas 76011



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

NUREG-0737 ITEM II.K.2.17

VOIDING IN THE REACTOR COOLANT SYSTEM DURING
ANTICIPATED TRANSIENTS IN COMBUSTION ENGINEERING PLANTS

I. INTRODUCTION

During NRC's review of transients in Babcock and Wilcox (B&W) plants after the TMI-2 accident it was noticed that pressurizer water levels did not always change as expected. It was surmised that steam, which formed and accumulated in the hotter, upper-head region of the reactor vessel during the transients, caused this anomaly by acting as a second pressurizer. There was not enough data to determine how much steam was formed during the transient. Also, the formation of steam in the upper head had not been considered in the accident and transient analyses; so a letter (ref. 1) requesting an evaluation was sent to all B&W plants on January 9, 1980.

On June 11, 1980, a steam bubble formed in the upper head region of a Combustion Engineering plant during a natural circulation cooldown (ref. 2). The issue of steam formation in the reactor coolant system (RCS) was thereafter extended to all pressurized water reactors (ref. 3).

The June 11, 1980 event also caused the generation of another NRC Generic Letter (ref. 4) which asked all PWR licensees about their capabilities for performing natural circulation cooldown. The natural circulation issue, which is called Multi Plant Action

No. B-66, is being evaluated separately even though there is some overlap with this F-33 task action item.

II. DISCUSSION

To comply with task action item F-33 the Combustion Engineering Owners Group evaluated the potential for and consequences of voiding in the RCSs of all Combustion Engineering plants. This evaluation is described in reference 5.

For this evaluation explicit nodes for the upper head region of the reactor vessel were put into the models for two computer programs. The LTC program, which is one-dimensional and assumes a single phase in the RCS, was used for the normal operational transients. The CESEC program, which uses a node flow path network to model the RCS, was used to analyze the effect of steam voids in the events in Chapter 15 of the Safety Analysis Report (SAR).

In general, calculations with these computer programs showed that the ratio of upper head volume to total RCS volume is a direct indicator of the impact steam void formation has upon transient RCS pressure. Since this ratio gets larger with plant size the effect of steam void in the upper reactor vessel heads is greatest in the largest plants. Other plant dependent parameters that were taken into account in the calculations are: safety injection set point, high pressure safety injection pump shut off head, auxiliary feedwater flow, and the capacity of the main steam safety valves.

By using the LTC program it was shown that for normal operational

transients, including rapid cooldowns after trips from normal operation, the subcooling margin in the upper region of the reactor vessels is at least 30°F. This minimum occurs shortly after a reactor trip from normal operation. After that at operator controlled cooldown rates of up to 100°F/hour, which is a Technical Specification limit, with reactor coolant pumps running the minimum subcooling margin was calculated to be 46°F for all operating C.E. plants including San Onofre 2 & 3. C.E. concluded that this is sufficient margin to prevent a void from forming in the upper region of reactor vessels during operational transients in which the reactor coolant pumps continue to run.

A loss of offsite power (LOOP) and consequent trip of the reactor coolant pumps was analyzed where it was also assumed that an atmospheric steam dump valve was inadvertently opened. This was found to be the most limiting anticipated operational occurrence and it is more limiting than just a LOOP by itself. The analysis showed that during the pretrip portion of this occurrence the pressure remains above the saturation pressure in the hot, upper-head region of the reactor vessel; so no steam void is formed and there is no impact on the departure from nucleate boiling (DNB) during this time period. Voids begin to form in the upper head region after the reactor is tripped on the low pressurizer pressure trip setpoint. The void volume increases slowly with cooldown until reaching its maximum value near the time of steam generator dryout. Thereafter the void volume decreases slowly because the RCS pressure increases due to decay heat and the high pressure safety injection flow.

Further CESEC analyses showed that: (1) all of the effects of upper head voiding after a main steamline break (MSLB) are more limiting than for the inadvertent opening of an atmospheric dump valve, and (2) the MSLB is the most limiting overcooling event with steam void in the upper reactor head. Once again the analysis showed that during the pretrip portion of the MSLB the pressure remains above the saturation pressure in the upper head region; so no steam is formed and there is no impact on DNB during this time period. After the reactor trip, void formed in the upper head region and held up the pressure. This higher pressure delayed the safety injection actuation signal and reduced the flow from the high pressure safety injection pumps; so that less boron reached the core prior to steam generator dryout. Consequently there was insufficient boron to keep the reactor shutdown in all CE plants and there was a return to power in the largest plants. However, it was found that during the return to power all Standard Review Plan (SRP) acceptance criteria were satisfied for all CE plants when the reactor vessel upper head region void effects were conservatively modeled. The most void was formed in the largest plants, which in this case are San Onofre 2 & 3, but even in these plants there is a minimum of over 200 cubic feet of water between the steam void and the hot legs.

For the depressurization events, LOCAs, including an inadvertent opening of the PORV, were analyzed according to 10CFR50 Appendix K criteria and have been evaluated separately. For the remaining depressurization events the CESEC analyses showed that the effects of steam voids in the upper head are most limiting after a steam

generator tube rupture (SGTR), but the amount of void formed is much less than during a MSLB. The major concern for the SGTR is the primary to secondary leakage and consequently the amount of radioactivity released from the secondary side. Voids form in the upper head region after the reactor trips on low pressurizer pressure and forced RCS flow is lost due to a concurrent loss of offsite power. These voids act as a second pressurizer and hold up the RCS pressure so there is more primary to secondary leakage and hence more radioactivity released. However, the calculated increase in released radioactivity is still within the SRP acceptance criteria.

III. EVALUATION

The CESEC computer program, which was used to analyze the Chapter 15, depressurization and overcooling events with an explicit upper reactor vessel region, has been checked with experiments and approved by the NRC. The staff finds that: (1) the steam void effect on the DNB ratio is negligible and (2) the calculated minimum 200 cubic feet of water between the steam void and hot legs in these reactor is sufficient to prevent the blocking of flow in the hot legs and that the consequences of this steam void in the upper reactor vessel region are acceptable for all of the non-LOCA, Chapter 15 depressurization and overcooling events.

IV. CONCLUSION

The staff concludes that the voids generated in the reactor coolant system of Combustion Engineering plants during any anticipated event are accounted for in present analysis models even though these models and analyses are not described in the FSARs of the older plants. The staff further concludes that this steam void will not result in unacceptable consequences in any of these CE plants.

Principal Contributor:
E. Lantz, DSI

REFERENCES

1. Reid, R. W. "Concern for Voiding During Transients on B&W Plants", dated January 9, 1980.
2. Check, P. S. "Void Formation in Vessel Head During St. Lucie Natural Circulation Cooldown Event of June 11, 1980, dated August 12, 1980.
3. U.S.N.R.C. "Clarification of TMI Action Plan Requirements"; NUREG-0737; page II.K.2.17-1, dated November, 1980.
4. U.S.N.R.C. "Natural Circulation Cooldown (Generic Letter No. 81-21)", dated May 5, 1981.
5. Nuclear Power Systems Division, Combustion Engineering Incorporated; "Effects of Vessel Head Voiding During Transients and Accidents in C-E NSSS's", CEN-199; March 1982.